



Healthy People Healthy Communities

JERRY AYCOCK  
PLANTATION PIPE LINE  
1000 WINDWARD CONCOURSE  
SUITE 450  
ALPHARETTA GA 30005

MAY 12 2019



Re: Review of Request for Modification of Product Recovery Activities & Revised Pumping Plan  
Plantation Pipe Line Lewis Drive Release, 112 Lewis Drive, Belton, SC  
Anderson County  
Site #18693  
Petroleum Pipe Line Release Reported December 8, 2014  
Request for Modification or Recovery Activities received January 13, 2019  
Lewis Drive Revised Pumping Plan received February 13, 2019

Dear Mr. Aycock,

The South Carolina Department of Health and Environmental Control (DHEC) has reviewed the above referenced documents. The following comments and/or recommendations are provided:

In regards to the Request for Modification of Recovery Activities;

- 1) The request to remove all passive skimmers and petroleum absorbent socks from all recovery features at the site is denied. However, DHEC does agree for the removal of the skimmers or socks from the following locations, MW-08, MW-15, RS-10, RS-17 and RW-08. These features have been absent of free phase product (FPP) since September 2017.
- 2) MW-08, MW-15, RS-10, RS-17 and RW-08 will continue to be monitored according to the new Annual Monitoring, Reporting and Product Recover Plan that is to be submitted to DHEC by April 30, 2020. If FPP is present it will be removed by hand bailer or absorbent sock at that time.


In regards to the Revised Pumping Plan;

- 1) The pumping of residuum well MW-23 and bedrock wells MW-12B, MW-15B and 17B will continue. The pumping frequency of these wells will be in accordance with the April 1, 2020 to March 31, 2021 Monitoring, Reporting, and Product Recovery Plan. The new plan is due by April 30, 2020.
- 2) DHEC agrees to the addition of pumping residuum wells MW-07, MW-11, MW-36, and MW-45 and bedrock wells MW-13B and MW-50B. The pumping frequency for these wells will also be determined by the submittal of the new Monitoring, Reporting and Product Recovery Plan.

- 3) DHEC agrees to discontinuing the pumping of MW-34, MW-40 and MW-46. MW-34 and MW-40 are low yield residuum wells that pump dry rapidly (<10 minutes) and are slow to recharge (<5 gal/hr). MW-46 is located in the area of the recent oxidant injection work that occurred in August 2019.

DHEC should be notified a minimum of four days prior to any environmental work being conducted. Documents should continue to be provided in paper format and pdf via a disk with Site ID # 18693 and Plantation Pipe Line Lewis Drive Release noted in a prominent location. Should you have any questions, I can be reached at (803) 898-7542 or [mendenje@dhec.sc.gov](mailto:mendenje@dhec.sc.gov). Faxes can be sent to (803) 898-0673.

Sincerely,



Ed Mendenhall, Hydrogeologist  
Assessment & Non-Permitted Petroleum Section  
Underground Storage Tank Management Division  
Bureau of Land and Waste Management

CC: Chris McCluskey, Upstate EA Region Anderson Office  
William Waldron, Jacobs, 3120 Highwoods Blvd., Suite 214, Raleigh, NC 27604  
Gary Poliakoff, Poliakoff & Associates, PO Box 1571, Spartanburg, SC 29304  
Scott Lewis, 15 Edgewood Drive, Williamston, SC 29697  
Eric Lewis, 421 Reedy Fork Road, Greenville, SC 29605  
Technical File