



SC DEPARTMENT of
**ENVIRONMENTAL
SERVICES**

Greg Cassidy
Bureau of Land and Waste Management
2600 Bull Street
Columbia, SC 29201

July 2, 2025

Ms. Nancy Parr
Westinghouse CFFF
5801 Bluff Road
Hopkins, SC 29061

RE: Monitoring Well Permit (SARRMW-00717v1.0)
Westinghouse CFFF Site
Richland County, South Carolina

Dear Ms. Parr:

The Division of Site Assessment, Remediation, and Revitalization (the Department) has reviewed the request to install monitoring wells at the Westinghouse CFFF Site as described in the Monitoring Well Application received on July 2, 2025.

Based on this review, approval for the installations are granted under R.61-71 of the South Carolina Well Standards and Regulations. Once the data is received, a report should be sent to the Department summarizing the recent work. Should you have any questions regarding the above, you may contact me at (803) 898-0910.

Sincerely,

A handwritten signature in cursive script, appearing to read "Greg Cassidy".

Greg Cassidy, Project Manager
State Remediation Section
Division of Site Assessment, Remediation and Revitalization
Bureau of Land and Waste Management

cc: Jessica Price, DES BRLS
Lucas Berresford, BLWM
Jeremy Grant, AECOM
File # 51377

Monitoring Well Approval

Approval is hereby granted to: Ms. Nancy Parr
Facility: Westinghouse CFFF Site
Richland County

This approval is for the installation of up to 18 groundwater monitoring wells. The monitoring well is to be installed in the areas described by AECOM and per the proposed construction details provided in the request. The monitoring well is to be installed following all applicable requirements of R.61-71.

Please note that R.61-71 requires the following:

1. All wells shall be drilled, constructed, and abandoned by a South Carolina certified well driller per R.61-71.D.1.
2. All wells shall be properly developed per R.61-71.H.2.d. A Water Well Record Form or other form provided or approved by the Department shall be completed and submitted within 30 days after well completion or abandonment unless the Department has approved another schedule. The form should contain the "as-built" construction details and all other information required by R.61-71.H.1.f
3. All analytical data and water levels obtained from each monitoring well shall be submitted to the Department within 30 days of receipt of laboratory results unless another schedule has been approved by the Department as required by R.61-71.H.1.d.
4. All monitoring wells shall be labeled as required by R.61-71.H.2.c.
5. All soil borings points that penetrate any confining unit must be grouted in accordance with R. 61-71.
6. If any of the information provided to the Department changes, the Author (Greg Cassidy) shall be notified a minimum of twenty-four hours prior to well construction as required by R.61-71.H.1.a.

This approval is pursuant to the provisions of Section 44-55-40 of the 1976 South Carolina Code of Laws and R.61-71 of the South Carolina Well Standards and Regulations, dated May 27, 2016.

Date of Issuance: 07-02-2025

Approval #: SARRMW-00717v1.0



Greg Cassidy, Project Manager
State Remediation Section
Division of Site Assessment, Remediation and Revitalization
Bureau of Land and Waste Management