



**Wastewater System Construction**

**APPROVAL TO PLACE INTO OPERATION**

**ISSUED TO:** US DEPARTMENT OF EI  
SAVANNAH RIVER SITE  
BUILDING 705-3C  
AIKEN SC 29808

*Please file in  
Construction Permit  
No. 19,219-IW as  
a supplemental  
Record. Thanks*

for the operation of a wastewater treatment/collecti  
Permit No. 19,219-IW, dated August 6, 2008. This  
Construction Permit No. 19,164-IW, dated January  
installation of three (3) waste transfer line segments

**PROJECT NAME:** SRS/SALT WASTE PROCESSIN

**COUNTY:** Aiken

**PROJECT DESCRIPTION:** The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for disposal at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A lists the SWPF equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be disposed as a solid waste in canisters that are transferred to the Glass Waste Storage Buildings.

**PERMITTED FLOW:** System Nominal Daily Flow: 35,840 gallons per day  
System Design Capacity Flow: 185,736 gallons per day

**WWTP:** US DOE/SAVANNAH RIVER SITE Salt Waste Processing Facility (SWPF)

**SPECIAL CONDITIONS:**

1. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by Construction Permit No. 20,234-IW. There shall be no radioactive salt solution received from the HLW tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued an Approval to Place into Operation for Construction Permit No. 20,234-IW.

2. The use of water, chemicals, and non-radioactive materials to support SWPF activities such as flushing, cleaning, startup testing, and demonstrations to validate performance of components and/or systems is allowed as long as the jumpers in Condition #1 have not been installed or the jumpers are physically isolated from the SWPF.
3. NPDES Permit No. SC0000175 allows the disposal of "scavenger" wastewater. If the wastewater is not scavenger wastewater, a written request shall be submitted to the Department describing this wastewater. No discharge of this wastewater may be performed without the written approval from the Department.
4. Note that Construction Permit No. 20,194-IW was issued for the Next Generation Solvent Cold Chemical Feed Facility. This facility is in addition to Construction Permit No. 19,219-IW that was issued for the SWPF.

This approval is based on the Engineer's letter of certification signed by James C. Somma, P.E., South Carolina Registration No. 14718 (Parsons).

 **Date Issued:** August 14, 2019  
Barry S Mullinax, Engineer  
(for) Environmental Affairs  
AIKEN EA OFFICE

cc: Bureau of Water Permitting File – Construction Permit No. 19,219-IW  
Bureau of Water Permitting File – Construction Permit No. 20,194-IW  
Bureau of Water Permitting File – Construction Permit No. 20,234-IW  
Travis Fuss, Aiken EA Office  
Shawn M. Clarke, BOW – Columbia  
Crystal Rippy, BOW - Columbia  
Crystal Robertson, Aiken EA Office  
James Somma, P.E., Parsons

**Attachment A for SWPF Approval to Operate (APO)**

**SWPF Equipment List (Drawing No. G-P1-J-00001)**

**PROCESS BUILDING – PROCESS EQUIPMENT**

| Tank Number              | Tank Name                                  |
|--------------------------|--|
| <b>Process Cell Area</b> |  |
| TK-101                   | Alpha Sorption Tank-A (AST-A)              |
| TK-102                   | Filter Feed Tank-A (FFT-A)                 |
| TK-103                   | Cleaning Solution Dump Tank-A (CSDT-A)     |
| TK-104                   | Sludge Solids Receipt Tank (SSRT)          |
| TK-105                   | Wash Water Hold Tank (WWHT)                |
| TK-109                   | Salt Solution Feed Tank (SSFT)             |
| TK-121A/B/C              | Back Pulse Tank                            |
| TK-123                   | Washing Filter Back Pulse Tank             |
| TK-127                   | <b>Spent Acid Storage Tank (SAST)</b>      |
| TK-205                   | Strip Effluent Hold Tank (SEHT)            |
| TK-208                   | Solvent Drain Tank                         |
| TK-235                   | Lab Drain Tank                             |
| TK-505                   | <b>Backup Air Receiver</b>                 |
| TK-506                   | <b>Backup Air Receiver</b>                 |
| TK-601                   | Alpha Sorption Drain Tank (ASDT)           |
| <b>Operating Deck</b>    |  |
| TK-122                   | Back Pulse Charge Tank-A                   |
| TK-128                   | AST-A Air Pulse Agitator Charge Tank       |
| TK-129                   | FFT-A Air Pulse Agitator Charge Tank       |
| TK-131                   | SSRT Air Pulse Agitator Charge Tank        |
| TK-132                   | SSFT Air Pulse Agitator Charge Tank        |
| TK-133                   | WWHT Air Pulse Agitator Charge Tank        |
| <b>CSSX Tank Cell</b>    |  |
| TK-202                   | Solvent Hold Tank (SHT)                    |
| TK-203                   | Strip Effluent Coalescer                   |
| TK-204                   | Caustic Wash Tank                          |
| TK-206                   | Ba-137 Decay Tank (BDT)                    |
| TK-211                   | Decontaminated Salt Solution Stilling Tank |
| TK-212                   | Strip Effluent Stilling Tank               |
| TK-215                   | Strip Effluent Pump Tank                   |
| TK-217                   | Solvent Strip Feed Tank                    |

| <b>Tank Number</b>              | <b>Tank Name</b>                         |
|---------------------------------|--|
| <b>CSSX Contactor Drop Area</b> |  |
| TK-201                          | Decon. Salt Solution Coalescer           |
| <b>Cold Chemicals Area</b>      |  |
| TK-106                          | Filter Cleaning Acid Feed Tank           |
| TK-107                          | Filter Cleaning Caustic Tank             |
| TK-108                          | Caustic Dilution Feed Tank               |
| TK-301                          | Process Water Tank                       |
| TK-302                          | Caustic Receipt Tank                     |
| TK-303                          | Caustic Makeup Tank                      |
| TK-304                          | Nitric Acid Receipt Tank                 |
| TK-305                          | Process Water Pressure Tank              |
| TK-307                          | Nitric Acid Scrub Makeup Tank            |
| TK-311                          | MST Storage Tank                         |
| TK-312                          | DI Water Storage Tank                    |
| TK-313                          | Solvent Makeup Tank                      |
| <b>TK-314</b>                   | <b>DI Water Expansion Tank</b>           |
| TK-317                          | Neutralization Tank                      |
| TK-330                          | Argon Tank                               |
| <b>CSSX Contactor Area</b>      |  |
| EXT-201A-P                      | Solvent Extraction Contactors            |
| EXT-202A/B                      | Scrub Contactors                         |
| EXT-203A-P                      | Stripping Contactors                     |
| EXT-204A/B                      | Caustic Wash Contactors                  |
| <b>Process Filters</b>          |  |
| FLT-102A/B/C                    | Alpha Sorption Filters                   |
| FLT-104                         | Washing Filter                           |
| <b>Alpha Finishing Facility</b> |  |
| TK-207                          | DSS Hold Tank (DSSHT)                    |
| TK-220                          | Intermediate Storage Tank (IST)          |
| TK-221                          | Alpha Sorption Tank - B (AST-B)          |
| TK-222                          | Filter Feed Tank - B (FFT-B)             |
| TK-223                          | Cleaning Solution Dump Tank - B (CSDT-B) |
| TK-224                          | MST/Sludge Transfer Tank (MSTT)          |
| <b>TK-225A/B/C</b>              | <b>Finishing Area Back Pulse Tank</b>    |
| <b>TK-228</b>                   | <b>Alpha Finishing Drain Tank (AFDT)</b> |
| <b>TK-233</b>                   | <b>Back Pulse Charge Tank B</b>          |
| <b>TK-236/237</b>               | <b>Lab Collection Tank</b>               |
| <b>TK-604</b>                   | <b>Low Level Drain Tank</b>              |
| <b>FLT-222A/B/C</b>             | <b>Alpha Sorption Filters</b>            |

| <b>PUMPS</b>                            |   |
|---|---|
| <b>North ASP Pump and Valve Gallery</b> |   |
| P-015A                                  | ASP Secondary Loop Pump Water Pump        |
| P-015B                                  | ASP Secondary Loop Pump Water Pump        |
| P-101A/B                                | Alpha Sorption Tank-A Transfer Pumps      |
| P-102-1A/B/C                            | Filter Feed/Solids Trans Pumps            |
| P-102-2 A/B/C                           | Filter Recirculation Pumps                |
| P-104-1                                 | Washing FLT Feed/Sludge Solids Trans Pump |
| P-104-2                                 | Washing Filter Recirculation Pump         |
| P-110                                   | ASP Sump Trans Pump                       |
| <b>South ASP Pump and Valve Gallery</b> |   |
| P-105A/B                                | Wash Water Trans Pumps                    |
| P-208A/B                                | Solvent Drain Tank Pumps                  |
| P-601A/B                                | Alpha Sorption Drain TK Transfer Pumps    |
| <b>CSSX Pump and Valve Gallery</b>      |   |
| P-109A/B                                | Salt Solution Feed Pumps                  |
| P-202A/B                                | Solvent Feed Pumps                        |
| P-204A/B                                | Caustic Wash Tank Pumps                   |
| P-205A/B                                | Strip Effluent Trans Pumps                |
| P-206A/B                                | Ba-137 Decay Tank Trans Pumps             |
| P-212A/B                                | Strip Effluent Coalescer Feed Pumps       |
| P-215A/B                                | Strip Effluent Pump Tank Pumps            |
| P-217A/B                                | Solvent Strip Feed Pumps                  |
| P-218                                   | CSSX Tank Cell Sump Transfer Pump         |
| <b>Sample Pump and Valve Gallery</b>    |   |
| SP-101                                  | Alpha Sorption Tank-A Sample Pump         |
| SP-102                                  | Filter Feed Tank-A Sample Pump            |
| SP-103                                  | Cleaning Solution Dump Tank-A Sample Pump |
| SP-104                                  | Sludge Solids Receipt Tank Sample Pump    |
| SP-105                                  | Wash Water Hold Tank Sample Pump          |
| SP-109                                  | Salt Solution Feed Tank Sample Pump       |
| SP-205                                  | Strip Effluent Hold Tank Sample Pump      |
| SP-235                                  | Lab Drain Tank Sample Pump                |
| <b>Drum off/Decon Area</b>              |   |
| P-605                                   | Decon Area Sump Pump                      |

| <b>PUMPS (continued)</b>        |   |
|---------------------------------|---|
| <b>Cold Chemicals Area</b>      |   |
| P-106                           | <b>Acid Transfer Pump</b>                       |
| P-107                           | Filter Cleaning Caustic Trans Pump              |
| P-108                           | Caustic Dilution Trans Pump                     |
| P-300                           | Cold Chemicals Receiving Dock Sump Pump         |
| P-301-1                         | Process Water Utility Pump                      |
| P-301-2                         | Flush Pump                                      |
| P-302                           | Caustic Trans Pump                              |
| P-303                           | Caustic Makeup Trans Pump                       |
| P-304-1                         | Nitric Acid Metering Pump                       |
| P-304-2                         | Neutralization Metering Pump                    |
| P-305A/B                        | Sodium Hypochlorite Addition Pump               |
| P-309A/B                        | Scrub Feed Pumps                                |
| P-310A/B                        | Strip Feed Pumps                                |
| P-311                           | MST Transfer Pump                               |
| P-311-1                         | MST Drum Pump                                   |
| P-312-1                         | DI Water Trans Pump                             |
| P-312-2                         | Scrub Water Feed Pump                           |
| P-312-3A/B                      | Strip Water Feed Pumps                          |
| P-313                           | Solvent Makeup Trans Pump                       |
| P-313-1                         | Solvent Drum Pump                               |
| P-317                           | Neutralization Tank Discharge Pump              |
| P-318                           | Caustic Sump Pump                               |
| P-319                           | <b>Acid Sump Pump</b>                           |
| P-320                           | Neutralization Sump Pump                        |
| P-321                           | Nitric Acid Sump Pump                           |
| P-322                           | Water Sump Pump                                 |
| P-326                           | Pump Seal Make-up Water Supply Pump             |
| <b>Alpha Finishing Facility</b> |   |
| P-207A/B                        | <b>DSS Hold Tank Transfer Pumps</b>             |
| P-220A/B                        | <b>Intermediate Storage Tank Transfer Pumps</b> |
| P-221A/B                        | <b>Alpha Sorption Tank B Transfer Pumps</b>     |
| P-222-1A/B/C                    | <b>Filter Feed/Solids Transfer Pumps</b>        |
| P-222-2A/B/C                    | <b>Filter Recirculation Pumps</b>               |
| P-224                           | <b>MST/Sludge Transfer Pump</b>                 |
| P-228                           | <b>Alpha Finishing Drain Tank Transfer Pump</b> |
| <b>PUMPS (continued)</b>        |   |

|                                     |   |
|-------------------------------------|---|
| <b>P-236</b>                        | <b>Lab Collection Tank Pump</b>                       |
| <b>P-604</b>                        | <b>Low Level Drain Tank Transfer Pump</b>             |
| <b>P-025A/B</b>                     | <b>AFP Secondary Cooler Loop Pump</b>                 |
| <b>SP-207, SP-220 – SP-224</b>      | <b>Sample Pumps</b>                                   |
| <b>P-210, P-226, P-227, P-228-1</b> | <b>AFF Sump Pumps</b>                                 |
| <b>P-229</b>                        | <b>Alpha Finishing Process Filter Loop Drain Pump</b> |
| <b>AGITATORS</b>                    |   |
| <b>AGT-107</b>                      | <b>Filter Cleaning Caustic Tank Agitator</b>          |
| <b>AGT-108</b>                      | <b>Caustic Dilution Feed Tank Agitator</b>            |
| <b>AGT-303</b>                      | <b>Caustic Makeup Tank Agitator</b>                   |
| <b>AGT-307</b>                      | <b>Nitric Acid Scrub Makeup Tank Agitator</b>         |
| <b>AGT-311</b>                      | <b>MST Storage Tank Agitator</b>                      |
| <b>AGT-311-1</b>                    | <b>MST Drum Agitator</b>                              |
| <b>AGT-313</b>                      | <b>Solvent Makeup Tank Agitator</b>                   |
| <b>AGT-221</b>                      | <b>Alpha Sorption Tank B Agitator</b>                 |
| <b>AGT-222</b>                      | <b>Filter Feed Tank B Agitator</b>                    |
| <b>AGT-224</b>                      | <b>MST/Sludge Transfer Tank Agitator</b>              |
| <b>LABORATORY EQUIPMENT</b>         |   |
| <b>GB-001 – GB-011, GB-014</b>      | <b>Glove Boxes</b>                                    |
| <b>RH-001 – RH-017</b>              | <b>Radio Hoods</b>                                    |
| <b>FH-001</b>                       | <b>Fume Hood</b>                                      |
| <b>HC-001 – HC-004</b>              | <b>Hot Cell Windows</b>                               |
| <b>STS-101</b>                      | <b>Sample Transfer System</b>                         |
| <b>ELECTRICAL SYSTEMS</b>           |   |
| <b>ATS-203 – ATS-205</b>            | <b>Automatic Transfer Switch</b>                      |
| <b>ATS-207</b>                      | <b>Automatic Transfer Switch</b>                      |
| <b>ATS-208</b>                      | <b>Automatic Transfer Switch</b>                      |
| <b>ATS-210</b>                      | <b>Automatic Transfer Switch</b>                      |
| <b>MCC-201 – MCC-206</b>            | <b>Motor Control Center</b>                           |
| <b>MCC-209 – MCC-210</b>            | <b>Motor Control Center</b>                           |
| <b>SWGR-201 – SWGR-204</b>          | <b>Switchgear</b>                                     |
| <b>USX-301</b>                      | <b>Uninterruptible Power Supply</b>                   |

| <b>INSTRUMENTATION</b>                                    |   |
|---|---|
| ICP-001 – ICP-013   | Instrument Control Panel                      |
| ICP-014 – ICP-016   | Instrument Control Panel                      |
| IR-001 – IR-014, IR-016 – IR-022, IR-024, IR-026 – IR-040 | Instrument Control Rack                       |
| <b>AIR HANDLING EQUIPMENT</b>                             |   |
| ACU-001   | Wall Mounted Heat Pump                        |
| AHU-001 – AHU-006   | Air Handling Units                            |
| AHU-008 – AHU-009   | Air Handling Units                            |
| <b>Filters/Fans/Coils</b>                                 |   |
| CCL-401A/B  | Process Vessel Vent Coolers                   |
| CCL-402A/B  | Pulse Mixer Vent Coolers                      |
| FAN-401A/B  | Process Vessel Vent Exhaust Fans              |
| FAN-402A/B  | Pulse Mixer Vent Exhaust Fans                 |
| FAN-001   | Exhaust Fan                                   |
| FAN-002   | Exhaust Fan                                   |
| FAN-003   | Exhaust Fan on Roof                           |
| FAN-004   | Exhaust Fan on Roof                           |
| FAN-007   | Exhaust Fan on Roof                           |
| FAN-009   | Exhaust Fan on Roof                           |
| FAN-010   | Exhaust Fan on Roof                           |
| FAN-013   | Exhaust Fan on Roof                           |
| FAN-014   | Exhaust Fan on Roof                           |
| FAN-015   | Exhaust Fan on Roof                           |
| FLT-001 – FLT-004   | Exhaust Air HEPA Filters                      |
| FLT-009   | Lab Exhaust Air HEPA Filter                   |
| FLT-010 – FLT-016   | Cell Inlet Air HEPA Filters                   |
| FLT-017   | Lab Exhaust Air HEPA Filter                   |
| FLT-020   | Hot Lab Intake Filter Above Suspended Ceiling |
| FLT-021   | Hot Cell Exhaust Air HEPA Filter              |
| FLT-022   | Hot Cell Exhaust Air HEPA Filter              |
| FLT-023 – FLT-034   | Glovebox Inlet Air HEPA Filters               |
| FLT-240 – FLT-242   | Solvent Recovery Filters                      |
| FLT-250   | Solvent Adjustment Filter                     |
| FLT-301A/B  | Process Water Cartridge Filter                |
| FLT-401A/B  | Process Vessel Vent Filters                   |
|   |   |



**AIR HANDLING EQUIPMENT (continued)**

|                    |  |
|--------------------|--|
| FLT-402A/B/C/D     | Pulse Mixer Vent Filters                 |
| HRC-001            | Heat Recovery Coil                       |
| <b>Scrubbers</b>   |  |
| SCB-001            | Scrubber                                 |
| SCB-002            | Scrubber                                 |
| SCB-003            | Hot Cell Scrubber                        |
| SCB-004            | Hot Cell Scrubber                        |
| SCFS-001           | Scrubber Caustic Feed System             |
| SCFS-002           | Scrubber Caustic Feed System             |
| <b>Separators</b>  |  |
| SEP-001            | Bldg Chilled Water Air Separator         |
| SEP-003            | Control Room Chilled Water Air Separator |
| SEP-005            | Process Chilled Water Air Separator      |
| SEP-007            | Heat Recovery Air Separator              |
| <b>Pumps</b>       |  |
| P-001A/B           | Bldg Chilled Water Supply Pumps          |
| P-003A/B           | Control Room Chilled Water Pumps         |
| P-005A/B           | Process Chilled Water Supply Pumps       |
| P-007A/B           | Heat Recovery Water Pumps                |
| <b>Tanks</b>       |  |
| TK-001             | Bldg Chilled Wtr Exp Tank                |
| TK-002             | Bldg Chilled Wtr Chem Feed Tank          |
| TK-003             | Control Room Chilled Wtr Exp Tank        |
| TK-004             | Control Room Chilled Wtr Chem Feed Tank  |
| TK-005             | Process Chilled Wtr Exp Tank             |
| TK-006             | Process Chilled Wtr Chem Feed Tank       |
| TK-007             | Heat Recovery Bladder Exp Tank           |
| TK-008             | Heat Recovery Chemical Feed Tank         |
| TK-015             | Process Chilled Water Expansion Tank     |
| TK-016             | Chemical Bypass Feeder Tank              |
| TK-025             | Process Chilled Water Expansion Tank     |
| <b>Ventilators</b> |  |
| VLR-001            | Gravity Roof Ventilator                  |
| VLR-002            | Gravity Roof Ventilator                  |

**MISCELLANEOUS ITEMS**

|                    |  |
|--------------------|--|
| <b>BTR-001</b>     | <b>DW Pressure Booster System</b>                    |
| <b>CMP-504</b>     | <b>Back Up Air Receiver Compressor</b>               |
| <b>DMST-401A/B</b> | <b>Process Vessel Vent Demisters</b>                 |
| <b>DMST-402A/B</b> | <b>Pulse Mixer Vent Demisters</b>                    |
| <b>FAN-005</b>     | <b>Exhaust Fan</b>                                   |
| <b>FAN-006</b>     | <b>Exhaust Fan</b>                                   |
| <b>FLT-007</b>     | <b>Exhaust Air HEPA Filter</b>                       |
| <b>HTR-007</b>     | <b>Domestic Water Heater/Tank</b>                    |
| <b>HTR-017A/B</b>  | <b>Strip Contactors Tempered Water Heaters</b>       |
| <b>HTR-203A/B</b>  | <b>Solvent Strip Feed Tempered Water Heaters</b>     |
| <b>HTR-310A/B</b>  | <b>Strip Feed Heaters</b>                            |
| <b>HTR-401A/B</b>  | <b>Process Vessel Vent Heaters</b>                   |
| <b>HTR-402A/B</b>  | <b>Pulse Mixer Vent Heaters</b>                      |
| <b>HX-015</b>      | <b>ASP Secondary Loop Cooler</b>                     |
| <b>HX-025</b>      | <b>AFP Secondary Loop Cooler</b>                     |
| <b>HX-102A/B/C</b> | <b>Filter Recirculation Coolers</b>                  |
| <b>HX-104</b>      | <b>Washing Filter Recirculation Cooler</b>           |
| <b>HX-201</b>      | <b>Salt Solution Feed Cooler</b>                     |
| <b>HX-202A/B</b>   | <b>Solvent Feed Coolers</b>                          |
| <b>HX-203</b>      | <b>Strip Contactor Tempered Water Heat Exchanger</b> |
| <b>HX-217A/B</b>   | <b>Solvent Strip Feed Heat Exchanger</b>             |
| <b>HX-222A/B/C</b> | <b>Filter Recirculation Coolers</b>                  |
| <b>HX-250</b>      | <b>Solvent Adjustment Heat Exchanger</b>             |
| <b>IX-312</b>      | <b>DI Water Package Unit</b>                         |
| <b>SEP-015</b>     | <b>Process Chiller Water Air Separator</b>           |
| <b>SEP-025</b>     | <b>Process Chilled Water Separator</b>               |
| <b>VMP-001</b>     | <b>Vibration Monitor Panel</b>                       |



Attachment B. Process Flow Drawings

1. G-M1-J-00001, SWPF Process Flow Drawing Index (U)
2. G-M1-J-00002P, SWPF Process Flow Legend Sheet (U)
3. M-M5-J-0001P, SWPF Simplified Process Flow Schematic (U)
4. M-M5-J-0002P, SWPF Feed Receipt, Alpha Sorption Tank-A, Filter Feed Tank-A, and Cleaning Solution Dump Tank-A PFD (U)
5. M-M5-J-0003P, SWPF Alpha Sorption Filters FLT-102A/B/C PFD (U)
6. M-M5-J-0004P, SWPF Sludge Solids Washing Filter, Sludge Solids Receipt Tank and Wash Water Hold Tank PFD (U)
7. M-M5-J-0005P, SWPF Cold Chemical Makeup for Filter Cleaning and Feed Adjustment PFD (U)
8. M-M5-J-0006P, SWPF Salt Solution Feed Tank and Solvent Drain Tank PFD (U)
9. M-M5-J-0007P, SWPF Solvent Extraction and Acid Scrub PFD (U)
10. M-M5-J-0008P, SWPF Solvent Stripping and Caustic Wash PFD (U)
11. M-M5-J-0009P, SWPF DSS Coalescer, DSS Hold Tank and Transfer Pumps PFD (U)
12. M-M5-J-0010P, SWPF Cold Chemical Makeup and Process Water Tank PFD (U)
13. M-M5-J-0011P, SWPF Cold Chemical Makeup Tank PFD (U)
14. M-M5-J-0012P, SWPF Solvent Extraction Strip and Scrub Feed Pumps PFD (U)
15. M-M5-J-0013P, SWPF Solvent Makeup Tank PFD (U)
16. M-M5-J-0014P, SWPF Process Vessel Vent System PFD (U)
17. M-M5-J-0015P, SWPF Intermediate Storage Tank, Alpha Sorption Tank-B, Filter Feed Tank-B, and Cleaning Solution Dump Tank-B PFD (U)
18. M-M5-J-0016P, SWPF Alpha Sorption Filters FLT-222A/B/C PFD (U)
19. M-M5-J-0018P, SWPF Lab Drain Tank, Alpha Sorption Drain Tank and Spent Oxalic Acid Storage Tank PFD (U)

STATE OF CALIFORNIA  
DEPARTMENT OF THE PUBLIC UTILITIES  
BUREAU OF WATER  
WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)


FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW EXPIRES DATE Aug. 6, 2008


  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION











- NOTES**
- SEE DRAWING C-W-1-0002 FOR LEGEND.
  - DELETED.
  - LOW FEED TRANSFER ASSIGNED AT 130 GPM. DETAILS OF TRANSFER ARE PROVIDED IN 102-10, 104-P-100010.
  - TANK FILLING IS TO BE PROVIDED TO IN-TANK FLOTATION FOR ALL TANKS. BUT DETAILS ARE NOT SHOWN OR DRAWING.
  - REFER TO WWS BALANCE MODEL NUMBER P-101-00001, REV. 1 FOR DETAILED FLOW DATA FOR FLOW STREAMS. RATES AND FLOW VALUES ARE BASED ON TWO 40% STRIKES. ONE IN TK-101 (LAST 40%) AND ONE IN TK-102 (LAST 40%). DENSITY AND GRAVITY VALUES FOR FILTRATION LOOP ASSUME SPENT DIALIC ACID IS ADDED TO TK-104 AFTER SOLIDS WASHING.
  - DELETED.
  - LINE FLUSH IS PERFORMED AFTER TRANSFER OF ALL SOLIDS TRANSFERS.
  - TWO FILTER CIRCUITS WILL NORMALLY OPERATE WITH THE THIRD FILTER CIRCUIT AS A SPARE.
  - BATCH SIZE OF 23,300 GALLONS AND PEAK INSTANTANEOUS THROUGHPUT OF 2.1 MGAL PER HOUR (BASED ON MAXIMUM) FOR THE SINGLE STRIKE PROCESS OR FOR THE TWO STRIKE PROCESS DURING THE 40%.
  - TK-102 IS TO BE TEMPERATURE CONTROLLED TO 73°F (15°F) FOR OPTIMAL WWT ADAPTATION.
  - NOTE: TO BE USED FOR DETERMINING THE FILTERS AND/OR FILTER STRIPPER. LANE BENTS WILL BE USED WHEN FILTERS ARE SHUT DOWN UNTIL THE AFFECTED FILTER CAN BE ISOLATED.
  - LINE PROVIDED FOR CYS RECICLE TO PERMIT ADDITIONAL CYS STRIKE IN TK-102 IF REQUIRED.
  - DELETED.
  - LINE PROVIDED FOR WWT RECICLE FROM TK-104 FOR HOUSE OF RECYCLED.
  - LOW INLET TEMPERATURES WILL VARY BETWEEN 67°F AND 67°F FOR 10-15, 10-20, 10-25, 10-30.
  - WWT NOT PROVIDED IN WWS FLOW CALCULATED BASED ON FLOWING DENSITY VALUES.
  - DELETED.
  - TK-102 TO BE TEMPERATURE CONTROLLED TO 73°F (15°F) TO MINIMIZE SOLIDS PRECIPITATION DOWNSTREAM OF THE FILTERS.
  - DELETED.
  - DIALIC ACID IS HEATED TO 104°F WHILE IN FILTER LOOPS.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
**WASTEWATER FACILITIES**  
 APPROVED FOR CONSTRUCTION  
 (SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)  
 FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THIS OFFICE AFTER COMPLETION OF CONSTRUCTION.  
 PERMIT NO. 19,219-IW DATE Aug. 6, 2008  
*[Signature]*  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION


WWT 5

| STREAM NO.        | 100      | 103               | 104  | 106                | 111         | 121                | 130                | 131                | 133                | 200                | 210                |
|-------------------|----------|-------------------|------|--------------------|-------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| STREAM NAME       | LOW FEED | WWT/CLARIFY EFF-A | FASS | FROM TANK TO P-110 | WWT/STORAGE | FROM TANK TO P-110 | FROM TANK TO P-110 | FROM TANK TO P-110 | FROM TANK TO P-110 | FROM TANK TO P-110 | FROM TANK TO P-110 |
| Flow              | 130      | 60                | 60   | 60                 | 60          | 60                 | 60                 | 60                 | 60                 | 60                 | 60                 |
| Mass Flow (lb/hr) | 130      | 60                | 60   | 60                 | 60          | 60                 | 60                 | 60                 | 60                 | 60                 | 60                 |
| Density           | 1.0      | 1.0               | 1.0  | 1.0                | 1.0         | 1.0                | 1.0                | 1.0                | 1.0                | 1.0                | 1.0                |
| Temperature       | 67       | 67                | 67   | 67                 | 67          | 67                 | 67                 | 67                 | 67                 | 67                 | 67                 |
| WWT               | 100      | 100               | 100  | 100                | 100         | 100                | 100                | 100                | 100                | 100                | 100                |
| WWT               | 100      | 100               | 100  | 100                | 100         | 100                | 100                | 100                | 100                | 100                | 100                |
| WWT               | 100      | 100               | 100  | 100                | 100         | 100                | 100                | 100                | 100                | 100                | 100                |

**PARSONS**  
 1000 STEWART STREET, SUITE 400 • ATLANTA, GE 30303 • 404.521.1100  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 WWS-1-0002P  
 WWS-1-0002P  
 SHEET 1 OF 1  
 SWPE-BOR







- NOTES**
- SEE DRAWING C-40-J-0002 FOR LEGEND.
  - DELETED.
  - REFER TO MASS BALANCE MODEL (MHW-7-001-0001), REV. 1 FOR DETAILED FLOW DATA FOR EACH STREAM. BATCH AND FLOW VALUES ARE BASED ON TWO HRT CIRCLES, ONE IN EACH HRT-A1 AND ONE IN HRT-B1. DENSITY AND BATCH VALUES FOR FILTRATION LEAK ASSUME SPENT SULFURIC ACID IS ADDED TO HRT-B1 AFTER SLUDGE WASHING.
  - EACH FILTER WILL BE DESIGNED FOR 50% OF REQUIRED TOTAL CAPACITY. TWO FILTER CIRCLES WILL NORMALLY OPERATE WITH THIRD FILTER CIRCUIT AS SPARE.
  - DELETED.
  - PRESSURE RESTRICTION DEVICE TO PROVIDE BACK PRESSURE ON FILTERS.
  - ON-LINE PARTICULATE ANALYER TO DETECT FILTER BREAKTHROUGHS.
  - ROUTE TO BE USED FOR CONDITIONING THE FILTERS DURING FILTER STARTUP. SAME ROUTE WILL BE USED WHEN FILTER BREAKTHROUGH OCCURS UNTIL THE AFFECTED FILTER CAN BE ISOLATED.
  - LINE PROVIDED FOR CDS RECEIVES TO POINT ADDITIONAL WET STREAM IN HRT-B1 IF REQUIRED.
  - WEEK NOT PROVIDED IN MHW. MASS FLOW CALCULATED BASED ON ASSUMED DENSITY VALUES.
  - DELETED.
  - ROUTE TO BE USED DURING FILTER CLEANING.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
 WASTEWATER FACILITIES  
 APPROVED FOR CONSTRUCTION  
 (SUBJECT TO ANY PROVISIONS WHICH MAY  
 APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
 BE OBTAINED FROM THIS OFFICE AFTER COM-  
 PLETION OF CONSTRUCTION.

PERMIT NO. 19219-IW DATE Aug. 6, 2008  
*[Signature]*  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION


NOTE 3

| STREAM NO.  | 102     | 103         | 104         | 105    | 106           | 107                      | 108   | 109 | 110 | 111 | 112 |
|-------------|---------|-------------|-------------|--------|---------------|--------------------------|-------|-----|-----|-----|-----|
| STREAM NAME | GW      | Filter Sump | Filter Tank | Filter | Filter to SST | Cleaning Solution Return | W-4   |     |     |     |     |
| Flow        | 60      | 1300        | 1200-22     | 1200   | 1200          | 40-22                    | 80-41 |     |     |     |     |
| Head Flow   | 0.00    | 302.0       | 328.0       | 324.0  | 320.0         | 316.0                    | 312.0 |     |     |     |     |
| Capacity    | 100 GPM | 10-02       | 10-02       | 10-02  | 10-02         | 10-02                    | 10-02 |     |     |     |     |
| Material    | 0.00000 |             |             |        |               |                          |       |     |     |     |     |
| WWT Station | 1       |             |             |        |               |                          |       |     |     |     |     |

| PHASE  | NO. | DATE  | REVISION                  | BY | CHKD | APPV | DATE  |
|--------|-----|-------|---------------------------|----|------|------|-------|
| DESIGN | 1   | 08-01 | DESIGNED FOR CONSTRUCTION | MS | MS   | MS   | 08-01 |
| CONSTR | 2   | 08-04 | REVISED FOR 08-04         | MS | MS   | MS   | 08-04 |
| OPER   | 3   | 08-06 | REVISED FOR 08-06         | MS | MS   | MS   | 08-06 |

**PARSONS**  
 1000 VICTORY DRIVE, SUITE 1000, WASHINGTON, DC 20001 (202) 462-1000  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 W-45-J-0003  
 SWFF  
 ALPHA SORPTION FILTERS  
 FLT-102A/B/C  
 PFD  
 (U)  
 W-45-J-0003 1A  
 SWFE-BOR





- NOTES**
- SEE DRAWING C-46-J-0000 FOR LEGEND.
  - DELETED.
  - MAIN WATER RECYCLE FLOW TO TK-101 IS FOR SINGLE BATCH TO A31-A.
  - PROCESS WATER POSITION RATE IS CONTROLLED TO MATCH WASHING FILTER FLOW RATE. CALLING FOR BATCH VALUE FOR THE WASHED SLODGE SOLIDS IS FOR 3 BATCHES. ALL REQUIREING TWO WAST STREAMS ONE IN 30 SEC AND ONE IN 10 SEC.
  - REFER TO MASS BALANCE MODEL MODEL P-104-1-0000, REV. 1 FOR DETAILED FLOW DATA FOR EACH STREAM. BATCH AND FLOW VALUES ARE BASED ON THE WAST STREAMS ONE IN 30 SEC (A31-A) AND ONE IN 10 SEC (A31-B). DENSITY AND BATCH VALUES ARE BASED ON THE WASH WATER HOLD TANK. WASH WATER HOLD TANK IS 11,500 GAL. WY.
  - DELETED.
  - DELETED.
  - TRANSCENDERS OF WAST-SLODGE TO DUFF WILL OCCUR IN BATCH SIZES OF APPROXIMATELY 1000 GALLONS. EXACT BATCHES, TRANSFER RATE AND FREQUENCY WILL VARY. DETAILS OF TRANSFER ARE PROVIDED IN THE P-104-1-0000.
  - DELETED.
  - TK-104 IS TO BE TEMPERATURE CONTROLLED TO 77°F (15°F).
  - DELETED.
  - CONTROL VALVE TO PROVIDE BACK PRESSURE ON FILTER.
  - DELETED.
  - DELETED.
  - WEN NOT PROVIDED IN MBL, MASS FLOW CALCULATED BASED ON PROVIDED DENSITY VALUES.
  - DELETED.
  - TANK FLOWS TO BE PROVIDED TO 20-TANK FLOW RING FOR ALL TANKS. TO BE DETAIL AND NOT SHOWN ON DRAWING.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
**WASTEWATER FACILITIES**  
**APPROVED FOR CONSTRUCTION**  
 (SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN ANY PERMITTING AGENCY'S PERMITTING DOCUMENTS)

PERMIT NO. 19-219-114 DATE Aug. 6, 2008  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION


NOTE 5

| STREAM NO.        | 126         | 116         | 117         | 118         | 119         | 120         | 121         | 122         | 123         | 124         | 125         | 127         |
|-------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| STREAM NAME       | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE | WAST-SLODGE |
| Flow              | 60          | 60          | 150         | 130         | 130         | 130         | 130         | 130         | 130         | 130         | 130         | 130         |
| Mass Flow (lb/hr) | 1080        | 1080        | 2700        | 2340        | 2340        | 2340        | 2340        | 2340        | 2340        | 2340        | 2340        | 2340        |
| Density           | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        | 18.0        |
| Temperature       | 77          | 77          | 77          | 77          | 77          | 77          | 77          | 77          | 77          | 77          | 77          | 77          |
| WAST-SLODGE       | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        | 17.0        |

| NO. | REV. | DATE     | DESCRIPTION             | BY  | CHKD. |
|-----|------|----------|-------------------------|-----|-------|
| 1   | 1    | 08/06/08 | ISSUED FOR CONSTRUCTION | JMS | SWPE  |
| 2   | 1    | 08/06/08 | ISSUED FOR CONSTRUCTION | JMS | SWPE  |
| 3   | 1    | 08/06/08 | ISSUED FOR CONSTRUCTION | JMS | SWPE  |

**PARSONS**  
 1000 STEVENSON BLVD., SUITE 200, CHARLOTTE, NC 28203 (404) 363-7100  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 SWF  
 WASHING FILTER, SLODGE SOLIDS RECEIPT TANK  
 AND WASH WATER HOLD TANK  
 PFD  
 (U)  
 JMS-J-0004P 1 OF 1  
 SWPE, BDR





**NOTES**

- SEE DRAWING C-W-2-0003 FOR LEGEND.
- OXALIC ACID WILL BE ENCLOSED FROM TANKER TRUCKS OR PORTABLE CONTAINERS.
- FILTER CLEANING CAUSTIC IS MADE UP ON AS REQUIRED BASIS.
- MST SLURRY WILL BE TRANSFERRED FROM PORTABLE DRUMS.
- DELETED.
- WHEN NOT PROVIDED IN MASS BALANCE MODEL, ITEM # 4-106-J-0000, REV. 7 MASS FLOW CALCULATED BASED ON TANKING DENSITY VALUES.
- REFER TO M&S FOR DETAILED FLOW DATA FOR EACH STREAM.
- RECIRCULATION LINE WILL BE PROVIDED TO TK-106 FOR HEATING.

**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER  
WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)

**FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THE OFFICE AFTER COMPLETION OF CONSTRUCTION.**

PERMIT NO. **19219-100** DATE **Aug 6, 2008**

*[Signature]*  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

**PARSONS**  
1000 STEWART BLVD, SUITE 2000, COLUMBIA, SC 29203 (803) 733-7100

UNITED STATES DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE

SWPF  
COLD CHEMICAL MAKEUP  
FOR FILTER CLEANING  
AND FEED ADJUSTMENT  
PFD

(U)


DATE: 8/6/08  
DRAWN BY: JMS-J-0005P  
SCALE: 1/1  
SHEET NO: 1A  
SWPFE-BOR

**NOTE 8**

| STREAM NO          | 300                       | 301              | 302                           | 303                           | 304                           | 305                           | 306                           | 307                           | 308                           | 309                           | 310                           | 311                           | 312                           |
|--------------------|---------------------------|------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|
| STREAM NAME        | OXALIC ACID RECEIPT TO SW | OXALIC ACID FEED | OXALIC ACID TO 10.5 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC | OXALIC ACID TO 1.66 M CAUSTIC |
| Flow               | 100                       | 100              | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           |
| Mass Flow (Mole H) | 100                       | 100              | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           |
| Density            | 1200                      | 1200             | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          | 1200                          |
| Temperature        | 80                        | 80               | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            | 80                            |
| Water              | 100                       | 100              | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           |
| OXALIC ACID        | 100                       | 100              | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           |
| WATER              | 100                       | 100              | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           | 100                           |

| NO. | REV. | DATE     | REVISION                | APP'D | CHECK'D | DATE | BY | DATE | BY |
|-----|------|----------|-------------------------|-------|---------|------|----|------|----|
| 1   | 1    | 08/06/08 | ISSUED FOR CONSTRUCTION |       |         |      |    |      |    |
| 2   | 1    | 08/06/08 | REVISED PER SWPF        |       |         |      |    |      |    |
| 3   | 1    | 08/06/08 | REVISED PER SWPF        |       |         |      |    |      |    |





**NOTES**

- SEE DRAWING C-41-J-0000 FOR LEGEND.
- DELETED.
- REFER TO MASS BALANCE MODEL NUMBER P-001-00001, REV. 1 FOR RECYCLED FLOW DATA FOR EACH STREAM. FLOW AND FLOW VALUES ARE BASED ON TWO MFC STREAMS: ONE IN TK-109 (LAST-A) AND ONE IN TK-208 (LAST-B).
- DELETED.
- LINE PROVIDED FOR PRELIMINARY COST PROCESS WHEN REQUIRED. FUTURE USE TO EXTRACT AND STORE AT SALTWORK PROCESS CESSION FROM FLOWING THROUGH THE CONTRACTORS TO TK-208 (155FT).
- DELETED.
- SOLVENT DRAIN TANK CONTENTS ARE PUMPED TO JACKET OF THE CESSION SYSTEM. THE CONTENTS IN TK-208 COULD POTENTIALLY CONTAIN HIGH CESSION.
- DELETED.
- WASH NOT PROVIDED IN MFC. MASS FLOW CALCULATED BASED ON HIGHER DENSITY VALUES.
- TANK FLOW TO BE PROVIDED TO TK-TANK FLOW RING FOR ALL DRAINS. SEE DETAILS AND SEE DRAWING.
- TK-109 INLET TEMPERATURE OF 33°F ASSUMES CONTINUOUS OPERATION OF AP AND CESSION.
- RECIRCULATION LINE WILL BE PROVIDED TO TK-109 FOR WASHING.
- TK-109 TO BE TEMPERATURE CONTROLLED TO 33°F (1±1°F).
- ALTERNATE FLOW PATH EXISTS TO TK-208 FROM TK-208. LAB DRAIN FROM TK-208 CONTAINS SOLVENT.
- INSUFFICIENT FLOW FLOW RECYCLED TO PROCESS. PUMP SIZED FOR TANK WASHING.

**S-C-DEPT. OF HEALTH & ENVIRONMENTAL CONTROL**  
**BUREAU OF WATER**  
**WASTEWATER FACILITIES**  
**APPROVED FOR CONSTRUCTION**  
(SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)  
**FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THE DIVISION OF CONSTRUCTION PERMITS AFTER COMPLETION OF CONSTRUCTION.**  
PERMIT NO. 19219-1W  
DATE August 4, 2008  
DIRECTOR, WASTEWATER PERMITTING DIVISION

**PARSONS**  
1000 11th Street, Suite 600 • Atlanta, GA 30309 • 404.533.3100  
UNITED STATES DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE  
WASTE WATER TREATMENT PLANT


SWPF  
SALT SOLUTION FEED TANK  
AND SOLVENT DRAIN TANK  
PFD  
(U)  
DATE: 11/11/11  
DRAWN BY: JMS-J-0006P  
CHECKED BY: JMS  
SCALE: 1" = 1' 0"

NOTE 1

| STRAIN NO.   | 100              | 150                     | 175              | 200                |
|--------------|------------------|-------------------------|------------------|--------------------|
| STRAIN NAME  | Filterate to SST | Clarified Salt Solution | Recycle to AGI-4 | Recombined Solvent |
| Flow         | 0.56             | 0.56                    | 0                | 0.5                |
| Flow (lb/hr) | 11.2             | 11.2                    | 0                | 10.5               |
| Density      | 1.15             | 1.15                    | 1.15             | 1.15               |
| Temperature  | 77               | 77                      | 77               | 77                 |
| Recycle      | 0.56             | 0.56                    | 0                | 0.5                |

| NO. | REV. | DATE     | REVISION  | BY  | CHKD. | APP'D. |
|-----|------|----------|---|-----|-------|--------|
| 1   | 01   | 04/15/08 | DESIGNED FOR CONSTRUCTION                         | JMS | CC    | JMS    |
| 2   | 02   | 05/01/08 | REVISED PER 200-0007                              | JMS | CC    | JMS    |
| 3   | 03   | 05/01/08 | REVISED TO REFLECT OPERATIONAL WORK FOR PERMIT DC | JMS | CC    | JMS    |





**NOTES**

- SEE DRAWING C-41-0000 FOR LEGEND.
- CONTRACTOR DRAWING NOT SHOWN.
- ON VENT EXTRACTION STAGES TO BE TEMPERATURE CONTROLLED TO 125°F ± 5°F FOR OPTIMUM SOLVENT EXTRACTION. COOLING WATER SUPPLY AND RETURN WILL BE PROVIDED FOR EACH CONTRACTOR.
- REFER TO THIS DRAWING WHEN PUMP P-206A/B OR P-217A/B FOR DETAILED ALUM DATA FOR EACH STREAM. BATTERY AND FLOW RATES ARE BASED ON THE BEST CURRENTLY AVAILABLE DATA.
- ISOLATED.
- EACH CONTRACTOR OUTLET STREAM HAS AN INDEPENDENT VENT CONNECTED TO A COMMON BLEED.
- LINE 10 WILL BE PROVIDED TO ALLOW FLOWING OF CONTRACTORS 100% SHOWN.
- TK-202 TO BE TEMPERATURE CONTROLLED TO 73°F (15°F) FOR OPTIMUM OPERATION.
- ISOLATED.
- ISOLATED.
- REFER TO C-41-0000 FOR DISPOSAL DETAILS.
- WATER PROVIDED IN W.W. MASS FLOW CALCULATED BASED ON HIGHEST DENSITY VALUE.
- RECIRCULATION LINE WILL BE PROVIDED TO TK-202 FOR MIXING.
- TANK VOLUME TO BE PROVIDED FOR ALL TANKS. BUT DETAILS ARE NOT SHOWN ON DRAWING.
- PUMPS P-206A/B OPERATE TO MAINTAIN CONSTANT LEVEL IN TK-206.
- ALUM DRAIN BEARING REDUCES THE CUMUL FLOW BACK TO TANK TK-101.

**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER  
WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION  
(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE PERMITTING DOCUMENT)**

FINAL WRITER: JEFFREY L. FOR OPERATIONS MUST  
BE OBTAINED FROM THE S. OFFICE AFTER COM-  
PLETION OF 15244-150 DATE Aug 16, 2008


PERMIT NO. 15244-150 DATE Aug 16, 2008  
DIRECTOR, WASTEWATER FACILITIES PERMITTING DIVISION

**PARSONS**  
5000 SHILOH ROAD, SUITE 200, SAVANNAH, GA 31403-1000  
UNITED STATES DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE

| NO. | DATE     | REVISION                | BY | CHKD | APP'D | DATE | REVISION |
|-----|----------|-------------------------|----|------|-------|------|----------|
| 1   | 08/16/08 | ISSUED FOR CONSTRUCTION |    |      |       |      |          |
| 2   | 08/16/08 | REVISED FOR DESIGN      |    |      |       |      |          |
| 3   | 08/16/08 | REVISED FOR DESIGN      |    |      |       |      |          |

SWPF  
SOLVENT EXTRACTION  
AND ACID SCRUB  
PFD  
(U)  
SWPF-BDR





- NOTES**
- SEE DRAWING 04-1-0000 FOR LEGEND.
  - PLATE POSITIONS SHOWN REPRESENT SYSTEM CONFIGURATION DURING SHIPBUILDING OPERATIONS.
  - STRIP STAGES TO BE TEMPERATURE CONTROLLED TO 77°F (15°F) FOR OPTIMAL STRIPPING. COOLING WATER SUPPLY AND RETURN PIPING TO BE PROVIDED FOR EACH CONTACTOR.
  - SYSTEM WILL NORMALLY RECIRCULATE. ON LOW pH INDICATION P-205A/B WILL SEND REVERSE CURRENTS TO TK-212. AFTER STRIPPING, TK-204 WILL BE REFILLED WITH CAUSTIC FROM TK-203.
  - REFER TO WASTE BALANCE MODEL (MMS) P-154-20000, REV. J FOR DESIGNER'S BASIS FOR EACH STRIPPING, WASH, AND HOLD TANK. THE BASIS FOR THE WASH STRIPPER, ONE IN TK-108 (LAST 6) AND ONE IN TK-204 (LAST 6).
  - EACH CONTACTOR OUTLET STREAM HAS AN INDEPENDENT VENT CONNECTED TO A COMMON PIPING.
  - COOLER DESIGNED TO REMOVE SOLVENT TO 50 PPM IN AIRBORNE PHASE.
  - LINE'S WILL BE PROVIDED TO ALLOW FLUSHING OF CONTACTORS (NOT SHOWN).
  - CONTACTOR DRAINING NOT SHOWN.
  - TRANSFER OF STRIP EFFLUENT TO DUMP WILL OCCUR IN BATCH MODE AS APPROPRIATE TO USER CONTROL. EXACT AMOUNT, FREQUENCY, AND DURATION WILL VARY. DETAILS OF TRANSFER ARE PROVIDED IN 02-010, P-154-2-0000.
  - TK-205 TO BE TEMPERATURE CONTROLLED TO 77°F (15°F) FOR OPTIMAL OPERATION.
  - DELETED.
  - DELETED.
  - WASH RATE PROVIDED IN MMS. WASH FLOW CALCULATED BASED ON ROUNDED DENSITY VALUE.
  - RECIRCULATION LINE WILL BE PROVIDED TO TK-205 FOR WASHING.
  - WASH FLOW TO BE PROVIDED FOR ALL TANKS, BUT DETAILS ARE NOT SHOWN ON DRAWING.
  - WASH FLOW CONCENTRATION EXCEEDING SAFETY LIMITS TO BE PREVENTED.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
**WASTEWATER FACILITIES**  
**APPROVED FOR CONSTRUCTION**  
 (SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)  
 FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THIS OFFICE AFTER COMPLETION OF CONSTRUCTION.

PREPARED BY: *[Signature]*  
 DATE: 11-21-88  
 PROJECT: 154-2-0000

DIRECTOR, WATER FACILITIES PERMITTING DIVISION

PARSONS  
 5005 STEWART BLVD., SUITE 2000, FORT WORTH, TEXAS 76104-1700

UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE

| NO. | REV. | DATE     | DESCRIPTION             | BY | CHKD. | APPV. | IN CH. |
|-----|------|----------|-------------------------|----|-------|-------|--------|
| 1   | 0    | 11/21/88 | ISSUED FOR CONSTRUCTION | MB | DM    | CC    | MB     |
| 2   | 1    | 11/21/88 | REVISED FOR 02-000      | MB | DM    | CC    | MB     |
| 3   | 2    | 11/21/88 | REVISED FOR 02-000 W/ST | MB | DM    | CC    | MB     |

SWPF SOLVENT STRIPPING AND CAUSTIC WASH PFD (U)


NOTE: MMS-J-0000P SHEET 1 OF 1 TA

SWPFE-DOR

NOTE 5

| STREAM NO.         | 012                    | 013                    | 014                    | 015                    | 016                    | 017                    | 018                    | 019                    | 020                    |
|--------------------|------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|------------------------|
| STREAM NAME        | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent | Organic Strip Effluent |
| Flow               | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   |
| Flow (GPM)         | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  |
| Density            | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   | 1.00                   |
| Temperature        | 77                     | 77                     | 77                     | 77                     | 77                     | 77                     | 77                     | 77                     | 77                     |
| Flow (GPM) @ 100°F | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  |
| Flow (GPM) @ 120°F | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  |
| Flow (GPM) @ 150°F | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  | 15.00                  |





- NOTES**
- SEE DRAWING C-41-J-0000 FOR LEGEND.
  - DELETED.
  - DSS HOLD TANK SIZED FOR 24 HOUR STORAGE.
  - DELETED.
  - REVIEW TO MAKE SURE BRINE WHEEL NUMBER P-207-0000, MFC-1 FOR DELAYED FLOW DUE TO PUMP STOPPING, STOP AND FLOW TO BE MADE ON THE HOT STREAM. SEE TR-101, TR-101-A AND DMC IN TR-201 (ASST-8).
  - THE ALPHA PROCESSING FACILITY IS EQUIPPED WITH A PASSIVE VENTILATION SYSTEM.
  - TRANSFER RATE CAN BE PERFORMED BY THE DSS HOLD TANK TO THE DSS HOLD TANK. THE DSS HOLD TANK IS MAINTAINED AT A LEVEL OF APPROXIMATELY 15,000 GALLONS. EXACT AMOUNT OF STORAGE RATE AND PERFORMANCE WILL VARY. DETAILS OF STORAGE ARE PROVIDED IN 100-70, V-100-J-0000.
  - DELETED.
  - REGULATION LINE WILL BE PROVIDED TO TK-207 FOR WEIGHING.
  - WHEN NOT PROVIDED IN WHM, MASS FLOW CALCULATED BASED ON SCHEDULED DENSITY VALUE.
  - ORAIN PROVIDED TO ALPHA PROCESSING DRAIN TANK, TR-228.
  - DELETED.
  - TANK LEVELS TO BE PROVIDED FOR ALL TANKS, BUT DETAILS ARE NOT SHOWN ON DRAWING.
  - FLOW LEVELS TO BE PROVIDED FOR ALL TANKS, BUT DETAILS ARE NOT SHOWN ON DRAWING.
  - THE DSS HOLD TANK IS TO BE PROVIDED FOR THE STORAGE OF DSS HOLD TANK COLLECTOR DESIGNED TO REMOVE SOLVENT TO 50 PPM IN SOLVENT PHASE.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
**WASTEWATER FACILITIES**  
**APPROVED FOR CONSTRUCTION**  
 (SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)  
 FINAL WRITER APPROVAL FOR OPERATION MUST BE OBTAINED FROM U.S. OFFICE AFTER COMPLETION OF CONSTRUCTION.

PREPARED BY: *[Signature]* DATE: *Aug 16, 2008*  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION

NOTE 5

| STREAM NO.        | 201  | 202   | 207              | 207                  | 207                  | 207                  | 207                  | 207                  | 207                  |
|-------------------|------|-------|------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| STREAM NAME       | DSS  | DSS   | DSS to Saltstone | DSS Hold Tank to DSS | DSS Hold Tank to DSS | DSS Hold Tank to DSS | DSS Hold Tank to DSS | DSS Hold Tank to DSS | DSS Hold Tank to DSS |
| Flow              | 0.00 | 22.30 | 1.00             | 1.00                 | 1.00                 | 1.00                 | 1.00                 | 1.00                 | 1.00                 |
| Mass Flow (kg/hr) | 0.00 | 14900 | 1000             | 1000                 | 1000                 | 1000                 | 1000                 | 1000                 | 1000                 |
| Quantity          | 0.00 | 10.23 | 10.23            | 10.23                | 10.23                | 10.23                | 10.23                | 10.23                | 10.23                |
| Temperature       | 17   | 17    | 17               | 17                   | 17                   | 17                   | 17                   | 17                   | 17                   |
| Quality           | 0.00 | 1.24  | 1.24             | 1.24                 | 1.24                 | 1.24                 | 1.24                 | 1.24                 | 1.24                 |


| NO. | REV. | DATE     | DESCRIPTION             | BY | CHKD. | APP'D. | DATE |
|-----|------|----------|-------------------------|----|-------|--------|------|
| 1   | 0    | 08/16/08 | ISSUED FOR CONSTRUCTION |    |       |        |      |
| 2   | 1    | 08/16/08 | REVISED FOR DSS         |    |       |        |      |
| 3   | 2    | 08/16/08 | REVISED FOR DSS         |    |       |        |      |

**PARSONS**  
 1000 11th St., Suite 1000, Columbia, SC 29201 (803) 743-1000

UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE

DSS COLLECTOR, DSS HOLD TANK AND TRANSFER PUMPS PFD  
 (U)  
 J-MS-J-0000P  
 1 of 1  
 1A  
 SVPFE-DOR





S.C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
 WASTEWATER FACILITIES  
 APPROVED FOR CONSTRUCTION  
 (SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT)  
 FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THIS OFFICE AFTER COMPLETION OF CONSTRUCTION.  
 PERMIT NO. *19-274-10*  
 DATE: *Aug 6, 2008*  
*John D. Jeffers*  
 DIRECTOR, WASTEWATER FACILITIES PERMITTING DIVISION

NOTE 3


| STREAM NO.     | 155      | 157      | 158      | 159      | 161      | 163      | 165      | 167      | 169      | 171      | 173      | 175      | 177      | 179      | 181      | 183      |
|----------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| STREAM NAME    | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water | DI Water |
| Flow           | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |
| Max Flow (GPM) | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |
| Capacity       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |
| Temperature    | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |
| Water          | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |
| Waste          | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       | 50       |

| NO. | REV. | DATE     | DESCRIPTION                                      | BY | CHKD. | APP'D. | DATE |
|-----|------|----------|--|----|-------|--------|------|
| 1   | 1    | 08-06-08 | ISSUED FOR CONSTRUCTION                          |    |       |        |      |
| 2   | 1    | 08-06-08 | REVISED FOR PERMIT                               |    |       |        |      |
| 3   | 1    | 08-06-08 | REVISED TO REFLECT DESIGN CHANGES FOR PERMIT USE |    |       |        |      |

**PARSONS**  
 1000 Littleton Street, Suite 2000, Littleton, CO 80120-1000  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 SWPF COLD CHEMICAL MAKEUP AND PROCESS WATER TANK PFD  
 (U)  
 MHS-J-001-001







**NOTES**

- SEE DRAWING 6-W-1-00002 FOR LEGEND.
- NITRIC ACID WILL BE UNLOADED FROM TANKER TRUCKS OR PORTABLE CONTAINERS.
- DELETED.
- WHEN NOT PROVIDED IN MASS BALANCE MODEL (MHW-P-ESH-1-00001), REV. 1, MASS FLOW CALCULATED BASED ON NOMINAL DENSITY VALUES.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
 WASTEWATER FACILITIES  
 APPROVED FOR CONSTRUCTION  
 (SUBJECT TO ANY PROVISIONS WHICH MAY  
 APPEAR IN THE CONSTRUCTION PERMIT)  
 FINAL WRITTEN APPROVAL FOR OPERATION MUST  
 BE OBTAINED FROM THE STATE OFFICE AFTER COM-  
 PLETION OF CONSTRUCTION

Permit No. 19-219-100 Date Aug 6 1988

*Col. S. J. Brown*  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION

NOTE 4

| COND. NO.          | 101                  | 102                     | 103                     | 104                     |
|--------------------|----------------------|-------------------------|-------------------------|-------------------------|
| COND. NAME         | NITRIC ACID (20 WTS) | NITRIC ACID (60.05 WTS) | NITRIC ACID (60.05 WTS) | NITRIC ACID (60.05 WTS) |
| Flow               | 1.44                 | 1.44                    | 1.44                    | 1.44                    |
| Mass Flow (Note 4) | 24                   | 24                      | 24                      | 24                      |
| Density            | 1.42                 | 1.42                    | 1.42                    | 1.42                    |
| Temperature        | 77                   | 77                      | 77                      | 77                      |
| MOF                | 1.42                 | 1.42                    | 1.42                    | 1.42                    |

| PRO. | NO. | DATE    | REVISION                 | REV. | CHK. | APP. | BY |
|------|-----|---------|--------------------------|------|------|------|----|
| 1    | 1   | 10/1/88 | ISSUED FOR CONSTRUCTION  | 1    | 1    | 1    | 1  |
| 2    | 2   | 10/1/88 | REVISED FOR CONSTRUCTION | 2    | 2    | 2    | 2  |
| 3    | 3   | 10/1/88 | REVISED FOR CONSTRUCTION | 3    | 3    | 3    | 3  |
| 4    | 4   | 10/1/88 | REVISED FOR CONSTRUCTION | 4    | 4    | 4    | 4  |

**PARSONS**  
 1000 17th Street, N.W., Atlanta, GA 30339  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 SWPF  
 COLD CHEMICAL MAKEUP TANK  
 PFD  
 (U)  
 SHEET NO. 1A  
 SWPFC-001P






1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20

DE100-r-SH-N

AGT-313 SOLVENT MAKEUP TANK ASSEMBLY  
 TK-313 SOLVENT MAKEUP TANK 50 GAL. WT.  
 P-313 SOLVENT MAKEUP TANK TRIGGER PUMP MAXIMUM CAPACITY: 5 GPM



S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
 BUREAU OF WATER  
**WASTEWATER FACILITIES  
 APPROVED FOR CONSTRUCTION**  
 (SUBJECT TO ANY PROVISIONS WHICH MAY  
 APPEAR IN THE CONSTRUCTION PERMIT.)  
 FINAL WRITTEN APPROVAL FOR OPERATION MUST  
 BE OBTAINED FROM THIS OFFICE AFTER COM-  
 PLETION OF CONSTRUCTION.  
 PERMIT NO. 19,219-IW DATE Aug. 6, 2008  
*[Signature]*  
 DIRECTOR, WATER FACILITIES PERMITTING DIVISION

**NOTES**

1. SEE DRAWING S-W-V-0002 FOR LEGEND.
2. RELATED.
3. EXTRACTING, SUPPLEMENTAL LEGALS, AND MODIFIERS CAN BE ADDED (IF NEEDED) IN SMALL QUANTITIES TO SOLVENT MAKEUP TANK.
4. WHEN NOT PROVIDED BY MANUFACTURER, MODEL NUMBER P-313-100000 MUST BE USED FOR CALCULATED PRESSURE RATED DESIGN VALUES.
5. SOLVENT WILL BE TRANSPORTED FROM PORTABLE DRUMS.

NOTE 4

|             |          |
|-------------|----------|
| SHEET NO.   | 343      |
| SHEET NAME  | PERMIT   |
| DATE        | 08/06/08 |
| DESIGNED BY | WMS      |
| CHECKED BY  | WMS      |
| DATE        | 08/06/08 |

| NO. | REV. | DATE     | REVISION                              | APP'D | CHK'D | DATE | APP'D | CHK'D | DATE |
|-----|------|----------|---------------------------------------|-------|-------|------|-------|-------|------|
| 1   |      | 08/06/08 | DESIGNED FOR CONSTRUCTION             |       |       |      |       |       |      |
| 2   |      | 08/06/08 | REVISED FOR 50-GAL. TANK              |       |       |      |       |       |      |
| 3   |      | 08/06/08 | REVISED TO MATCH PERMIT NO. 19-219-IW |       |       |      |       |       |      |
| 4   |      | 08/06/08 | FOR PRINTING                          |       |       |      |       |       |      |

**PARSONS**  
 1000 EIGHTH STREET, SUITE 200, COLUMBIA, SC 29202 (803) 743-1100


UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE  
 WASTEWATER FACILITIES PERMITTING DIVISION

SMPF  
 SOLVENT MAKEUP TANK  
 PFD

(1)

NO. 19-219-IW  
 SHEET 343 OF 343  
 DATE 08/06/08













Please file as a record document for Construction Permit No. 19,219-IW.

**WASTEWATER**

**FINAL APPROVAL TO PLACE INTO OPERATION**

*Dany*

**ISSUED TO:** US DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE  
BUILDING 705-3C  
AIKEN SC 29808

19219-IW

for the operation of a wastewater treatment/collection system permitted under Construction Permit No. 20,234-IW, dated November 1, 2018.

**PROJECT NAME:** SRS/SALT WASTE PROCESSING FACILITY (SWPF) Final Tie-Ins

**COUNTY:** Aiken

**PROJECT DESCRIPTION:** The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for treatment at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A provides a list of equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be vitrified and poured into canisters that are transferred to the Glass Waste Storage Buildings.

**PERMITTED FLOW:** System Nominal Daily Flow: 35,840 gallons per day  
System Design Capacity Flow: 185,736 gallons per day

**WWTP:** US DOE/SAVANNAH RIVER SITE Salt Waste Processing Facility (SWPF)

**SPECIAL CONDITIONS:**

1. This permit is in addition to Construction Permit No. 19,219-IW (Salt Waste Processing Facility (SWPF)), Construction Permit No. 20,194-IW (SWPF NGS Cold Chemical Feed Facility), Construction Permit No. 18,801-IW (Saltstone Production Facility (SPF)), Construction Permit No. 17,424-IW (F-Area and H-Area Tank Farms), and Construction Permit No. 16,783, Defense Waste Processing Facility.





dhec

2. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by this construction permit. There shall be no radioactive salt solution received from the High Level Waste (HLW) tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued the Approval to Place into Operation for this construction permit.

This approval is based on the APO request letter (SRR-ESH-2019-00118) signed by Ms. Patricia M. Allen. Note that Attachment 1 is the Engineer's letter of certification (signed by Andrew R. Redwood, P.E., South Carolina Registration No. 20525).

*Barry S. Mullinax*

Barry S Mullinax, Engineer  
(for) Environmental Affairs  
AIKEN EA OFFICE

**Date Issued:** October 29, 2019

cc: Bureau of Water Permitting File – Construction Permit No. 20,234-IW  
Bureau of Water Permitting File – Construction Permit No. 19,219-IW  
Bureau of Water Permitting File – Construction Permit No. 20,194-IW  
Bureau of Water Permitting File – Construction Permit No. 18,801-IW  
Bureau of Water Permitting File – Construction Permit No. 17,424-IW  
Bureau of Water Permitting File – Construction Permit No. 16,783-IW  
Travis Fuss, Aiken EA Office  
Crystal Robertson, Aiken EA Office  
Shawn M. Clarke, BOW, Columbia Office  
Crystal Rippey, BOW – Columbia Office  
Andrew Redwood, P.E.,SRR



Attachment A    Equipment List

The equipment included in Construction Permit No. 20,234-IW is listed below:

1. Transfer Line SDP1 and Jumper 6-7(SPP2)2 for Raw Salt Solution (RSS) Transfer Line
2. Jumper 6-7(SPP3)3 for Strip Effluent (SE) Waste Transfer Line
3. Jumper 3(SPP3)15 for Monosodium Titanate Precipitate (MSTPCP) Waste Transfer Line
4. Transfer lines DSS-0077, SSP077, and WTS-SSP4 for the Decontaminated Salt Solution to Tank 50 and the Saltstone Production Facility.



July 25, 2019

SRR-ESH-2019-00082  
RSM Track #: 10667

Mr. Travis Fuss  
Area Director Midlands – Aiken and Orangeburg  
South Carolina Department of Health and  
Environmental Control  
Midlands Region BEHS Aiken  
206 Beaufort Street, NE  
Aiken, South Carolina 29801

Dear Mr. Fuss,

**SALT WASTE PROCESSING FACILITY PROFESSIONAL ENGINEER'S  
CERTIFICATION REPORT (U)**

- References:
- 1. Industrial Wastewater Treatment Facility Construction Permit Application, Engineering Report & Equipment List for the Salt Waste Processing Facility, ESH-EPG-2008-00048, April 2, 2008 & ESH-EPG-2008-00101, July 28, 2008
  - 2. SCDHEC Industrial Wastewater Construction Permit Number: 19,219-IW, SRS/Salt Waste Processing Facility/Phase 2, August 6, 2008

On behalf of the U.S. Department of Energy (DOE) and Parsons Government Services, please find as Attachment 1 the Professional Engineer's Certification Report of Salt Waste Processing Facility (SWPF) construction completion.

The U.S. DOE and Parsons Government Services is requesting an inspection of the SWPF and associated Approval to Place into Operation (APO). Please contact Keith Liner at (803) 208-6466 to coordinate the inspection.

Should you have any questions or concerns, please feel free to contact me at (803) 208-1462

Sincerely,

Keith D. Harp  
SRR-SWPF Integration Program Manager  
Savannah River Remediation, LLC

*Please put into file  
for construction  
Permit No. 19,219-IW*

Attachment: 1. Profession Engineer's Certification Report, Salt Waste Processing Facility,  
July 2019

c: M. Reece, SCDHEC, Columbia, SC  
C.D. Rippy, Columbia, SC  
J. Blalock, Columbia, SC  
B.S. Mullinax, Columbia SC  
P.A. Marks, DOE, 704-122S  
S.S. Farrell, 704-122S  
F. Sheppard Jr., Parsons, 992005-W  
Dr. T.D. Burns, 992005-W  
B. Brasel, 992005-W  
C. Connor, 992005-W  
R. Gurske, 221-J  
D. Yarbrough, 992005-W  
C. Everatt, 221-J  
K.R. Wells, SRR, 766-H  
C.S. Weston, 766-H  
C.L. Bergren, SRNS, 730-4B  
A.J. Meyer, 730-4B  
T.F. Kmetz, 730-4B  
V.E. Millings III, 730-4B  
Records Administration, 773-52A  
DOEECATS

July 17, 2019

Ref. No.: 00-700-27599

Mr. Travis R. Fuss  
Area Director Midlands – Aiken and Orangeburg  
South Carolina Department of Health and  
Environmental Control  
Midlands Region BEHS Aiken  
206 Beaufort ST NE  
Aiken, South Carolina 29801

Subject: Contract No. DE-AC09-02SR22210  
Salt Waste Processing Facility (SWPF) Project  
Professional Engineer's Certification Report

Reference: SCDHEC Construction Permit Number: 19219-IW, Salt Waste Processing Facility


Dear Mr. Fuss:

I have performed a final inspection of the Salt Waste Processing Facility (SWPF) Industrial Wastewater Treatment Facility as described in referenced Permit #19219-IW and have attached certified as-built drawings. This project has been found to be, to the best of my knowledge, built in accordance with the approved plans and specifications, with the exceptions listed in Attachment 1.

Attachment 2 contains the "as-built" drawings in support of the authorization to operate. All equipment listed in Attachment A of Permit 19219-IW has been installed.


If you have any questions, please contact me at 803-643-2300 (office) or 706-631-8572 (mobile).

Sincerely,



James C. Somma, PE  
South Carolina #14718

cc: F. Sheppard Jr., SWPF  
Dr. T. D. Burns, SWPF  
B. Brasel, SWPF  
C. Connor, SWPF  
R. Gurske, SWPF  
K. Liner, SRR  
D. Yarbrough, SWPF  
C. Everatt, SWPF  
SWPFDCA  
File No.: 3.4.1



ATTACHMENT 1

| Permit Drawing # | Final Drawing #            | Title  | Synopsis of Changes  |
|------------------|----------------------------|--|--|
| G-M1-J-0001P     | G-M1-J-00001               | Process Flow Drawing Index   | Added Drawing No. M-M-J-0020 with the title "Next Generation Solvent Building Cold Chemical Makeup Tanks PFD." (Reference SCDHEC Construction Permit Number 20194-1W, NGS Cold Chemical Feed Facility at SWPF, June 21, 2018).   |
| G-M1-J-0002P     | G-M1-J-00002               | Process Flow Legend Sheet  | No Changes.  |
| G-P1-J-00001     | G-P1-J-00001 Sh. 1 & Sh. 2 | SWPF Process Building General Arrangement Drawing Index, Symbols, Abbreviations, Equipment Designations, and General Notes | <ol style="list-style-type: none"> <li>1. Added P-PG-J-0024 with the title "SWPF Next Generation Solvent Building General Arrangement Plan at Elevation 98'-9" and Sections" to the drawing index.</li> <li>2. In the "Process Building - Process Equipment" section: <ol style="list-style-type: none"> <li>a. TK-121A/B/C &amp; TK-123: Capacity increased from 7 to 22 gal; Diameter increased from 8 1/8" to 1'-3".</li> <li>b. TK-127 name changed from Spent Oxalic Acid Storage Tank (SOAST) to Spent Acid Storage Tank (SAST).</li> <li>c. Added TK-505/506, Back Up Air Receiver, with dimensions &amp; capacity (3'-0" dia x 14'-11", 600 gal.).</li> <li>d. TK-206 height increased from 6'-6" to 8'; capacity increased from 1700 to 2160 gal</li> <li>e. TK-106 name changed from Oxalic Acid Feed Tank to Filter Cleaning Acid Feed Tank.</li> <li>f. TK-301 diameter decreased from 11' to 10'; height increased from 15' to 16'-9"; capacity decreased from 9600 to 9100 gal.</li> <li>g. TK-305 capacity increased from 400 to 600 gal.</li> <li>h. TK-312 diameter decreased from 9' to 8'-6"; height increased from 16' to 18'-8"; capacity increased from 7200 to 7400 gal.</li> <li>i. Added TK-314, DI water expansion tank, with dimensions &amp; capacity (1'-8" dia x 4'-11", 57 gal.).</li> </ol> </li> <li>3. In the Pumps category of the "equipment designations" section, added P-015A/B, ASP Secondary Loop Pump, to the North ASP Pump &amp; Valve Gallery subsection &amp; added P-212A/B, Strip Effluent Coalescer Feed Pump, to CSSX Pump &amp; Valve Gallery subsection. Renamed P-106 "Acid Transfer Pump".</li> <li>4. Added FLT-250, Solvent Adjustment Filter; Added SCF5-001 &amp; -002, Scrubber Caustic Feed System; SEP-015, Process Chilled Water Separator; Added TK-015, Process Chilled Water Expansion Tank &amp; TK-016, Chemical Bypass Feeder Tank.</li> </ol> |
| M-M5-J-0001P     | M-M5-J-0001                | Simplified Process Flow Schematic  | No Changes.  |
| M-M5-J-0002P     | M-M5-J-0002                | Feed Receipt, Alpha Sorption Tank-A, Filter Feed Tank-A, and Cleaning Solution Dump Tank-A PFD                             | TK-106 name & associated stream information was changed from "Oxalic Acid" to the generic "Filter Cleaning Acid".  |
| M-M5-J-0003P     | M-M5-J-0003                | Alpha Sorption Filters FLT-102A/B/C PFD  | No Changes.  |
| M-M5-J-0004P     | M-M5-J-0004                | Sludge Solids Washing Filter, Sludge Solids Receipt Tank and Wash Water Hold Tank PFD                                      | No Changes.  |
| M-M5-J-0005P     | M-M5-J-0005                | Cold Chemical Makeup for Filter Cleaning and Feed Adjustment PFD   | TK-106 name changed from "Oxalic Acid Feed Tank" to "Filter Cleaning Acid Feed Tank", added a heater to the tank, & the chemical composition changed from 0.5M Oxalic acid to 20 wt% Nitric acid. Changed the chemical composition of TK-107 from 0.02 M to 1M NaOH.   |

ATTACHMENT 1

| Permit Drawing # | Final Drawing # | Title   | Synopsis of Changes  |
|------------------|-----------------|---|--|
| M-MS-J-0006P     | M-MS-J-0006     | Salt Solution Feed Tank and Solvent Drain Tank PFD  | No Changes.  |
| M-MS-J-0007P     | M-MS-J-0007     | Solvent Extraction and Acid Scrub PFD   | Added stream 708 for caustic scrub from the NGS Cold Chemical Feed Facility (Reference SCDHEC Construction Permit Number 20194-1W, NGS Cold Chemical Feed Facility at SWPF, June 21, 2018).  |
| M-MS-J-0008P     | M-MS-J-0008     | Solvent Stripping and Caustic Wash PFD  | Renamed HTR-217A/B to HK-217A/B. Added pumps P-212A/B. Added stream 705 & 700 for boric acid solution from the NGS Cold Chemical Feed Facility (Reference SCDHEC Construction Permit Number 20194-1W, NGS Cold Chemical Feed Facility at SWPF, June 21, 2018). |
| M-MS-J-0009P     | M-MS-J-0009     | DSS Cooler, DSS Hold Tank and Transfer Pumps PFD  | No Changes.  |
| M-MS-J-0010P     | M-MS-J-0010     | Cold Chemical Makeup and Process Water PFD  | Added streams 701, 702, 707 & 708 for feeds to the NGS Cold Chemical Feed Facility (Reference SCDHEC Construction Permit Number 20194-1W, NGS Cold Chemical Feed Facility at SWPF, June 21, 2018).   |
| M-MS-J-0011P     | M-MS-J-0011     | Cold Chemical Makeup Tank PFD   | No Changes.  |
| M-MS-J-0012P     | M-MS-J-0012     | Solvent Extraction Strip and Scrub Feed Pumps PFD   | No Changes.  |
| M-MS-J-0013P     | M-MS-J-0013     | Solvent Makeup Tank PFD   | No Changes.  |
| M-MS-J-0014P     | M-MS-J-0014     | Process Vessel Vent System PFD  | Updated acronym from SOAST to SAST for TK-127.   |
| M-MS-J-0015P     | M-MS-J-0015     | Intermediate Storage Tank, Alpha Sorption Tank-B, Filter Feed Tank-B, and Cleaning Solution Dump Tank-B PFD | The name for TK-106, TK-127 & associated streams was revised to reflect the generic filter cleaning acid & spent acid.   |
| M-MS-J-0016P     | M-MS-J-0016     | Alpha Sorption Filters FLT-222A/B/C PFD   | No Changes.  |
| M-MS-J-0018P     | M-MS-J-0018     | Lab Drain Tank, Alpha Sorption Drain Tank and Spent Acid Storage Tank PFD                                   | No Changes.  |
| P-PG-J-0002      | P-PG-J-0002     | Process Building General Arrangement Index Key Plan   | Added note to reference P-PG-J-0024 for NGS building general arrangement (Reference SCDHEC Construction Permit Number 20194-1W, NGS Cold Chemical Feed Facility at SWPF, June 21, 2018).   |
| P-PG-J-0003P     | P-PG-J-0003     | Process Building General Arrangement Central Process Area Plan at Elevation 100'-0"                         | No Changes.  |
| P-PG-J-0004      | P-PG-J-0004     | Process Building General Arrangement Cold Chemicals Area Plan at Elevation 100'-0"                          | No Changes.  |

ATTACHMENT 1

| Permit Drawing # | Final Drawing # | Title  | Synopsis of Changes  |
|------------------|-----------------|--|--|
| P-PG-J-0005      | P-PG-J-0005     | Process Building General Arrangement Northern Facility Support Area Plan at Elevation 100'-0"                | No Changes.  |
| P-PG-J-0006      | P-PG-J-0006     | Process Building General Arrangement Eastern Facility Support Area Plan at Elevation 100'-0"                 | No Changes.  |
| P-PG-J-0007P     | P-PG-J-0007     | Alpha Finishing Facility General Arrangement Alpha Finishing Facility Support Area Plan at Elevation 100'-0" | <p>1. In the Alpha Finishing Facility - Process Equipment &amp; Equipment Designations section:</p> <p>a. TK-225A/B/C: Capacity increased from 7 to 22 gal; Diameter increased from 8 5/8" to 1'-3".</p> <p>b. Lab Drain Tank-A (TK-236) and Tank-B (TK-237) capacity revised from 1000 gals to 1800 gals; DIA revised from 5'-0" to 5'-6"; Height revised from 7'-3" to 10'-5".</p> <p>c. Alpha Sorption Filters (FLT-222A/B/C) surface area decreased from 225 ft<sup>2</sup> to 216 ft<sup>2</sup>.</p> <p>d. Added Pumps P-025A/B (AFP Secondary Loop Pump), HX-025 (AFP Secondary Loop Cooler), TK-025 (Process Chilled Water Expansion Tank), TK-026 (Process Chilled Water Chemical Bypass Tank), and SEP-025 (Process Chilled Water Separator).</p> <p>e. Added equipment size &amp; capacity for TK-504 to the table.</p> |
| P-PG-J-0008      | P-PG-J-0008     | Process Building General Arrangement Central Process Area Plan at Elevation 116'-0"                          | No Changes.  |
| P-PG-J-0009      | P-PG-J-0009     | Process Building General Arrangement Central Process Area Plan at Elevation 124'-0"                          | No Changes.  |
| P-PG-J-0010      | P-PG-J-0010     | Process Building General Arrangement Central Process Area Plan at Elevation 139'-0"                          | Added SCFS-001 & SCFS-002 (Scrubber Caustic Feed system), HX-250 (Solvent Adjustment Heat Exchanger), FLT-250 (Solvent Adjustment Filter), room numbers, glovebox & radihood details, miscellaneous instrument racks/panels, safety showers and room numbers.  |



| <b>Drawing #</b>          | <b>Drawing Title</b>   |
|---------------------------|--|
| G-M1-J-00001              | Process Flow Drawing Index   |
| G-M1-J-00002              | Process Flow Legend Sheet  |
| G-P1-J-00001 Sh. 1 & Sh.2 | SWPF Process Building General Arrangement Drawing Index, Symbols, Abbreviations, Equipment Designations, and General Notes |
| M-M5-J-0001               | Simplified Process Flow Schematic  |
| M-M5-J-0002               | Feed Receipt, Alpha Sorption Tank-A, Filter Feed Tank-A, and Cleaning Solution Dump Tank-A PFD                             |
| M-M5-J-0003               | Alpha Sorption Filters FLT-102A/B/C PFD  |
| M-M5-J-0004               | Sludge Solids Washing Filter, Sludge Solids Receipt Tank and Wash Water Hold Tank PFD                                      |
| M-M5-J-0005               | Cold Chemical Makeup for Filter Cleaning and Feed Adjustment PFD   |
| M-M5-J-0006               | Salt Solution Feed Tank and Solvent Drain Tank PFD   |
| M-M5-J-0007               | Solvent Extraction and Acid Scrub PFD  |
| M-M5-J-0008               | Solvent Stripping and Caustic Wash PFD   |
| M-M5-J-0009               | DSS Coalexcer, DSS Hold Tank and Transfer Pumps PFD  |
| M-M5-J-0010               | Cold Chemical Makeup and Process Water PFD   |
| M-M5-J-0011               | Cold Chemical Makeup Tank PFD  |
| M-M5-J-0012               | Solvent Extraction Strip and Scrub Feed Pumps PFD  |
| M-M5-J-0013               | Solvent Makeup Tank PFD  |
| M-M5-J-0014               | Process Vessel Vent System PFD   |
| M-M5-J-0015               | Intermediate Storage Tank, Alpha Sorption Tank-B, Filter Feed Tank-B, and Cleaning Solution Dump Tank-B PFD                |
| M-M5-J-0016               | Alpha Sorption Filters FLT-222A/B/C PFD  |
| M-M5-J-0018               | Lab Drain Tank, Alpha Sorption Drain Tank and Spent Acid Storage Tank PFD  |
| P-PG-J-0002               | Process Building General Arrangement Index Key Plan  |
| P-PG-J-0003               | Process Building General Arrangement Central Process Area Plan at Elevation 100'-0"  |
| P-PG-J-0004               | Process Building General Arrangement Cold Chemicals Area Plan at Elevation 100'-0"   |

## ATTACHMENT 2

| <b>Drawing #</b> | <b>Drawing Title</b>   |
|------------------|--|
| P-PG-J-0005      | Process Building General Arrangement Northern Facility Support Area Plan at Elevation 100'-0"                |
| P-PG-J-0006      | Process Building General Arrangement Eastern Facility Support Area Plan at Elevation 100'-0"                 |
| P-PG-J-0007      | Alpha Finishing Facility General Arrangement Alpha Finishing Facility Support Area Plan at Elevation 100'-0" |
| P-PG-J-0008      | Process Building General Arrangement Central Process Area Plan at Elevation 116'-0"                          |
| P-PG-J-0009      | Process Building General Arrangement Central Process Area Plan at Elevation 124'-0"                          |
| P-PG-J-0010      | Process Building General Arrangement Central Process Area Plan at Elevation 139'-0"                          |





DRAWING INDEX

| DRAWING NO. | TITLE  |
|-------------|--|
| 14-1001     | GENERAL NOTES                                |
| 14-1002     | PROCESS BUILDING - PROCESS EQUIPMENT         |
| 14-1003     | PROCESS BUILDING - ELECTRICAL SYSTEMS        |
| 14-1004     | PROCESS BUILDING - FIRE PROTECTION EQUIPMENT |
| 14-1005     | PROCESS BUILDING - LABORATORY EQUIPMENT      |
| 14-1006     | PROCESS BUILDING - AIR HANDLING EQUIPMENT    |
| 14-1007     | PROCESS BUILDING - MISCELLANEOUS             |

PROCESS BUILDING - PROCESS EQUIPMENT

| NO. | DESCRIPTION                                     | QTY | UNIT | REMARKS |
|-----|---|-----|------|---------|
| 1   | 1. PROCESS BUILDING - PROCESS EQUIPMENT         | 1   | SET  |         |
| 2   | 2. PROCESS BUILDING - ELECTRICAL SYSTEMS        | 1   | SET  |         |
| 3   | 3. PROCESS BUILDING - FIRE PROTECTION EQUIPMENT | 1   | SET  |         |
| 4   | 4. PROCESS BUILDING - LABORATORY EQUIPMENT      | 1   | SET  |         |
| 5   | 5. PROCESS BUILDING - AIR HANDLING EQUIPMENT    | 1   | SET  |         |
| 6   | 6. PROCESS BUILDING - MISCELLANEOUS             | 1   | SET  |         |

PROCESS BUILDING CHANGES & MODIFICATIONS

| NO. | DESCRIPTION                                  | DATE     | BY           | REVISION |
|-----|--|----------|--------------|----------|
| 1   | 1. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 1        |
| 2   | 2. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 2        |
| 3   | 3. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 3        |
| 4   | 4. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 4        |
| 5   | 5. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 5        |
| 6   | 6. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 6        |
| 7   | 7. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 7        |
| 8   | 8. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 8        |
| 9   | 9. PROCESS BUILDING CHANGES & MODIFICATIONS  | 10/15/50 | J. H. HARRIS | 9        |
| 10  | 10. PROCESS BUILDING CHANGES & MODIFICATIONS | 10/15/50 | J. H. HARRIS | 10       |

EQUIPMENT DESIGNATIONS

| NO. | DESCRIPTION                | QTY | UNIT | REMARKS |
|-----|----------------------------|-----|------|---------|
| 1   | 1. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 2   | 2. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 3   | 3. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 4   | 4. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 5   | 5. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 6   | 6. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 7   | 7. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 8   | 8. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 9   | 9. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 10  | 10. EQUIPMENT DESIGNATIONS | 1   | SET  |         |

EQUIPMENT DESIGNATIONS

| NO. | DESCRIPTION                | QTY | UNIT | REMARKS |
|-----|----------------------------|-----|------|---------|
| 1   | 1. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 2   | 2. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 3   | 3. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 4   | 4. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 5   | 5. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 6   | 6. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 7   | 7. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 8   | 8. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 9   | 9. EQUIPMENT DESIGNATIONS  | 1   | SET  |         |
| 10  | 10. EQUIPMENT DESIGNATIONS | 1   | SET  |         |

AIR HANDLING EQUIPMENT


| NO. | DESCRIPTION                | QTY | UNIT | REMARKS |
|-----|----------------------------|-----|------|---------|
| 1   | 1. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 2   | 2. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 3   | 3. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 4   | 4. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 5   | 5. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 6   | 6. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 7   | 7. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 8   | 8. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 9   | 9. AIR HANDLING EQUIPMENT  | 1   | SET  |         |
| 10  | 10. AIR HANDLING EQUIPMENT | 1   | SET  |         |

GENERAL NOTES

1. PRESS BUILDING ELEVATIONS ARE BASED ON THE FINISHED FLOOR LEVELS AND ARE NOT TO BE USED FOR CONSTRUCTION PURPOSES.
2. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
3. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
4. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
5. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
6. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
7. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
8. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
9. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.
10. THE ARCHITECT'S ELEVATIONS ARE TO BE USED FOR THE ARCHITECT'S RECORD DRAWINGS AND FOR THE ARCHITECT'S RECORD DRAWINGS.

MISCELLANEOUS

| NO. | DESCRIPTION       | QTY | UNIT | REMARKS |
|-----|-------------------|-----|------|---------|
| 1   | 1. MISCELLANEOUS  | 1   | SET  |         |
| 2   | 2. MISCELLANEOUS  | 1   | SET  |         |
| 3   | 3. MISCELLANEOUS  | 1   | SET  |         |
| 4   | 4. MISCELLANEOUS  | 1   | SET  |         |
| 5   | 5. MISCELLANEOUS  | 1   | SET  |         |
| 6   | 6. MISCELLANEOUS  | 1   | SET  |         |
| 7   | 7. MISCELLANEOUS  | 1   | SET  |         |
| 8   | 8. MISCELLANEOUS  | 1   | SET  |         |
| 9   | 9. MISCELLANEOUS  | 1   | SET  |         |
| 10  | 10. MISCELLANEOUS | 1   | SET  |         |




6 P 1 3 0000 11

PARSONS  
 300 N. ZEEB ROAD, SUITE 100, CHARLOTTE, N.C. 28202  
 UNITED STATES DEPARTMENT OF ENERGY  
 CONTRACT NO. DE-AC02-76SF00001  
 SHEFFIELD, IOR

| NO. | DESCRIPTION     | QTY | UNIT | REMARKS |
|-----|-----------------|-----|------|---------|
| 1   | 1. SHEET INDEX  | 1   | SET  |         |
| 2   | 2. SHEET INDEX  | 1   | SET  |         |
| 3   | 3. SHEET INDEX  | 1   | SET  |         |
| 4   | 4. SHEET INDEX  | 1   | SET  |         |
| 5   | 5. SHEET INDEX  | 1   | SET  |         |
| 6   | 6. SHEET INDEX  | 1   | SET  |         |
| 7   | 7. SHEET INDEX  | 1   | SET  |         |
| 8   | 8. SHEET INDEX  | 1   | SET  |         |
| 9   | 9. SHEET INDEX  | 1   | SET  |         |
| 10  | 10. SHEET INDEX | 1   | SET  |         |

| NO. | DATE     | BY  | DESCRIPTION       |
|-----|----------|-----|-------------------|
| 1   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 2   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 3   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 4   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 5   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 6   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 7   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 8   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 9   | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 10  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 11  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 12  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 13  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 14  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 15  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 16  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 17  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 18  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 19  | 11/15/00 | JCW | ISSUED FOR PERMIT |
| 20  | 11/15/00 | JCW | ISSUED FOR PERMIT |



**ABBREVIATIONS**

420 AIR CONDITIONING PANEL UNIT  
421 AIR CONDITIONING UNIT  
422 AIR CONDITIONING UNIT  
423 AIR CONDITIONING UNIT  
424 AIR CONDITIONING UNIT  
425 AIR CONDITIONING UNIT  
426 AIR CONDITIONING UNIT  
427 AIR CONDITIONING UNIT  
428 AIR CONDITIONING UNIT  
429 AIR CONDITIONING UNIT  
430 AIR CONDITIONING UNIT  
431 AIR CONDITIONING UNIT  
432 AIR CONDITIONING UNIT  
433 AIR CONDITIONING UNIT  
434 AIR CONDITIONING UNIT  
435 AIR CONDITIONING UNIT  
436 AIR CONDITIONING UNIT  
437 AIR CONDITIONING UNIT  
438 AIR CONDITIONING UNIT  
439 AIR CONDITIONING UNIT  
440 AIR CONDITIONING UNIT  
441 AIR CONDITIONING UNIT  
442 AIR CONDITIONING UNIT  
443 AIR CONDITIONING UNIT  
444 AIR CONDITIONING UNIT  
445 AIR CONDITIONING UNIT  
446 AIR CONDITIONING UNIT  
447 AIR CONDITIONING UNIT  
448 AIR CONDITIONING UNIT  
449 AIR CONDITIONING UNIT  
450 AIR CONDITIONING UNIT  
451 AIR CONDITIONING UNIT  
452 AIR CONDITIONING UNIT  
453 AIR CONDITIONING UNIT  
454 AIR CONDITIONING UNIT  
455 AIR CONDITIONING UNIT  
456 AIR CONDITIONING UNIT  
457 AIR CONDITIONING UNIT  
458 AIR CONDITIONING UNIT  
459 AIR CONDITIONING UNIT  
460 AIR CONDITIONING UNIT  
461 AIR CONDITIONING UNIT  
462 AIR CONDITIONING UNIT  
463 AIR CONDITIONING UNIT  
464 AIR CONDITIONING UNIT  
465 AIR CONDITIONING UNIT  
466 AIR CONDITIONING UNIT  
467 AIR CONDITIONING UNIT  
468 AIR CONDITIONING UNIT  
469 AIR CONDITIONING UNIT  
470 AIR CONDITIONING UNIT  
471 AIR CONDITIONING UNIT  
472 AIR CONDITIONING UNIT  
473 AIR CONDITIONING UNIT  
474 AIR CONDITIONING UNIT  
475 AIR CONDITIONING UNIT  
476 AIR CONDITIONING UNIT  
477 AIR CONDITIONING UNIT  
478 AIR CONDITIONING UNIT  
479 AIR CONDITIONING UNIT  
480 AIR CONDITIONING UNIT  
481 AIR CONDITIONING UNIT  
482 AIR CONDITIONING UNIT  
483 AIR CONDITIONING UNIT  
484 AIR CONDITIONING UNIT  
485 AIR CONDITIONING UNIT  
486 AIR CONDITIONING UNIT  
487 AIR CONDITIONING UNIT  
488 AIR CONDITIONING UNIT  
489 AIR CONDITIONING UNIT  
490 AIR CONDITIONING UNIT  
491 AIR CONDITIONING UNIT  
492 AIR CONDITIONING UNIT  
493 AIR CONDITIONING UNIT  
494 AIR CONDITIONING UNIT  
495 AIR CONDITIONING UNIT  
496 AIR CONDITIONING UNIT  
497 AIR CONDITIONING UNIT  
498 AIR CONDITIONING UNIT  
499 AIR CONDITIONING UNIT  
500 AIR CONDITIONING UNIT

**REFERENCES**

1. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
2. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
3. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
4. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
5. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
6. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
7. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
8. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
9. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
10. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
11. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
12. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
13. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
14. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
15. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
16. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
17. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
18. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
19. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES  
20. SARASOTA BINDER SITE ELECTRICAL GENERAL NOTES

**MATERIALS**


1. WIRE  
2. CABLE  
3. CONDUIT  
4. TRAY  
5. PANEL  
6. SWITCH  
7. RELAY  
8. VALVE  
9. PUMP  
10. MOTOR  
11. FAN  
12. COMPRESSOR  
13. CONDENSER  
14. EVAPORATOR  
15. COIL  
16. TANK  
17. BATTERY  
18. CHARGER  
19. INVERTER  
20. RECTIFIER  
21. TRANSFORMER  
22. CAPACITOR  
23. RESISTOR  
24. DIODE  
25. TRIAC  
26. SCR  
27. IGBT  
28. MOSFET  
29. BJT  
30. PNP  
31. NPN  
32. JUNCTION DIODE  
33. ZENER DIODE  
34. LED  
35. LASER DIODE  
36. PHOTO DIODE  
37. PHOTO TRANSISTOR  
38. PHOTO RESISTOR  
39. PHOTO VOLTAGE CELL  
40. PHOTO CELL  
41. PHOTO DIODE  
42. PHOTO TRANSISTOR  
43. PHOTO RESISTOR  
44. PHOTO VOLTAGE CELL  
45. PHOTO CELL  
46. PHOTO DIODE  
47. PHOTO TRANSISTOR  
48. PHOTO RESISTOR  
49. PHOTO VOLTAGE CELL  
50. PHOTO CELL

**SYMBOLS**

1. AIR CONDITIONING PANEL UNIT  
2. AIR CONDITIONING UNIT  
3. AIR CONDITIONING UNIT  
4. AIR CONDITIONING UNIT  
5. AIR CONDITIONING UNIT  
6. AIR CONDITIONING UNIT  
7. AIR CONDITIONING UNIT  
8. AIR CONDITIONING UNIT  
9. AIR CONDITIONING UNIT  
10. AIR CONDITIONING UNIT  
11. AIR CONDITIONING UNIT  
12. AIR CONDITIONING UNIT  
13. AIR CONDITIONING UNIT  
14. AIR CONDITIONING UNIT  
15. AIR CONDITIONING UNIT  
16. AIR CONDITIONING UNIT  
17. AIR CONDITIONING UNIT  
18. AIR CONDITIONING UNIT  
19. AIR CONDITIONING UNIT  
20. AIR CONDITIONING UNIT  
21. AIR CONDITIONING UNIT  
22. AIR CONDITIONING UNIT  
23. AIR CONDITIONING UNIT  
24. AIR CONDITIONING UNIT  
25. AIR CONDITIONING UNIT  
26. AIR CONDITIONING UNIT  
27. AIR CONDITIONING UNIT  
28. AIR CONDITIONING UNIT  
29. AIR CONDITIONING UNIT  
30. AIR CONDITIONING UNIT  
31. AIR CONDITIONING UNIT  
32. AIR CONDITIONING UNIT  
33. AIR CONDITIONING UNIT  
34. AIR CONDITIONING UNIT  
35. AIR CONDITIONING UNIT  
36. AIR CONDITIONING UNIT  
37. AIR CONDITIONING UNIT  
38. AIR CONDITIONING UNIT  
39. AIR CONDITIONING UNIT  
40. AIR CONDITIONING UNIT  
41. AIR CONDITIONING UNIT  
42. AIR CONDITIONING UNIT  
43. AIR CONDITIONING UNIT  
44. AIR CONDITIONING UNIT  
45. AIR CONDITIONING UNIT  
46. AIR CONDITIONING UNIT  
47. AIR CONDITIONING UNIT  
48. AIR CONDITIONING UNIT  
49. AIR CONDITIONING UNIT  
50. AIR CONDITIONING UNIT



2000 1-24-84



2-100-10000  
 2-100-10000  
 2-100-10000

TL-102  
 ALPHA SORPTION TANK-A  
 2-100-10000

TL-102  
 ALPHA SORPTION TANK-A  
 2-100-10000

TL-102  
 ALPHA SORPTION TANK-A  
 2-100-10000

P-101A/B  
 ALPHA SORPTION TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

TL-103  
 CLEANING SOLUTION DUMP TANK-A  
 2-100-10000

1. ALL DRAWING SCALE 1/8" = 1'-0" UNLESS OTHERWISE NOTED.
2. THIS DRAWING IS THE PROPERTY OF THE UNITED STATES DEPARTMENT OF ENERGY AND IS TO BE KEPT IN THE OFFICE OF THE PROJECT MANAGER.
3. NO PART OF THIS DRAWING IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF THE PROJECT MANAGER.
4. THIS DRAWING IS TO BE USED ONLY FOR THE PROJECT AND IS NOT TO BE USED FOR ANY OTHER PURPOSE.
5. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY DAMAGE TO PERSONS OR PROPERTY CAUSED BY THE USE OF THIS DRAWING.
6. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY INJURY TO PERSONS OR DAMAGE TO PROPERTY CAUSED BY THE USE OF THIS DRAWING.
7. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF LIFE OR LIMB CAUSED BY THE USE OF THIS DRAWING.
8. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF PROPERTY CAUSED BY THE USE OF THIS DRAWING.
9. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF REVENUE CAUSED BY THE USE OF THIS DRAWING.
10. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF PROFITS CAUSED BY THE USE OF THIS DRAWING.
11. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF BUSINESS CAUSED BY THE USE OF THIS DRAWING.
12. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF GOODWILL CAUSED BY THE USE OF THIS DRAWING.
13. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF REPUTATION CAUSED BY THE USE OF THIS DRAWING.
14. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF CREDIT CAUSED BY THE USE OF THIS DRAWING.
15. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF INTEREST CAUSED BY THE USE OF THIS DRAWING.
16. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF POWER CAUSED BY THE USE OF THIS DRAWING.
17. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF LIGHT CAUSED BY THE USE OF THIS DRAWING.
18. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF SOUND CAUSED BY THE USE OF THIS DRAWING.
19. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF HEAT CAUSED BY THE USE OF THIS DRAWING.
20. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF COOLING CAUSED BY THE USE OF THIS DRAWING.
21. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF FUEL CAUSED BY THE USE OF THIS DRAWING.
22. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF OIL CAUSED BY THE USE OF THIS DRAWING.
23. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF WATER CAUSED BY THE USE OF THIS DRAWING.
24. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF AIR CAUSED BY THE USE OF THIS DRAWING.
25. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF SOIL CAUSED BY THE USE OF THIS DRAWING.
26. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF PLANTS CAUSED BY THE USE OF THIS DRAWING.
27. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF ANIMALS CAUSED BY THE USE OF THIS DRAWING.
28. THE PROJECT MANAGER IS NOT RESPONSIBLE FOR ANY LOSS OF HUMANS CAUSED BY THE USE OF THIS DRAWING.



UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH 6, GA 31406

| NO. | DATE    | DESCRIPTION             | BY  |
|-----|---------|-------------------------|-----|
| 1   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 2   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 3   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 4   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 5   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 6   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 7   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 8   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 9   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 10  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 11  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 12  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 13  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 14  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 15  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 16  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 17  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 18  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 19  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 20  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 21  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 22  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 23  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 24  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 25  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 26  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 27  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 28  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 29  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 30  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |

SWP  
 ALPHA SORPTION TANK FEED TANK-A  
 AND CLEANING SOLUTION TANK-A  
 (P.2)

| NO. | DATE    | DESCRIPTION             | BY  |
|-----|---------|-------------------------|-----|
| 1   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 2   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 3   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 4   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 5   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 6   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 7   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 8   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 9   | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 10  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 11  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 12  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 13  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 14  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 15  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 16  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 17  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 18  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 19  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 20  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 21  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 22  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 23  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 24  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 25  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 26  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 27  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 28  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 29  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |
| 30  | 10/1/83 | ISSUED FOR CONSTRUCTION | JCK |







NOTES

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
2. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
3. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
4. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
5. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
6. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
7. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
8. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
9. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
10. ALL WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

2. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

3. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

4. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

5. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

6. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

7. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

8. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

9. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

10. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.



NO. 00054

PARSONS  
ENGINEERING & TECHNOLOGY GROUP INC.  
1000 W. BROAD ST., SUITE 1000, RICHMOND, VA 23297






UNITED STATES DEPARTMENT OF ENERGY

PROJECT TITLE  
SMT  
COLD CHEMICAL MAKEUP  
FOR FILTER CLEANING  
AND FEED AUGUSTER

DATE  
NOV 1985

5000-T-ONE

- TK-106  
120 MTS NITRIC ACID  
FEED TANK  
120 MTS NITRIC ACID
- TK-107  
FILTER CLEANING  
CAUSTIC TANK  
11.0 M HIGH
- TK-108  
CAUSTIC DILUTION  
FEED TANK  
11.66 M HIGH
- TK-311  
MSI STORAGE TANK



| ITEM NO. | DESCRIPTION                               | QTY  | UNIT | PRICE | TOTAL  |
|----------|---|------|------|-------|--------|
| 1        | TK-106                                    | 1    | TANK | 10000 | 10000  |
| 2        | TK-107                                    | 1    | TANK | 10000 | 10000  |
| 3        | TK-108                                    | 1    | TANK | 10000 | 10000  |
| 4        | TK-311                                    | 1    | TANK | 10000 | 10000  |
| 5        | P-106                                     | 1    | PUMP | 5000  | 5000   |
| 6        | P-107                                     | 1    | PUMP | 5000  | 5000   |
| 7        | P-108                                     | 1    | PUMP | 5000  | 5000   |
| 8        | P-311                                     | 1    | PUMP | 5000  | 5000   |
| 9        | PIPE                                      | 100  | FT   | 100   | 10000  |
| 10       | VALVE                                     | 10   | PCS  | 1000  | 10000  |
| 11       | WELDING                                   | 100  | HRS  | 100   | 10000  |
| 12       | LABOR                                     | 1000 | HRS  | 100   | 100000 |
| 13       | MATERIAL                                  | 1000 | PCS  | 100   | 100000 |
| 14       | PERMITS                                   | 10   | PCS  | 1000  | 10000  |
| 15       | INSURANCE                                 | 10   | PCS  | 1000  | 10000  |
| 16       | TRAVEL                                    | 10   | PCS  | 1000  | 10000  |
| 17       | UTILITIES                                 | 10   | PCS  | 1000  | 10000  |
| 18       | TESTING                                   | 10   | PCS  | 1000  | 10000  |
| 19       | TRAINING                                  | 10   | PCS  | 1000  | 10000  |
| 20       | CONSTRUCTION                              | 10   | PCS  | 1000  | 10000  |
| 21       | OPERATION                                 | 10   | PCS  | 1000  | 10000  |
| 22       | MAINTENANCE                               | 10   | PCS  | 1000  | 10000  |
| 23       | REPAIRS                                   | 10   | PCS  | 1000  | 10000  |
| 24       | REPLACEMENT                               | 10   | PCS  | 1000  | 10000  |
| 25       | MODIFICATIONS                             | 10   | PCS  | 1000  | 10000  |
| 26       | UPGRADES                                  | 10   | PCS  | 1000  | 10000  |
| 27       | RECONSTRUCTION                            | 10   | PCS  | 1000  | 10000  |
| 28       | DEMOLITION                                | 10   | PCS  | 1000  | 10000  |
| 29       | LANDFILL                                  | 10   | PCS  | 1000  | 10000  |
| 30       | WATER TREATMENT                           | 10   | PCS  | 1000  | 10000  |
| 31       | AIR POLLUTION CONTROL                     | 10   | PCS  | 1000  | 10000  |
| 32       | SOIL REMEDIATION                          | 10   | PCS  | 1000  | 10000  |
| 33       | HAZARDOUS WASTE                           | 10   | PCS  | 1000  | 10000  |
| 34       | SLURRY HANDLING                           | 10   | PCS  | 1000  | 10000  |
| 35       | SLURRY STORAGE                            | 10   | PCS  | 1000  | 10000  |
| 36       | SLURRY TREATMENT                          | 10   | PCS  | 1000  | 10000  |
| 37       | SLURRY DISPOSAL                           | 10   | PCS  | 1000  | 10000  |
| 38       | SLURRY RECOVERY                           | 10   | PCS  | 1000  | 10000  |
| 39       | SLURRY REUSE                              | 10   | PCS  | 1000  | 10000  |
| 40       | SLURRY RECYCLING                          | 10   | PCS  | 1000  | 10000  |
| 41       | SLURRY REFINING                           | 10   | PCS  | 1000  | 10000  |
| 42       | SLURRY PURIFICATION                       | 10   | PCS  | 1000  | 10000  |
| 43       | SLURRY POLYMERIZATION                     | 10   | PCS  | 1000  | 10000  |
| 44       | SLURRY GRAFTING                           | 10   | PCS  | 1000  | 10000  |
| 45       | SLURRY COPOLYMERIZATION                   | 10   | PCS  | 1000  | 10000  |
| 46       | SLURRY BLOCK COPOLYMERIZATION             | 10   | PCS  | 1000  | 10000  |
| 47       | SLURRY GRAFT COPOLYMERIZATION             | 10   | PCS  | 1000  | 10000  |
| 48       | SLURRY BLOCK GRAFT COPOLYMERIZATION       | 10   | PCS  | 1000  | 10000  |
| 49       | SLURRY GRAFT BLOCK COPOLYMERIZATION       | 10   | PCS  | 1000  | 10000  |
| 50       | SLURRY BLOCK GRAFT BLOCK COPOLYMERIZATION | 10   | PCS  | 1000  | 10000  |

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

2. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

NOTES

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
2. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
3. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
4. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
5. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
6. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
7. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
8. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
9. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.
10. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

2. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

3. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

4. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

5. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

6. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

7. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

8. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

9. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

10. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.



NO. 00054

PARSONS  
ENGINEERING & TECHNOLOGY GROUP INC.  
1000 W. BROAD ST., SUITE 1000, RICHMOND, VA 23297

UNITED STATES DEPARTMENT OF ENERGY

PROJECT TITLE  
SMT  
COLD CHEMICAL MAKEUP  
FOR FILTER CLEANING  
AND FEED AUGUSTER


DATE  
NOV 1985

1. ALL DRAWING WORK SHALL BE IN ACCORD WITH THE PROJECT MANUAL.

17 18 19 20 21 22

NOTES

1. AT JUNCTIONS WITH OTHER LINES
2. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
3. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
4. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
5. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
6. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
7. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
8. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
9. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
10. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
11. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
12. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
13. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
14. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
15. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
16. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
17. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
18. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
19. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
20. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
21. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED
22. ALL LINES TO BE 1/2" DIA. UNLESS OTHERWISE NOTED



**PARSONS**  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH POWER SITE

NO. 149718  
 JAMES C. JONES

**SOUTH CAROLINA**  
 PROFESSIONAL ENGINEERING CERTIFICATE  
 NO. 00718

**SOUTH CAROLINA**  
 PROFESSIONAL ARCHITECTURE & INTERIOR DESIGN GROUP INC.  
 NO. 00718

CERTIFICATE OF APPROVAL

M 45 J 0302 4

DATE: 11/12/78

PROJECT: SFP  
 SHEET: 809

| NO. | DATE     | BY     | DESCRIPTION             |
|-----|----------|--------|-------------------------|
| 1   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 2   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 3   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 4   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 5   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 6   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 7   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 8   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 9   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 10  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 11  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 12  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 13  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 14  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 15  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 16  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 17  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 18  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 19  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 20  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 21  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 22  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |

REVISIONS


| NO. | DATE     | BY     | DESCRIPTION             |
|-----|----------|--------|-------------------------|
| 1   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 2   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 3   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 4   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 5   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 6   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 7   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 8   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 9   | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 10  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 11  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 12  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 13  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 14  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 15  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 16  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 17  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 18  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 19  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 20  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 21  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |
| 22  | 11/12/78 | J.C.J. | ISSUED FOR CONSTRUCTION |

NOTES

1. SEE DRAWING L&P 2002 FOR L&P.
2. CONSULT THE DRAWING FOR L&P.
3. ALL EXTRACTOR STAGES, EXCEPT STAGE 1, ARE OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
4. OPERATIONAL FLOW DIRECTION FOR THE EXTRACTOR STAGES IS INDICATED BY THE ARROWS IN THE DRAWING. THE FLOW DIRECTION FOR THE SOLVENT STRIP FIELD TANK IS INDICATED BY THE ARROW IN THE DRAWING.
5. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
6. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
7. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
8. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
9. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
10. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
11. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
12. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
13. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
14. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
15. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
16. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
17. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
18. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
19. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.
20. THE SOLVENT STRIP FIELD TANK IS OPERATED CONTINUOUSLY TO MAINTAIN A CONSTANT FLOW OF SOLVENT THROUGH THE SYSTEM.



PARSONS  
 1000 17TH ST. N.W.  
 WASHINGTON, D.C. 20036  
 UNITED STATES DEPARTMENT OF ENERGY



| ITEM NO. | DESCRIPTION | QTY | UNIT | PRICE | TOTAL |
|----------|-------------|-----|------|-------|-------|
| 1        | ...         | ... | ...  | ...   | ...   |
| 2        | ...         | ... | ...  | ...   | ...   |
| 3        | ...         | ... | ...  | ...   | ...   |
| 4        | ...         | ... | ...  | ...   | ...   |
| 5        | ...         | ... | ...  | ...   | ...   |
| 6        | ...         | ... | ...  | ...   | ...   |
| 7        | ...         | ... | ...  | ...   | ...   |
| 8        | ...         | ... | ...  | ...   | ...   |
| 9        | ...         | ... | ...  | ...   | ...   |
| 10       | ...         | ... | ...  | ...   | ...   |
| 11       | ...         | ... | ...  | ...   | ...   |
| 12       | ...         | ... | ...  | ...   | ...   |
| 13       | ...         | ... | ...  | ...   | ...   |
| 14       | ...         | ... | ...  | ...   | ...   |
| 15       | ...         | ... | ...  | ...   | ...   |
| 16       | ...         | ... | ...  | ...   | ...   |
| 17       | ...         | ... | ...  | ...   | ...   |
| 18       | ...         | ... | ...  | ...   | ...   |
| 19       | ...         | ... | ...  | ...   | ...   |
| 20       | ...         | ... | ...  | ...   | ...   |

| ITEM NO. | DESCRIPTION | QTY | UNIT | PRICE | TOTAL |
|----------|-------------|-----|------|-------|-------|
| 1        | ...         | ... | ...  | ...   | ...   |
| 2        | ...         | ... | ...  | ...   | ...   |
| 3        | ...         | ... | ...  | ...   | ...   |
| 4        | ...         | ... | ...  | ...   | ...   |
| 5        | ...         | ... | ...  | ...   | ...   |
| 6        | ...         | ... | ...  | ...   | ...   |
| 7        | ...         | ... | ...  | ...   | ...   |
| 8        | ...         | ... | ...  | ...   | ...   |
| 9        | ...         | ... | ...  | ...   | ...   |
| 10       | ...         | ... | ...  | ...   | ...   |
| 11       | ...         | ... | ...  | ...   | ...   |
| 12       | ...         | ... | ...  | ...   | ...   |
| 13       | ...         | ... | ...  | ...   | ...   |
| 14       | ...         | ... | ...  | ...   | ...   |
| 15       | ...         | ... | ...  | ...   | ...   |
| 16       | ...         | ... | ...  | ...   | ...   |
| 17       | ...         | ... | ...  | ...   | ...   |
| 18       | ...         | ... | ...  | ...   | ...   |
| 19       | ...         | ... | ...  | ...   | ...   |
| 20       | ...         | ... | ...  | ...   | ...   |

| ITEM NO. | DESCRIPTION | QTY | UNIT | PRICE | TOTAL |
|----------|-------------|-----|------|-------|-------|
| 1        | ...         | ... | ...  | ...   | ...   |
| 2        | ...         | ... | ...  | ...   | ...   |
| 3        | ...         | ... | ...  | ...   | ...   |
| 4        | ...         | ... | ...  | ...   | ...   |
| 5        | ...         | ... | ...  | ...   | ...   |
| 6        | ...         | ... | ...  | ...   | ...   |
| 7        | ...         | ... | ...  | ...   | ...   |
| 8        | ...         | ... | ...  | ...   | ...   |
| 9        | ...         | ... | ...  | ...   | ...   |
| 10       | ...         | ... | ...  | ...   | ...   |
| 11       | ...         | ... | ...  | ...   | ...   |
| 12       | ...         | ... | ...  | ...   | ...   |
| 13       | ...         | ... | ...  | ...   | ...   |
| 14       | ...         | ... | ...  | ...   | ...   |
| 15       | ...         | ... | ...  | ...   | ...   |
| 16       | ...         | ... | ...  | ...   | ...   |
| 17       | ...         | ... | ...  | ...   | ...   |
| 18       | ...         | ... | ...  | ...   | ...   |
| 19       | ...         | ... | ...  | ...   | ...   |
| 20       | ...         | ... | ...  | ...   | ...   |

DATE: 11/12/14

PROJECT: SOLVENT EXTRACTION AND ACID SQUEL

NO. 14718

NO. 000715

UNITED STATES DEPARTMENT OF ENERGY

PARSONS  
 1000 17TH ST. N.W.  
 WASHINGTON, D.C. 20036









1 2 3 4 5 6 7 8 9 10 11 12 13 14 15

1.000 P-304-1

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

INDEX

1. SEE DRAWING P-304-1 FOR LOCATION.
2. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
3. PUMP.
4. TANKS SHALL BE FILLING TANKS IN ORDER OF PRIORITY.
5. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
6. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
7. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
8. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
9. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
10. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
11. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
12. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
13. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
14. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.
15. NITRIC ACID SHALL BE TRANSFERRED FROM TANKS TO TANKS OR TO STORAGE TANKS.



**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-304**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**TL-307**  
 NITRIC ACID  
 STORAGE TANK  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>

**P-304-1**  
 PUMP  
 120 M<sup>3</sup> NITRIC ACID  
 61% NITRIC ACID  
 MATERIAL CAPACITY: 2.0 M<sup>3</sup>



N 95 J 0011 4

**PARSONS**  
 UNITED STATES DEPARTMENT OF ENERGY  
 1100 11TH STREET, N.W., WASHINGTON, D.C. 20540-1100

SHEET NO. 11 OF 11  
 PROJECT NO. 11-11-11-11  
 TITLE: NITRIC ACID STORAGE TANKS  
 DATE: 11-11-11

| NO. | DESCRIPTION   | QTY | UNIT | AMOUNT |
|-----|---------------|-----|------|--------|
| 1   | TL-304        | 1   | TANK | 1.00   |
| 2   | TL-307        | 1   | TANK | 1.00   |
| 3   | P-304-1       | 1   | PUMP | 1.00   |
| 4   | PIPE          | 100 | FT   | 100.00 |
| 5   | VALVE         | 10  | PC   | 10.00  |
| 6   | FLANGE        | 20  | PC   | 20.00  |
| 7   | WELDING       | 100 | HR   | 100.00 |
| 8   | PAINT         | 100 | HR   | 100.00 |
| 9   | LABOR         | 100 | HR   | 100.00 |
| 10  | MATERIAL      | 100 | HR   | 100.00 |
| 11  | INSULATION    | 100 | HR   | 100.00 |
| 12  | TESTING       | 100 | HR   | 100.00 |
| 13  | COMMISSIONING | 100 | HR   | 100.00 |
| 14  | OPERATION     | 100 | HR   | 100.00 |
| 15  | MAINTENANCE   | 100 | HR   | 100.00 |
| 16  | REPAIR        | 100 | HR   | 100.00 |
| 17  | REPLACE       | 100 | HR   | 100.00 |
| 18  | REMOVE        | 100 | HR   | 100.00 |
| 19  | INSTALL       | 100 | HR   | 100.00 |
| 20  | TEST          | 100 | HR   | 100.00 |
| 21  | COMMISSION    | 100 | HR   | 100.00 |
| 22  | OPERATE       | 100 | HR   | 100.00 |
| 23  | MAINTAIN      | 100 | HR   | 100.00 |
| 24  | REPAIR        | 100 | HR   | 100.00 |
| 25  | REPLACE       | 100 | HR   | 100.00 |
| 26  | REMOVE        | 100 | HR   | 100.00 |
| 27  | INSTALL       | 100 | HR   | 100.00 |
| 28  | TEST          | 100 | HR   | 100.00 |
| 29  | COMMISSION    | 100 | HR   | 100.00 |
| 30  | OPERATE       | 100 | HR   | 100.00 |

| NO. | DESCRIPTION   | QTY | UNIT | AMOUNT |
|-----|---------------|-----|------|--------|
| 1   | TL-304        | 1   | TANK | 1.00   |
| 2   | TL-307        | 1   | TANK | 1.00   |
| 3   | P-304-1       | 1   | PUMP | 1.00   |
| 4   | PIPE          | 100 | FT   | 100.00 |
| 5   | VALVE         | 10  | PC   | 10.00  |
| 6   | FLANGE        | 20  | PC   | 20.00  |
| 7   | WELDING       | 100 | HR   | 100.00 |
| 8   | PAINT         | 100 | HR   | 100.00 |
| 9   | LABOR         | 100 | HR   | 100.00 |
| 10  | MATERIAL      | 100 | HR   | 100.00 |
| 11  | INSULATION    | 100 | HR   | 100.00 |
| 12  | TESTING       | 100 | HR   | 100.00 |
| 13  | COMMISSIONING | 100 | HR   | 100.00 |
| 14  | OPERATION     | 100 | HR   | 100.00 |
| 15  | MAINTENANCE   | 100 | HR   | 100.00 |
| 16  | REPAIR        | 100 | HR   | 100.00 |
| 17  | REPLACE       | 100 | HR   | 100.00 |
| 18  | REMOVE        | 100 | HR   | 100.00 |
| 19  | INSTALL       | 100 | HR   | 100.00 |
| 20  | TEST          | 100 | HR   | 100.00 |
| 21  | COMMISSION    | 100 | HR   | 100.00 |
| 22  | OPERATE       | 100 | HR   | 100.00 |
| 23  | MAINTAIN      | 100 | HR   | 100.00 |
| 24  | REPAIR        | 100 | HR   | 100.00 |
| 25  | REPLACE       | 100 | HR   | 100.00 |
| 26  | REMOVE        | 100 | HR   | 100.00 |
| 27  | INSTALL       | 100 | HR   | 100.00 |
| 28  | TEST          | 100 | HR   | 100.00 |
| 29  | COMMISSION    | 100 | HR   | 100.00 |
| 30  | OPERATE       | 100 | HR   | 100.00 |


| NO. | DESCRIPTION   | QTY | UNIT | AMOUNT |
|-----|---------------|-----|------|--------|
| 1   | TL-304        | 1   | TANK | 1.00   |
| 2   | TL-307        | 1   | TANK | 1.00   |
| 3   | P-304-1       | 1   | PUMP | 1.00   |
| 4   | PIPE          | 100 | FT   | 100.00 |
| 5   | VALVE         | 10  | PC   | 10.00  |
| 6   | FLANGE        | 20  | PC   | 20.00  |
| 7   | WELDING       | 100 | HR   | 100.00 |
| 8   | PAINT         | 100 | HR   | 100.00 |
| 9   | LABOR         | 100 | HR   | 100.00 |
| 10  | MATERIAL      | 100 | HR   | 100.00 |
| 11  | INSULATION    | 100 | HR   | 100.00 |
| 12  | TESTING       | 100 | HR   | 100.00 |
| 13  | COMMISSIONING | 100 | HR   | 100.00 |
| 14  | OPERATION     | 100 | HR   | 100.00 |
| 15  | MAINTENANCE   | 100 | HR   | 100.00 |
| 16  | REPAIR        | 100 | HR   | 100.00 |
| 17  | REPLACE       | 100 | HR   | 100.00 |
| 18  | REMOVE        | 100 | HR   | 100.00 |
| 19  | INSTALL       | 100 | HR   | 100.00 |
| 20  | TEST          | 100 | HR   | 100.00 |
| 21  | COMMISSION    | 100 | HR   | 100.00 |
| 22  | OPERATE       | 100 | HR   | 100.00 |
| 23  | MAINTAIN      | 100 | HR   | 100.00 |
| 24  | REPAIR        | 100 | HR   | 100.00 |
| 25  | REPLACE       | 100 | HR   | 100.00 |
| 26  | REMOVE        | 100 | HR   | 100.00 |
| 27  | INSTALL       | 100 | HR   | 100.00 |
| 28  | TEST          | 100 | HR   | 100.00 |
| 29  | COMMISSION    | 100 | HR   | 100.00 |
| 30  | OPERATE       | 100 | HR   | 100.00 |

| NO. | DESCRIPTION   | QTY | UNIT | AMOUNT |
|-----|---------------|-----|------|--------|
| 1   | TL-304        | 1   | TANK | 1.00   |
| 2   | TL-307        | 1   | TANK | 1.00   |
| 3   | P-304-1       | 1   | PUMP | 1.00   |
| 4   | PIPE          | 100 | FT   | 100.00 |
| 5   | VALVE         | 10  | PC   | 10.00  |
| 6   | FLANGE        | 20  | PC   | 20.00  |
| 7   | WELDING       | 100 | HR   | 100.00 |
| 8   | PAINT         | 100 | HR   | 100.00 |
| 9   | LABOR         | 100 | HR   | 100.00 |
| 10  | MATERIAL      | 100 | HR   | 100.00 |
| 11  | INSULATION    | 100 | HR   | 100.00 |
| 12  | TESTING       | 100 | HR   | 100.00 |
| 13  | COMMISSIONING | 100 | HR   | 100.00 |
| 14  | OPERATION     | 100 | HR   | 100.00 |
| 15  | MAINTENANCE   | 100 | HR   | 100.00 |
| 16  | REPAIR        | 100 | HR   | 100.00 |
| 17  | REPLACE       | 100 | HR   | 100.00 |
| 18  | REMOVE        | 100 | HR   | 100.00 |
| 19  | INSTALL       | 100 | HR   | 100.00 |
| 20  | TEST          | 100 | HR   | 100.00 |
| 21  | COMMISSION    | 100 | HR   | 100.00 |
| 22  | OPERATE       | 100 | HR   | 100.00 |
| 23  | MAINTAIN      | 100 | HR   | 100.00 |
| 24  | REPAIR        | 100 | HR   | 100.00 |
| 25  | REPLACE       | 100 | HR   | 100.00 |
| 26  | REMOVE        | 100 | HR   | 100.00 |
| 27  | INSTALL       | 100 | HR   | 100.00 |
| 28  | TEST          | 100 | HR   | 100.00 |
| 29  | COMMISSION    | 100 | HR   | 100.00 |
| 30  | OPERATE       | 100 | HR   | 100.00 |

SHEET NO. 11 OF 11  
 PROJECT NO. 11-11-11-11  
 TITLE: NITRIC ACID STORAGE TANKS  
 DATE: 11-11-11

NOTES

1. SEE DRAWING FOR DIMENSIONS FOR LAYOUT.
2. DETERMINE IF THIS SOLUTION COMPLIES WITH ANY OTHER REGULATIONS.
3. ALL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE SOUTH CAROLINA PROFESSIONAL ENGINEER REGISTERED PROFESSIONAL ENGINEER NO. 14718 JAMES C. HARRIS
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES.
5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES.
6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES.




N HS J 00124

**PARSONS**  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE

DATE: 11/11/03  
 BY: JCH  
 TITLE: PROJECT ENGINEER

PROJECT: SRP  
 DRAWING: SRP KEY STRUCTURE  
 STRIP AND SCRUB FEED PUMPS  
 PFD  
 (1)

SCALE: AS SHOWN  
 SHEET: 808 OF 808



| NO. | REV. | DATE     | DESCRIPTION           |
|-----|------|----------|-----------------------|
| 1   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 2   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 3   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 4   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 5   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 6   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 7   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 8   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 9   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 10  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 11  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 12  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 13  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 14  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 15  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 16  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 17  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 18  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 19  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 20  | 1    | 11/11/03 | ISSUED FOR PERMITTING |

| NO. | REV. | DATE     | DESCRIPTION           |
|-----|------|----------|-----------------------|
| 1   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 2   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 3   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 4   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 5   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 6   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 7   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 8   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 9   | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 10  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 11  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 12  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 13  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 14  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 15  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 16  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 17  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 18  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 19  | 1    | 11/11/03 | ISSUED FOR PERMITTING |
| 20  | 1    | 11/11/03 | ISSUED FOR PERMITTING |

NOTES

1. ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES.
3. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES.
4. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER.
5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES.
6. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME.
7. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES.
8. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS.
9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE.
10. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.


ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ALL WORK SHALL BE ACCORDING TO THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AND STATE AUTHORITIES. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AT ALL TIMES. ALL MATERIALS AND WORKMANSHIP SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE ENGINEER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY INSURANCE COVERAGE. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.



H 95 J 00134

**PARSONS**  
 INFRASTRUCTURE & TECHNOLOGY  
 UNITED STATES DEPARTMENT OF ENERGY

PROJECT: SOLVENT MAKE-UP TANK  
 SHEET: 101  
 DATE: 10/1/11

| NO. | REV. | DATE    | DESCRIPTION                |
|-----|------|---------|----------------------------|
| 1   | 1    | 10/1/11 | ISSUED FOR PERMITTING      |
| 2   | 1    | 10/1/11 | ISSUED FOR CONSTRUCTION    |
| 3   | 1    | 10/1/11 | ISSUED FOR OPERATION       |
| 4   | 1    | 10/1/11 | ISSUED FOR MAINTENANCE     |
| 5   | 1    | 10/1/11 | ISSUED FOR DECOMMISSIONING |


|                               |                 |
|-------------------------------|-----------------|
| DATE: 10/1/11                 | BY: [Signature] |
| SCALE: AS SHOWN               |                 |
| PROJECT: SOLVENT MAKE-UP TANK |                 |
| SHEET: 101                    |                 |

5/11/11




NOTES

1. SEE DRAWINGS FOR SPECIFICATIONS FOR TANKS.
2. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
3. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
4. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
5. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
6. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
7. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
8. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
9. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
10. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
11. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
12. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
13. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
14. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
15. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
16. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
17. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
18. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
19. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:
20. TANKS TO BE CONSTRUCTED IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS AND THE FOLLOWING NOTES:



PARSONS  
 ARCHITECTURE & TECHNOLOGY, INC.  
 1000 EAST BROADWAY  
 CHARLOTTE, NC 28202  
 DATE: 01/15/04

UNITED STATES DEPARTMENT OF ENERGY  
 SUBMITTER: BUREAU OF ENERGY EFFICIENCY  
 PROJECT: BUREAU OF ENERGY EFFICIENCY  
 DRAWING: BUREAU OF ENERGY EFFICIENCY



| ITEM NO. | DESCRIPTION                 | QTY | UNIT | PRICE    | TOTAL    |
|----------|-----------------------------|-----|------|----------|----------|
| 1        | INTERMEDIATE STORAGE TANK   | 1   | EA   | 10000.00 | 10000.00 |
| 2        | FILTER FEED TANK            | 1   | EA   | 10000.00 | 10000.00 |
| 3        | ALPHA SORPTION TANK         | 1   | EA   | 10000.00 | 10000.00 |
| 4        | CLEANING SOLUTION DUMP TANK | 1   | EA   | 10000.00 | 10000.00 |
| 5        | TRANSFER TANK               | 1   | EA   | 10000.00 | 10000.00 |

| ITEM NO. | DESCRIPTION                 | QTY | UNIT | PRICE    | TOTAL    |
|----------|-----------------------------|-----|------|----------|----------|
| 1        | INTERMEDIATE STORAGE TANK   | 1   | EA   | 10000.00 | 10000.00 |
| 2        | FILTER FEED TANK            | 1   | EA   | 10000.00 | 10000.00 |
| 3        | ALPHA SORPTION TANK         | 1   | EA   | 10000.00 | 10000.00 |
| 4        | CLEANING SOLUTION DUMP TANK | 1   | EA   | 10000.00 | 10000.00 |
| 5        | TRANSFER TANK               | 1   | EA   | 10000.00 | 10000.00 |

DATE: 01/15/04



NOTES

1. ALL DRAWINGS SHALL BE MADE TO SCALE.
2. ALL DIMENSIONS SHALL BE IN INCHES UNLESS OTHERWISE SPECIFIED.
3. ALL DIMENSIONS SHALL BE TO CENTER UNLESS OTHERWISE SPECIFIED.
4. ALL DIMENSIONS SHALL BE TO FACE UNLESS OTHERWISE SPECIFIED.
5. ALL DIMENSIONS SHALL BE TO CENTER UNLESS OTHERWISE SPECIFIED.
6. ALL DIMENSIONS SHALL BE TO FACE UNLESS OTHERWISE SPECIFIED.
7. ALL DIMENSIONS SHALL BE TO CENTER UNLESS OTHERWISE SPECIFIED.
8. ALL DIMENSIONS SHALL BE TO FACE UNLESS OTHERWISE SPECIFIED.
9. ALL DIMENSIONS SHALL BE TO CENTER UNLESS OTHERWISE SPECIFIED.
10. ALL DIMENSIONS SHALL BE TO FACE UNLESS OTHERWISE SPECIFIED.



NO. 00184

PARSONS  
UNITED STATES DEPARTMENT OF ENERGY

SWFT  
LAB DRAIN TANK,  
ALPHA SORPTION DRAIN TANK AND  
SPIRIT ACID STORAGE TANK  
P-401A/B  
(U)





TABLE 7

| ITEM NO. | DESCRIPTION               | QTY | UNIT | PRICE | TOTAL |
|----------|---------------------------|-----|------|-------|-------|
| 1        | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 2        | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 3        | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 4        | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 5        | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 6        | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 7        | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 8        | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 9        | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 10       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 11       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 12       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 13       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 14       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 15       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 16       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 17       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 18       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 19       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 20       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 21       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 22       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 23       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 24       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 25       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 26       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 27       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 28       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 29       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 30       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 31       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 32       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 33       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 34       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 35       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 36       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 37       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 38       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 39       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 40       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 41       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 42       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 43       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 44       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 45       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 46       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 47       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 48       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 49       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 50       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 51       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 52       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 53       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 54       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 55       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 56       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 57       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 58       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 59       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 60       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 61       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 62       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 63       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 64       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 65       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 66       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 67       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 68       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 69       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 70       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 71       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 72       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 73       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 74       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 75       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 76       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 77       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 78       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 79       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 80       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 81       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 82       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 83       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 84       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 85       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 86       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 87       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 88       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 89       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 90       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 91       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 92       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 93       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 94       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 95       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 96       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 97       | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |
| 98       | ALPHA SORPTION DRAIN TANK | 1   | EA   | 15000 | 15000 |
| 99       | SPIRIT ACID STORAGE TANK  | 1   | EA   | 12000 | 12000 |
| 100      | LAB DRAIN TANK            | 1   | EA   | 10000 | 10000 |

SWFT, BDR



F P C J 0002 4


**PARSONS**  
UNITED STATES DEPARTMENT OF ENERGY  
SAVANNAH 8 WEST SITE

| NO. | REV. | DATE  | BY | CHKD. | REVISION             |
|-----|------|-------|----|-------|----------------------|
| 1   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 2   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 3   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 4   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 5   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 6   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 7   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 8   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 9   | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 10  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 11  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 12  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 13  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 14  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 15  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 16  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 17  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 18  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 19  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |
| 20  | 1    | 03/04 | JW | MS    | ISSUE FOR PERMITTING |

PROJECT NO. 1000000000  
GENERAL ARRANGEMENT  
INDEX KEY PLAN  
101  
P-PC-J-0002  
SHEET 008




**KEY PLAN**



**NOTES**

1. FOR GENERAL BUILDING INFORMATION REFER TO SHEET P-10-J-0001.
2. PROVIDE THE SAME SLOPE FOR ALL FLOOR SURFACES AS SHOWN ON SHEET P-10-J-0001. PROVIDE CURBS AND FINISHES AS NOTED.
3. FLOOR FINISHES SHALL BE AS NOTED. PROVIDE FINISHES AS NOTED IN THE SCHEDULE AND OTHERWISE AS NOTED.
4. PROVIDE THE SAME FINISHES FOR ALL FLOOR SURFACES AS NOTED.
5. PROVIDE CURBS AND FINISHES AS NOTED.
6. PROVIDE CURBS AND FINISHES AS NOTED.
7. PROVIDE CURBS AND FINISHES AS NOTED.
8. PROVIDE CURBS AND FINISHES AS NOTED.
9. PROVIDE CURBS AND FINISHES AS NOTED.
10. PROVIDE CURBS AND FINISHES AS NOTED.
11. PROVIDE CURBS AND FINISHES AS NOTED.
12. PROVIDE CURBS AND FINISHES AS NOTED.
13. PROVIDE CURBS AND FINISHES AS NOTED.
14. PROVIDE CURBS AND FINISHES AS NOTED.
15. PROVIDE CURBS AND FINISHES AS NOTED.
16. PROVIDE CURBS AND FINISHES AS NOTED.
17. PROVIDE CURBS AND FINISHES AS NOTED.
18. PROVIDE CURBS AND FINISHES AS NOTED.
19. PROVIDE CURBS AND FINISHES AS NOTED.
20. PROVIDE CURBS AND FINISHES AS NOTED.



CENTRAL PROCESS AREA PLAN AT ELEVATION 100'-0" UNLESS OTHERWISE NOTED



P-10-J-0001  
 P-10-J-0002  
 P-10-J-0003  
 P-10-J-0004



| NO. | DATE    | DESCRIPTION        |
|-----|---------|--------------------|
| 1   | 7/12/09 | ISSUED FOR PERMITS |
| 2   | 7/12/09 | ISSUED FOR PERMITS |
| 3   | 7/12/09 | ISSUED FOR PERMITS |
| 4   | 7/12/09 | ISSUED FOR PERMITS |
| 5   | 7/12/09 | ISSUED FOR PERMITS |
| 6   | 7/12/09 | ISSUED FOR PERMITS |
| 7   | 7/12/09 | ISSUED FOR PERMITS |
| 8   | 7/12/09 | ISSUED FOR PERMITS |
| 9   | 7/12/09 | ISSUED FOR PERMITS |
| 10  | 7/12/09 | ISSUED FOR PERMITS |

SHEET NO. P-10-J-0001  
 SHEET TITLE  
 SHEET SCALE  
 SHEET DATE

SHEET NO. P-10-J-0002  
 SHEET TITLE  
 SHEET SCALE  
 SHEET DATE


SHEET NO. P-10-J-0003  
 SHEET TITLE  
 SHEET SCALE  
 SHEET DATE

SHEET NO. P-10-J-0004  
 SHEET TITLE  
 SHEET SCALE  
 SHEET DATE



COLD CHEMICALS AREA PLAN AT ELEVATION 100'-0"

- NOTES
1. ALL WORK SHALL BE IN ACCORDANCE WITH THE SPECIFICATIONS AND DRAWINGS.
  2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.
  3. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT AREAS AT ALL TIMES.
  4. ALL MATERIALS AND METHODS OF CONSTRUCTION SHALL BE APPROVED BY THE ENGINEER BEFORE USE.
  5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL EXISTING UTILITIES AND STRUCTURES.
  6. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME.
  7. THE CONTRACTOR SHALL MAINTAIN A NEAT AND ORDERLY WORK SITE AT ALL TIMES.
  8. ALL MATERIALS SHALL BE STORED PROPERLY AND PROTECTED FROM THE ELEMENTS.
  9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL ADJACENT AREAS.
  10. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH THE SPECIFICATIONS AND DRAWINGS.



EXPANSIONS  
 UNITED STATES DEPARTMENT OF ENERGY  
 STANFORD BLDG 3113  
 STANFORD, CALIF. 94305

NO. 14718  
 JAMES C. WILLIAMS  
 PROFESSIONAL ENGINEER  
 STATE OF SOUTH CAROLINA

NO. 14718  
 JAMES C. WILLIAMS  
 PROFESSIONAL ENGINEER  
 STATE OF SOUTH CAROLINA

P P G J 0004 11

STAFF  
 PROCESS BUILDING  
 GENERAL ARRANGEMENT  
 COLD CHEMICALS AREA  
 PLAN AT ELEVATION 100'-0"  
 (U)

P-PG-J-0004

| NO. | DATE    | REVISION              |
|-----|---------|-----------------------|
| 1   | 10/1/78 | ISSUED FOR PERMITTING |
| 2   | 10/1/78 | ISSUED FOR PERMITTING |
| 3   | 10/1/78 | ISSUED FOR PERMITTING |
| 4   | 10/1/78 | ISSUED FOR PERMITTING |
| 5   | 10/1/78 | ISSUED FOR PERMITTING |
| 6   | 10/1/78 | ISSUED FOR PERMITTING |
| 7   | 10/1/78 | ISSUED FOR PERMITTING |
| 8   | 10/1/78 | ISSUED FOR PERMITTING |
| 9   | 10/1/78 | ISSUED FOR PERMITTING |
| 10  | 10/1/78 | ISSUED FOR PERMITTING |
| 11  | 10/1/78 | ISSUED FOR PERMITTING |
| 12  | 10/1/78 | ISSUED FOR PERMITTING |
| 13  | 10/1/78 | ISSUED FOR PERMITTING |
| 14  | 10/1/78 | ISSUED FOR PERMITTING |
| 15  | 10/1/78 | ISSUED FOR PERMITTING |
| 16  | 10/1/78 | ISSUED FOR PERMITTING |
| 17  | 10/1/78 | ISSUED FOR PERMITTING |
| 18  | 10/1/78 | ISSUED FOR PERMITTING |
| 19  | 10/1/78 | ISSUED FOR PERMITTING |
| 20  | 10/1/78 | ISSUED FOR PERMITTING |
| 21  | 10/1/78 | ISSUED FOR PERMITTING |
| 22  | 10/1/78 | ISSUED FOR PERMITTING |
| 23  | 10/1/78 | ISSUED FOR PERMITTING |
| 24  | 10/1/78 | ISSUED FOR PERMITTING |
| 25  | 10/1/78 | ISSUED FOR PERMITTING |
| 26  | 10/1/78 | ISSUED FOR PERMITTING |
| 27  | 10/1/78 | ISSUED FOR PERMITTING |
| 28  | 10/1/78 | ISSUED FOR PERMITTING |
| 29  | 10/1/78 | ISSUED FOR PERMITTING |
| 30  | 10/1/78 | ISSUED FOR PERMITTING |
| 31  | 10/1/78 | ISSUED FOR PERMITTING |
| 32  | 10/1/78 | ISSUED FOR PERMITTING |
| 33  | 10/1/78 | ISSUED FOR PERMITTING |
| 34  | 10/1/78 | ISSUED FOR PERMITTING |
| 35  | 10/1/78 | ISSUED FOR PERMITTING |
| 36  | 10/1/78 | ISSUED FOR PERMITTING |
| 37  | 10/1/78 | ISSUED FOR PERMITTING |
| 38  | 10/1/78 | ISSUED FOR PERMITTING |
| 39  | 10/1/78 | ISSUED FOR PERMITTING |
| 40  | 10/1/78 | ISSUED FOR PERMITTING |
| 41  | 10/1/78 | ISSUED FOR PERMITTING |
| 42  | 10/1/78 | ISSUED FOR PERMITTING |
| 43  | 10/1/78 | ISSUED FOR PERMITTING |
| 44  | 10/1/78 | ISSUED FOR PERMITTING |
| 45  | 10/1/78 | ISSUED FOR PERMITTING |
| 46  | 10/1/78 | ISSUED FOR PERMITTING |
| 47  | 10/1/78 | ISSUED FOR PERMITTING |
| 48  | 10/1/78 | ISSUED FOR PERMITTING |
| 49  | 10/1/78 | ISSUED FOR PERMITTING |
| 50  | 10/1/78 | ISSUED FOR PERMITTING |
| 51  | 10/1/78 | ISSUED FOR PERMITTING |
| 52  | 10/1/78 | ISSUED FOR PERMITTING |
| 53  | 10/1/78 | ISSUED FOR PERMITTING |
| 54  | 10/1/78 | ISSUED FOR PERMITTING |
| 55  | 10/1/78 | ISSUED FOR PERMITTING |
| 56  | 10/1/78 | ISSUED FOR PERMITTING |
| 57  | 10/1/78 | ISSUED FOR PERMITTING |
| 58  | 10/1/78 | ISSUED FOR PERMITTING |
| 59  | 10/1/78 | ISSUED FOR PERMITTING |
| 60  | 10/1/78 | ISSUED FOR PERMITTING |
| 61  | 10/1/78 | ISSUED FOR PERMITTING |
| 62  | 10/1/78 | ISSUED FOR PERMITTING |
| 63  | 10/1/78 | ISSUED FOR PERMITTING |
| 64  | 10/1/78 | ISSUED FOR PERMITTING |
| 65  | 10/1/78 | ISSUED FOR PERMITTING |
| 66  | 10/1/78 | ISSUED FOR PERMITTING |
| 67  | 10/1/78 | ISSUED FOR PERMITTING |
| 68  | 10/1/78 | ISSUED FOR PERMITTING |
| 69  | 10/1/78 | ISSUED FOR PERMITTING |
| 70  | 10/1/78 | ISSUED FOR PERMITTING |
| 71  | 10/1/78 | ISSUED FOR PERMITTING |
| 72  | 10/1/78 | ISSUED FOR PERMITTING |
| 73  | 10/1/78 | ISSUED FOR PERMITTING |
| 74  | 10/1/78 | ISSUED FOR PERMITTING |
| 75  | 10/1/78 | ISSUED FOR PERMITTING |
| 76  | 10/1/78 | ISSUED FOR PERMITTING |
| 77  | 10/1/78 | ISSUED FOR PERMITTING |
| 78  | 10/1/78 | ISSUED FOR PERMITTING |
| 79  | 10/1/78 | ISSUED FOR PERMITTING |
| 80  | 10/1/78 | ISSUED FOR PERMITTING |
| 81  | 10/1/78 | ISSUED FOR PERMITTING |
| 82  | 10/1/78 | ISSUED FOR PERMITTING |
| 83  | 10/1/78 | ISSUED FOR PERMITTING |
| 84  | 10/1/78 | ISSUED FOR PERMITTING |
| 85  | 10/1/78 | ISSUED FOR PERMITTING |
| 86  | 10/1/78 | ISSUED FOR PERMITTING |
| 87  | 10/1/78 | ISSUED FOR PERMITTING |
| 88  | 10/1/78 | ISSUED FOR PERMITTING |
| 89  | 10/1/78 | ISSUED FOR PERMITTING |
| 90  | 10/1/78 | ISSUED FOR PERMITTING |
| 91  | 10/1/78 | ISSUED FOR PERMITTING |
| 92  | 10/1/78 | ISSUED FOR PERMITTING |
| 93  | 10/1/78 | ISSUED FOR PERMITTING |
| 94  | 10/1/78 | ISSUED FOR PERMITTING |
| 95  | 10/1/78 | ISSUED FOR PERMITTING |
| 96  | 10/1/78 | ISSUED FOR PERMITTING |
| 97  | 10/1/78 | ISSUED FOR PERMITTING |
| 98  | 10/1/78 | ISSUED FOR PERMITTING |
| 99  | 10/1/78 | ISSUED FOR PERMITTING |
| 100 | 10/1/78 | ISSUED FOR PERMITTING |

KEY PLAN

5000-T-006-A

SCALE 1/8" = 1'-0"

DATE 10/1/78

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER


PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS



NOTES

1. ALL ROOMS SHALL BE FINISHED TO THE FINISHES SHOWN ON THE FINISH SCHEDULE.
2. PROVIDE BUILDING MATERIALS AS LISTED ON THE SPECIFICATIONS AND THE FINISH SCHEDULE.
3. PROVIDE ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
10. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
11. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
12. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
13. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
14. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
15. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
16. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.
17. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THE WORK SHOWN ON THIS PLAN.

NO. 14718



CERTIFICATE OF AUTHORITY

PARSONS

INFRASTRUCTURE & TECHNOLOGY GROUP INC.

1000 EAST 17TH AVENUE, SUITE 1000, DENVER, CO 80202

UNITED STATES DEPARTMENT OF ENERGY

SAFEGUARD DIVISION

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER

PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS

NORTHERN FACILITY SUPPORT AREA PLAN AT ELEVATION 100'-0"

MATCHLINE SEE P-00-J-0003

MATCHLINE SEE P-05-J-0006

SCALE 1/8" = 1'-0"

DATE 10/1/78

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER

PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER

PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS

| NO. | DESCRIPTION | QTY  | UNIT | PRICE  | TOTAL     |
|-----|-------------|------|------|--------|-----------|
| 1   | CONCRETE    | 100  | YD   | 100.00 | 10000.00  |
| 2   | STEEL       | 500  | LB   | 0.50   | 25000.00  |
| 3   | BRICK       | 1000 | YD   | 100.00 | 100000.00 |
| 4   | CEMENT      | 500  | YD   | 100.00 | 50000.00  |
| 5   | SAND        | 1000 | YD   | 100.00 | 100000.00 |
| 6   | GRAVEL      | 1000 | YD   | 100.00 | 100000.00 |
| 7   | ASPHALT     | 1000 | YD   | 100.00 | 100000.00 |
| 8   | PAINT       | 1000 | YD   | 100.00 | 100000.00 |
| 9   | GLASS       | 1000 | YD   | 100.00 | 100000.00 |
| 10  | ROOFING     | 1000 | YD   | 100.00 | 100000.00 |
| 11  | MECHANICAL  | 1000 | YD   | 100.00 | 100000.00 |
| 12  | ELECTRICAL  | 1000 | YD   | 100.00 | 100000.00 |
| 13  | PLUMBING    | 1000 | YD   | 100.00 | 100000.00 |
| 14  | INSULATION  | 1000 | YD   | 100.00 | 100000.00 |
| 15  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 16  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 17  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 18  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 19  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 20  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 21  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 22  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 23  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 24  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 25  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 26  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 27  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 28  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 29  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |
| 30  | FOUNDATION  | 1000 | YD   | 100.00 | 100000.00 |

SHEET NO. 001

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER

PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS

PROJECT NO. 5000-T-006-A

PROJECT NAME

PROJECT LOCATION

PROJECT OWNER

PROJECT ARCHITECT

PROJECT ENGINEER


PROJECT CONTRACTOR

PROJECT SUBMITTER

PROJECT DATE

PROJECT STATUS

PROJECT COMMENTS



EASTERN FACILITY SUPPORT AREA PLAN AT ELEVATION 100'-0"

- NOTES**
1. FOR DETAILS, NOTES, LEGEND, DIMENSIONS, AND SPECIFICATIONS, REFER TO THE DRAWING SHEET AND SPECIFICATIONS.
  2. PROVIDE ALL DIMENSIONS UNLESS OTHERWISE NOTED.
  3. CONSIDER THE WORK AREA TO BE AVOIDED UNLESS OTHERWISE NOTED.
  4. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE NATIONAL FIRE ALARM AND SIGNAL CODE (NFPA 72).
  5. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL BUILDING CODE (NBC) AND THE NATIONAL PLUMBING CODE (NPC).
  6. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL MECHANICAL CODE (NMC) AND THE NATIONAL GAS CODE (NGC).
  7. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL PAVEMENT CODE (NPC) AND THE NATIONAL ROADS AND HIGHWAYS CODE (NRHC).
  8. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL TRANSPORTATION CODE (NTC) AND THE NATIONAL AIRCRAFT CODE (NAC).
  9. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL MARINE CODE (NMC) AND THE NATIONAL COAST AND GEODISY CODE (NCGC).
  10. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL SPACE CODE (NSC) AND THE NATIONAL AERONAUTICS AND SPACE ADMINISTRATION CODE (NASA).



P 76 J 0005 J


**PARSONS**  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIVER SITE

SPR  
 PROCESSING  
 GENERAL MANAGEMENT  
 EASTERN FACILITY SUPPORT AREA  
 PLAN AT ELEVATION 100'-0"

| NO. | DATE    | DESCRIPTION           | BY  | CHKD. |
|-----|---------|-----------------------|-----|-------|
| 1   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 2   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 3   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 4   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 5   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 6   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 7   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 8   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 9   | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 10  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 11  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 12  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 13  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 14  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 15  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 16  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 17  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 18  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 19  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 20  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 21  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |
| 22  | 10/1/00 | ISSUED FOR PERMITTING | JCW | JCW   |

SHEET 001





- NOTES**
1. FOR ROOMS, SEE THE LEGEND, ADMINISTRATION AND GENERAL SERVICE AREAS ARE SHOWN ON SHEET P-0003.
  2. PROCESS BUILDING ELEVATIONS ARE BASED ON ELEVATION 1110.00. ALL ELEVATIONS ARE IN FEET AND INCHES.
  3. ROOM NUMBER INDICATION IS SHOWN IN THE IDENTIFICATION.
  4. ELEVATED
  5. DELETED
  6. PROPOSED MAINTENANCE STAIRS FOR SECOND FLOOR CONTAINMENT.
  7. FLOOR FINISH IS TO BE 3/4" GYPSUM BOARD.
  8. ROOM NOTES ARE BASED ON ARCHITECTURAL FINISHES.
  9. FOR DETAILS OF UTILITIES, SEE SHEETS P-0003, P-0004, P-0005, P-0006, P-0007, P-0008, P-0009, P-0010, P-0011, P-0012, P-0013, P-0014, P-0015, P-0016, P-0017, P-0018, P-0019, P-0020, P-0021, P-0022, P-0023, P-0024, P-0025, P-0026, P-0027, P-0028, P-0029, P-0030, P-0031, P-0032, P-0033, P-0034, P-0035, P-0036, P-0037, P-0038, P-0039, P-0040, P-0041, P-0042, P-0043, P-0044, P-0045, P-0046, P-0047, P-0048, P-0049, P-0050, P-0051, P-0052, P-0053, P-0054, P-0055, P-0056, P-0057, P-0058, P-0059, P-0060, P-0061, P-0062, P-0063, P-0064, P-0065, P-0066, P-0067, P-0068, P-0069, P-0070, P-0071, P-0072, P-0073, P-0074, P-0075, P-0076, P-0077, P-0078, P-0079, P-0080, P-0081, P-0082, P-0083, P-0084, P-0085, P-0086, P-0087, P-0088, P-0089, P-0090, P-0091, P-0092, P-0093, P-0094, P-0095, P-0096, P-0097, P-0098, P-0099, P-0100.



**P. PG. J. 0003 7**

**PARSONS**  
UNITED STATES DEPARTMENT OF ENERGY  
SPAWNSPORT PLANT SITE

DATE: 11/11/98  
SCALE: 1/8" = 1'-0"

PROJECT: PROCESS BUILDING  
GENERAL ARRANGEMENT  
CENTRAL PROCESS AREA  
PLAN AT ELEVATION 116'-0"  
(UNLESS OTHERWISE NOTED)  
101

P-PG-J-0003 7  
SHEET NO. 7

| NO. | DATE     | BY  | CHKD. | REVISION               | DATE     |
|-----|----------|-----|-------|------------------------|----------|
| 1   | 11/11/98 | JCS | JCS   | ISSUED FOR PERMITTING  | 11/11/98 |
| 2   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 3   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 4   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 5   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 6   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 7   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 8   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 9   | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |
| 10  | 11/11/98 | JCS | JCS   | REVISION TO PERMITTING | 11/11/98 |

THE UNITED STATES OF AMERICA

**REGISTERED PROFESSIONAL ENGINEER**  
SOUTH CAROLINA  
NO. 14710  
JAMES G. SMITH, JR.

DATE: 11/11/98



CENTRAL PROCESS AREA PLAN AT ELEVATION 116'-0" (UNLESS OTHERWISE NOTED)

18 17 16 15 14 13 12 11 10 9 8 7 6 5 4 3 2 1

10 9 8 7 6 5 4 3 2 1 A B C D E F G H I J K L M N O P



D1007-067d  
 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20



1. FOR GENERAL NOTES, SEE THE ARCHITECTURAL DRAWINGS.  
 2. PROVIDE ALL ELECTRICAL AND MECHANICAL WORK IN ACCORDANCE WITH THE LATEST EDITIONS OF THE NATIONAL ELECTRICAL CODE AND THE NATIONAL MECHANICAL CODE.  
 3. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE LOCAL HEALTH DEPARTMENT.  
 4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.  
 5. MATERIALS SHALL BE STORED IN A DRY AND VENTILATED AREA.  
 6. PERSONAL SAFETY EQUIPMENT SHALL BE WORN AT ALL TIMES.  
 7. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE LOCAL HEALTH DEPARTMENT.  
 8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.  
 9. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE LOCAL HEALTH DEPARTMENT.  
 10. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE LOCAL HEALTH DEPARTMENT.

**PARSONS**  
 1400 TOWERS DRIVE, SUITE 1000, RICHMOND, VIRGINIA 23219  
 UNITED STATES DEPARTMENT OF ENERGY  
 SAVANNAH RIFER SITE  
 P-PC-J-0010  
 15

| NO. | DESCRIPTION             | DATE     | BY          | CHKD.       |
|-----|-------------------------|----------|-------------|-------------|
| 1   | ISSUED FOR PERMITTING   | 08/27/01 | J. J. JONES | J. J. JONES |
| 2   | ISSUED FOR CONSTRUCTION | 09/10/01 | J. J. JONES | J. J. JONES |
| 3   | ISSUED FOR OPERATION    | 09/10/01 | J. J. JONES | J. J. JONES |
| 4   | ISSUED FOR MAINTENANCE  | 09/10/01 | J. J. JONES | J. J. JONES |
| 5   | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 6   | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 7   | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 8   | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 9   | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 10  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 11  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 12  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 13  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 14  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 15  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 16  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 17  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 18  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 19  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |
| 20  | ISSUED FOR REVISION     | 09/10/01 | J. J. JONES | J. J. JONES |

CENTRAL PROCESS AREA PLAN AT ELEVATION 139'-0"



15  
 P-PC-J-0010  
 SAVANNAH RIFER SITE  
 UNITED STATES DEPARTMENT OF ENERGY  
 PARSONS





Please file as a record document for Construction Permit No. 19,219-IW.

WASTEWATER

FINAL APPROVAL TO PLACE INTO OPERA

*Bany*

ISSUED TO: US DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE  
BUILDING 705-3C  
AIKEN SC 29808

19219-IW

for the operation of a wastewater treatment/collection system permitted under Construction Permit No. 20,234-IW, dated November 1, 2018.

PROJECT NAME: SRS/SALT WASTE PROCESSING FACILITY (SWPF) Final Tie-Ins

COUNTY: Aiken

PROJECT DESCRIPTION: The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for treatment at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A provides a list of equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be vitrified and poured into canisters that are transferred to the Glass Waste Storage Buildings.

PERMITTED FLOW: System Nominal Daily Flow: 35,840 gallons per day  
System Design Capacity Flow: 185,736 gallons per day

WWTP: US DOE/SAVANNAH RIVER SITE Salt Waste Processing Facility (SWPF)

SPECIAL CONDITIONS:

- 1. This permit is in addition to Construction Permit No. 19,219-IW (Salt Waste Processing Facility (SWPF)), Construction Permit No. 20,194-IW (SWPF NGS Cold Chemical Feed Facility), Construction Permit No. 18,801-IW (Saltstone Production Facility (SPF)), Construction Permit No. 17,424-IW (F-Area and H-Area Tank Farms), and Construction Permit No. 16,783, Defense Waste Processing Facility.



2. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by this construction permit. There shall be no radioactive salt solution received from the High Level Waste (HLW) tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued the Approval to Place into Operation for this construction permit.

This approval is based on the APO request letter (SRR-ESH-2019-00118) signed by Ms. Patricia M. Allen. Note that Attachment 1 is the Engineer's letter of certification (signed by Andrew R. Redwood, P.E., South Carolina Registration No. 20525).

*Barry S. Mullinax*

Barry S. Mullinax, Engineer  
(for) Environmental Affairs  
AIKEN EA OFFICE

**Date Issued:** October 29, 2019

cc: Bureau of Water Permitting File – Construction Permit No. 20,234-IW  
Bureau of Water Permitting File – Construction Permit No. 19,219-IW  
Bureau of Water Permitting File – Construction Permit No. 20,194-IW  
Bureau of Water Permitting File – Construction Permit No. 18,801-IW  
Bureau of Water Permitting File – Construction Permit No. 17,424-IW  
Bureau of Water Permitting File – Construction Permit No. 16,783-IW  
Travis Fuss, Aiken EA Office  
Crystal Robertson, Aiken EA Office  
Shawn M. Clarke, BOW, Columbia Office  
Crystal Rippey, BOW – Columbia Office  
Andrew Redwood, P.E.,SRR



Attachment A Equipment List

The equipment included in Construction Permit No. 20,234-IW is listed below:

1. Transfer Line SDP1 and Jumper 6-7(SPP2)2 for Raw Salt Solution (RSS) Transfer Line
2. Jumper 6-7(SPP3)3 for Strip Effluent (SE) Waste Transfer Line
3. Jumper 3(SPP3)15 for Monosodium Titanate Precipitate (MSTPCP) Waste Transfer Line
4. Transfer lines DSS-0077, SSP077, and WTS-SSP4 for the Decontaminated Salt Solution to Tank 50 and the Saltstone Production Facility.



Healthy People. Healthy Communities.

September 24, 2019

Ms. Patricia M. Allen, Director  
Savannah River Remediation, LLC  
Bldg-766H, Room 2308  
Aiken, SC 29808

*Put in file for  
Construction  
Permit No.*

RE: (1) Letter, Patricia M. Allen (SRR) to Barry S  
of Salt Waste Processing Facility Operator Cl  
September 23, 2019

*19,219-IW  
BSM*

*or Reclassification  
08, Dated*

(2) Letter, M. F. Sadler to W.L. Payne, Wastewater Treatment Plant Classification for  
Specialized Facilities at SRS, Dated August 14, 1995.

Dear Ms. Allen:

In Reference 1, SRR submitted a letter to request that the State-certification Classification for operators of specialized radioactive waste treatment facilities at SRS be established as "Not Applicable". This classification was previously established by South Carolina Department of Health and Environmental Control (SCDHEC) in Reference 2. The Department agrees with your request since the operator classifications in the South Carolina Pollution Control Act, Section 48-1-110, do not address the SRS specialized radioactive waste treatment facilities. This "NA" classification applies to the following SRS waste treatment facilities: (e.g., the Actinide Removal Process (ARP), the Modular Caustic Side Solvent Extraction Unit (MCU), the Defense Waste Processing Facility (DWPF), the Saltstone Production Facility (SPF), the Salt Waste Processing Facility (SWPF), and the Tank Closure Cesium Removal (TCCR) facility. While there are no State-certification classifications for operators of the SRS specialized radioactive waste treatment facilities, the Department of Energy (DOE) requires that operators of these specialized SRS treatment facilities receive training and obtain qualifications required by the appropriate administrative procedures. As SCDHEC has previously acknowledged (See Reference 2), the successful completion of the required training and qualification program is considered as an appropriate certification for operators of these SRS facilities.

It should be noted that the South Carolina Pollution Control Act, Section 48-1-110, requirements apply to the Effluent Treatment Project (ETP) and the DWPF Chemical Treatment Facility (through the Central Sanitary Wastewater Treatment Facility). Therefore, State-certified operators of the appropriate grade are required for these facilities.

Please contact me at 803-898-4012 or at [mullinbs@dhec.sc.gov](mailto:mullinbs@dhec.sc.gov) if you have any questions and/or comments.

Sincerely,

Barry Mullinax, P.E.  
Industrial Wastewater Permitting Section

I:\NPDES\INDUST\~SRS\SRS Construction Permits\Operator Classification for Specialized  
Radioactive Waste Treatment Facilities at SRS.doc

cc (via e-mail): Keith Liner, SRR  
Shawn Clarke, SCDHEC - Columbia  
Crystal Rippy, SCDHEC - Columbia  
Crystal Robertson, SCDHEC - Aiken Office

I:\NPDES\INDUST\~SRS\SRS Construction Permits\Operator Classification for Specialized  
Radioactive Waste Treatment Facilities at SRS.doc



**Wastewater System Construction**

**APPROVAL TO PLACE INTO OPERATION**

**ISSUED TO:** US DEPARTMENT OF ENERGY  
SAVANNAH RIVER SITE  
BUILDING 705-3C  
AIKEN SC 29808

for the operation of a wastewater treatment/collection system permitted under Construction Permit No. 19,219-IW, dated August 6, 2008. This construction permit superseded Construction Permit No. 19,164-IW, dated January 2, 2008, that was issued for the installation of three (3) waste transfer line segments.

**PROJECT NAME:** SRS/SALT WASTE PROCESSING FACILITY (SWPF)

**COUNTY:** Aiken

**PROJECT DESCRIPTION:** The Salt Waste Processing Facility (SWPF) is designed to extract and concentrate cesium, strontium, and actinides from salt wastes in the tank farms resulting in effluents that are acceptable for disposal at the Defense Waste Processing Facility (DWPF) and the Saltstone Production Facility (SPF). Attachment A lists the SWPF equipment.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred to Tank 50 to the SPF are contained in Construction Permit No. 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Solid Waste Industrial Permit #025500-1603. The wastewater sent to the DWPF will be disposed as a solid waste in canisters that are transferred to the Glass Waste Storage Buildings.

**PERMITTED FLOW:** System Nominal Daily Flow: 35,840 gallons per day  
System Design Capacity Flow: 185,736 gallons per day


**WWTP:** US DOE/SAVANNAH RIVER SITE Salt Waste  
Processing Facility (SWPF)

**SPECIAL CONDITIONS:**

1. The jumpers that will tie the SWPF in with the SPF and DWPF are permitted by Construction Permit No. 20,234-IW. There shall be no radioactive salt solution received from the HLW tanks for processing and transfer to the DWPF and/or the SPF until these jumpers have been installed and the Department has issued an Approval to Place into Operation for Construction Permit No. 20,234-IW.

2. The use of water, chemicals, and non-radioactive materials to support SWPF activities such as flushing, cleaning, startup testing, and demonstrations to validate performance of components and/or systems is allowed as long as the jumpers in Condition #1 have not been installed or the jumpers are physically isolated from the SWPF.
3. NPDES Permit No. SC0000175 allows the disposal of "scavenger" wastewater. If the wastewater is not scavenger wastewater, a written request shall be submitted to the Department describing this wastewater. No discharge of this wastewater may be performed without the written approval from the Department.
4. Note that Construction Permit No. 20,194-IW was issued for the Next Generation Solvent Cold Chemical Feed Facility. This facility is in addition to Construction Permit No. 19,219-IW that was issued for the SWPF.

This approval is based on the Engineer's letter of certification signed by James C. Somma, P.E., South Carolina Registration No. 14718 (Parsons).

  
Barry S Mullinax, Engineer  
(for) Environmental Affairs  
AIKEN EA OFFICE

**Date Issued:** August 14, 2019

cc: Bureau of Water Permitting File – Construction Permit No. 19,219-IW  
Bureau of Water Permitting File – Construction Permit No. 20,194-IW  
Bureau of Water Permitting File – Construction Permit No. 20,234-IW  
Travis Fuss, Aiken EA Office  
Shawn M. Clarke, BOW – Columbia  
Crystal Rippy, BOW - Columbia  
Crystal Robertson, Aiken EA Office  
James Somma, P.E., Parsons

**Attachment A for SWPF Approval to Operate (APO)**

**SWPF Equipment List (Drawing No. G-P1-J-00001)**

**PROCESS BUILDING – PROCESS EQUIPMENT**

| Tank Number              | Tank Name                                  |
|--------------------------|--|
| <b>Process Cell Area</b> |  |
| TK-101                   | Alpha Sorption Tank-A (AST-A)              |
| TK-102                   | Filter Feed Tank-A (FFT-A)                 |
| TK-103                   | Cleaning Solution Dump Tank-A (CSDT-A)     |
| TK-104                   | Sludge Solids Receipt Tank (SSRT)          |
| TK-105                   | Wash Water Hold Tank (WWHT)                |
| TK-109                   | Salt Solution Feed Tank (SSFT)             |
| TK-121A/B/C              | Back Pulse Tank                            |
| TK-123                   | Washing Filter Back Pulse Tank             |
| TK-127                   | Spent Acid Storage Tank (SAST)             |
| TK-205                   | Strip Effluent Hold Tank (SEHT)            |
| TK-208                   | Solvent Drain Tank                         |
| TK-235                   | Lab Drain Tank                             |
| TK-505                   | Backup Air Receiver                        |
| TK-506                   | Backup Air Receiver                        |
| TK-601                   | Alpha Sorption Drain Tank (ASDT)           |
| <b>Operating Deck</b>    |  |
| TK-122                   | Back Pulse Charge Tank-A                   |
| TK-128                   | AST-A Air Pulse Agitator Charge Tank       |
| TK-129                   | FFT-A Air Pulse Agitator Charge Tank       |
| TK-131                   | SSRT Air Pulse Agitator Charge Tank        |
| TK-132                   | SSFT Air Pulse Agitator Charge Tank        |
| TK-133                   | WWHT Air Pulse Agitator Charge Tank        |
| <b>CSSX Tank Cell</b>    |  |
| TK-202                   | Solvent Hold Tank (SHT)                    |
| TK-203                   | Strip Effluent Coalescer                   |
| TK-204                   | Caustic Wash Tank                          |
| TK-206                   | Ba-137 Decay Tank (BDT)                    |
| TK-211                   | Decontaminated Salt Solution Stilling Tank |
| TK-212                   | Strip Effluent Stilling Tank               |
| TK-215                   | Strip Effluent Pump Tank                   |
| TK-217                   | Solvent Strip Feed Tank                    |



| <b>Tank Number</b>              | <b>Tank Name</b>                         |
|---------------------------------|--|
| <b>CSSX Contactor Drop Area</b> |  |
| TK-201                          | Decon. Salt Solution Coalescer           |
| <b>Cold Chemicals Area</b>      |  |
| TK-106                          | Filter Cleaning Acid Feed Tank           |
| TK-107                          | Filter Cleaning Caustic Tank             |
| TK-108                          | Caustic Dilution Feed Tank               |
| TK-301                          | Process Water Tank                       |
| TK-302                          | Caustic Receipt Tank                     |
| TK-303                          | Caustic Makeup Tank                      |
| TK-304                          | Nitric Acid Receipt Tank                 |
| TK-305                          | Process Water Pressure Tank              |
| TK-307                          | Nitric Acid Scrub Makeup Tank            |
| TK-311                          | MST Storage Tank                         |
| TK-312                          | DI Water Storage Tank                    |
| TK-313                          | Solvent Makeup Tank                      |
| TK-314                          | DI Water Expansion Tank                  |
| TK-317                          | Neutralization Tank                      |
| TK-330                          | Argon Tank                               |
| <b>CSSX Contactor Area</b>      |  |
| EXT-201A-P                      | Solvent Extraction Contactors            |
| EXT-202A/B                      | Scrub Contactors                         |
| EXT-203A-P                      | Stripping Contactors                     |
| EXT-204A/B                      | Caustic Wash Contactors                  |
| <b>Process Filters</b>          |  |
| FLT-102A/B/C                    | Alpha Sorption Filters                   |
| FLT-104                         | Washing Filter                           |
| <b>Alpha Finishing Facility</b> |  |
| TK-207                          | DSS Hold Tank (DSSHT)                    |
| TK-220                          | Intermediate Storage Tank (IST)          |
| TK-221                          | Alpha Sorption Tank - B (AST-B)          |
| TK-222                          | Filter Feed Tank - B (FFT-B)             |
| TK-223                          | Cleaning Solution Dump Tank - B (CSDT-B) |
| TK-224                          | MST/Sludge Transfer Tank (MSTT)          |
| TK-225A/B/C                     | Finishing Area Back Pulse Tank           |
| TK-228                          | Alpha Finishing Drain Tank (AFDT)        |
| TK-233                          | Back Pulse Charge Tank B                 |
| TK-236/237                      | Lab Collection Tank                      |
| TK-604                          | Low Level Drain Tank                     |
| FLT-222A/B/C                    | Alpha Sorption Filters                   |

| <b>PUMPS</b>                            |   |
|---|---|
| <b>North ASP Pump and Valve Gallery</b> |   |
| P-015A                                  | ASP Secondary Loop Pump Water Pump        |
| P-015B                                  | ASP Secondary Loop Pump Water Pump        |
| P-101A/B                                | Alpha Sorption Tank-A Transfer Pumps      |
| P-102-1A/B/C                            | Filter Feed/Solids Trans Pumps            |
| P-102-2 A/B/C                           | Filter Recirculation Pumps                |
| P-104-1                                 | Washing FLT Feed/Sludge Solids Trans Pump |
| P-104-2                                 | Washing Filter Recirculation Pump         |
| P-110                                   | ASP Sump Trans Pump                       |
| <b>South ASP Pump and Valve Gallery</b> |   |
| P-105A/B                                | Wash Water Trans Pumps                    |
| P-208A/B                                | Solvent Drain Tank Pumps                  |
| P-601A/B                                | Alpha Sorption Drain TK Transfer Pumps    |
| <b>CSSX Pump and Valve Gallery</b>      |   |
| P-109A/B                                | Salt Solution Feed Pumps                  |
| P-202A/B                                | Solvent Feed Pumps                        |
| P-204A/B                                | Caustic Wash Tank Pumps                   |
| P-205A/B                                | Strip Effluent Trans Pumps                |
| P-206A/B                                | Ba-137 Decay Tank Trans Pumps             |
| P-212A/B                                | Strip Effluent Coalescer Feed Pumps       |
| P-215A/B                                | Strip Effluent Pump Tank Pumps            |
| P-217A/B                                | Solvent Strip Feed Pumps                  |
| P-218                                   | CSSX Tank Cell Sump Transfer Pump         |
| <b>Sample Pump and Valve Gallery</b>    |   |
| SP-101                                  | Alpha Sorption Tank-A Sample Pump         |
| SP-102                                  | Filter Feed Tank-A Sample Pump            |
| SP-103                                  | Cleaning Solution Dump Tank-A Sample Pump |
| SP-104                                  | Sludge Solids Receipt Tank Sample Pump    |
| SP-105                                  | Wash Water Hold Tank Sample Pump          |
| SP-109                                  | Salt Solution Feed Tank Sample Pump       |
| SP-205                                  | Strip Effluent Hold Tank Sample Pump      |
| SP-235                                  | Lab Drain Tank Sample Pump                |
| <b>Drum off/Decon Area</b>              |   |
| P-605                                   | Decon Area Sump Pump                      |

| <b>PUMPS (continued)</b>        |   |
|---------------------------------|---|
| <b>Cold Chemicals Area</b>      |   |
| P-106                           | <b>Acid Transfer Pump</b>                       |
| P-107                           | Filter Cleaning Caustic Trans Pump              |
| P-108                           | Caustic Dilution Trans Pump                     |
| P-300                           | Cold Chemicals Receiving Dock Sump Pump         |
| P-301-1                         | Process Water Utility Pump                      |
| P-301-2                         | Flush Pump                                      |
| P-302                           | Caustic Trans Pump                              |
| P-303                           | Caustic Makeup Trans Pump                       |
| P-304-1                         | Nitric Acid Metering Pump                       |
| P-304-2                         | Neutralization Metering Pump                    |
| P-305A/B                        | Sodium Hypochlorite Addition Pump               |
| P-309A/B                        | Scrub Feed Pumps                                |
| P-310A/B                        | Strip Feed Pumps                                |
| P-311                           | MST Transfer Pump                               |
| P-311-1                         | MST Drum Pump                                   |
| P-312-1                         | DI Water Trans Pump                             |
| P-312-2                         | Scrub Water Feed Pump                           |
| P-312-3A/B                      | Strip Water Feed Pumps                          |
| P-313                           | Solvent Makeup Trans Pump                       |
| P-313-1                         | Solvent Drum Pump                               |
| P-317                           | Neutralization Tank Discharge Pump              |
| P-318                           | Caustic Sump Pump                               |
| P-319                           | <b>Acid Sump Pump</b>                           |
| P-320                           | Neutralization Sump Pump                        |
| P-321                           | Nitric Acid Sump Pump                           |
| P-322                           | Water Sump Pump                                 |
| P-326                           | Pump Seal Make-up Water Supply Pump             |
| <b>Alpha Finishing Facility</b> |   |
| P-207A/B                        | <b>DSS Hold Tank Transfer Pumps</b>             |
| P-220A/B                        | <b>Intermediate Storage Tank Transfer Pumps</b> |
| P-221A/B                        | <b>Alpha Sorption Tank B Transfer Pumps</b>     |
| P-222-1A/B/C                    | <b>Filter Feed/Solids Transfer Pumps</b>        |
| P-222-2A/B/C                    | <b>Filter Recirculation Pumps</b>               |
| P-224                           | <b>MST/Sludge Transfer Pump</b>                 |
| P-228                           | <b>Alpha Finishing Drain Tank Transfer Pump</b> |
| <b>PUMPS (continued)</b>        |   |

|                              |  |
|------------------------------|--|
| P-236                        | Lab Collection Tank Pump                       |
| P-604                        | Low Level Drain Tank Transfer Pump             |
| P-025A/B                     | AFP Secondary Cooler Loop Pump                 |
| SP-207, SP-220 – SP-224      | Sample Pumps                                   |
| P-210, P-226, P-227, P-228-1 | AFF Sump Pumps                                 |
| P-229                        | Alpha Finishing Process Filter Loop Drain Pump |
| <b>AGITATORS</b>             |  |
| AGT-107                      | Filter Cleaning Caustic Tank Agitator          |
| AGT-108                      | Caustic Dilution Feed Tank Agitator            |
| AGT-303                      | Caustic Makeup Tank Agitator                   |
| AGT-307                      | Nitric Acid Scrub Makeup Tank Agitator         |
| AGT-311                      | MST Storage Tank Agitator                      |
| AGT-311-1                    | MST Drum Agitator                              |
| AGT-313                      | Solvent Makeup Tank Agitator                   |
| AGT-221                      | Alpha Sorption Tank B Agitator                 |
| AGT-222                      | Filter Feed Tank B Agitator                    |
| AGT-224                      | MST/Sludge Transfer Tank Agitator              |
| <b>LABORATORY EQUIPMENT</b>  |  |
| GB-001 – GB-011, GB-014      | Glove Boxes                                    |
| RH-001 – RH-017              | Radio Hoods                                    |
| FH-001                       | Fume Hood                                      |
| HC-001 – HC-004              | Hot Cell Windows                               |
| STS-101                      | Sample Transfer System                         |
| <b>ELECTRICAL SYSTEMS</b>    |  |
| ATS-203 – ATS-205            | Automatic Transfer Switch                      |
| ATS-207                      | Automatic Transfer Switch                      |
| ATS-208                      | Automatic Transfer Switch                      |
| ATS-210                      | Automatic Transfer Switch                      |
| MCC-201 – MCC-206            | Motor Control Center                           |
| MCC-209 – MCC-210            | Motor Control Center                           |
| SWGR-201 – SWGR-204          | Switchgear                                     |
| USX-301                      | Uninterruptible Power Supply                   |

| <b>INSTRUMENTATION</b>                                    |   |
|---|---|
| ICP-001 – ICP-013   | Instrument Control Panel                      |
| ICP-014 – ICP-016   | Instrument Control Panel                      |
| IR-001 – IR-014, IR-016 – IR-022, IR-024, IR-026 – IR-040 | Instrument Control Rack                       |
| <b>AIR HANDLING EQUIPMENT</b>                             |   |
| ACU-001   | Wall Mounted Heat Pump                        |
| AHU-001 – AHU-006   | Air Handling Units                            |
| AHU-008 – AHU-009   | Air Handling Units                            |
| <b>Filters/Fans/Coils</b>                                 |   |
| CCL-401A/B  | Process Vessel Vent Coolers                   |
| CCL-402A/B  | Pulse Mixer Vent Coolers                      |
| FAN-401A/B  | Process Vessel Vent Exhaust Fans              |
| FAN-402A/B  | Pulse Mixer Vent Exhaust Fans                 |
| FAN-001   | Exhaust Fan                                   |
| FAN-002   | Exhaust Fan                                   |
| FAN-003   | Exhaust Fan on Roof                           |
| FAN-004   | Exhaust Fan on Roof                           |
| FAN-007   | Exhaust Fan on Roof                           |
| FAN-009   | Exhaust Fan on Roof                           |
| FAN-010   | Exhaust Fan on Roof                           |
| FAN-013   | Exhaust Fan on Roof                           |
| FAN-014   | Exhaust Fan on Roof                           |
| FAN-015   | Exhaust Fan on Roof                           |
| FLT-001 – FLT-004   | Exhaust Air HEPA Filters                      |
| FLT-009   | Lab Exhaust Air HEPA Filter                   |
| FLT-010 – FLT-016   | Cell Inlet Air HEPA Filters                   |
| FLT-017   | Lab Exhaust Air HEPA Filter                   |
| FLT-020   | Hot Lab Intake Filter Above Suspended Ceiling |
| FLT-021   | Hot Cell Exhaust Air HEPA Filter              |
| FLT-022   | Hot Cell Exhaust Air HEPA Filter              |
| FLT-023 – FLT-034   | Glovebox Inlet Air HEPA Filters               |
| FLT-240 – FLT-242   | Solvent Recovery Filters                      |
| FLT-250   | Solvent Adjustment Filter                     |
| FLT-301A/B  | Process Water Cartridge Filter                |
| FLT-401A/B  | Process Vessel Vent Filters                   |
|   |   |

**AIR HANDLING EQUIPMENT (continued)**

|                    |  |
|--------------------|--|
| FLT-402A/B/C/D     | Pulse Mixer Vent Filters                 |
| HRC-001            | Heat Recovery Coil                       |
| <b>Scrubbers</b>   |  |
| SCB-001            | Scrubber                                 |
| SCB-002            | Scrubber                                 |
| SCB-003            | Hot Cell Scrubber                        |
| SCB-004            | Hot Cell Scrubber                        |
| SCFS-001           | Scrubber Caustic Feed System             |
| SCFS-002           | Scrubber Caustic Feed System             |
| <b>Separators</b>  |  |
| SEP-001            | Bldg Chilled Water Air Separator         |
| SEP-003            | Control Room Chilled Water Air Separator |
| SEP-005            | Process Chilled Water Air Separator      |
| SEP-007            | Heat Recovery Air Separator              |
| <b>Pumps</b>       |  |
| P-001A/B           | Bldg Chilled Water Supply Pumps          |
| P-003A/B           | Control Room Chilled Water Pumps         |
| P-005A/B           | Process Chilled Water Supply Pumps       |
| P-007A/B           | Heat Recovery Water Pumps                |
| <b>Tanks</b>       |  |
| TK-001             | Bldg Chilled Wtr Exp Tank                |
| TK-002             | Bldg Chilled Wtr Chem Feed Tank          |
| TK-003             | Control Room Chilled Wtr Exp Tank        |
| TK-004             | Control Room Chilled Wtr Chem Feed Tank  |
| TK-005             | Process Chilled Wtr Exp Tank             |
| TK-006             | Process Chilled Wtr Chem Feed Tank       |
| TK-007             | Heat Recovery Bladder Exp Tank           |
| TK-008             | Heat Recovery Chemical Feed Tank         |
| TK-015             | Process Chilled Water Expansion Tank     |
| TK-016             | Chemical Bypass Feeder Tank              |
| TK-025             | Process Chilled Water Expansion Tank     |
| <b>Ventilators</b> |  |
| VLR-001            | Gravity Roof Ventilator                  |
| VLR-002            | Gravity Roof Ventilator                  |

**MISCELLANEOUS ITEMS**

|             |   |
|-------------|---|
| BTR-001     | DW Pressure Booster System                    |
| CMP-504     | Back Up Air Receiver Compressor               |
| DMST-401A/B | Process Vessel Vent Demisters                 |
| DMST-402A/B | Pulse Mixer Vent Demisters                    |
| FAN-005     | Exhaust Fan                                   |
| FAN-006     | Exhaust Fan                                   |
| FLT-007     | Exhaust Air HEPA Filter                       |
| HTR-007     | Domestic Water Heater/Tank                    |
| HTR-017A/B  | Strip Contactors Tempered Water Heaters       |
| HTR-203A/B  | Solvent Strip Feed Tempered Water Heaters     |
| HTR-310A/B  | Strip Feed Heaters                            |
| HTR-401A/B  | Process Vessel Vent Heaters                   |
| HTR-402A/B  | Pulse Mixer Vent Heaters                      |
| HX-015      | ASP Secondary Loop Cooler                     |
| HX-025      | AFP Secondary Loop Cooler                     |
| HX-102A/B/C | Filter Recirculation Coolers                  |
| HX-104      | Washing Filter Recirculation Cooler           |
| HX-201      | Salt Solution Feed Cooler                     |
| HX-202A/B   | Solvent Feed Coolers                          |
| HX-203      | Strip Contactor Tempered Water Heat Exchanger |
| HX-217A/B   | Solvent Strip Feed Heat Exchanger             |
| HX-222A/B/C | Filter Recirculation Coolers                  |
| HX-250      | Solvent Adjustment Heat Exchanger             |
| IX-312      | DI Water Package Unit                         |
| SEP-015     | Process Chiller Water Air Separator           |
| SEP-025     | Process Chilled Water Separator               |
| VMP-001     | Vibration Monitor Panel                       |



December 21, 2010

SRR-ESH-2010-00154

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Re: Construction Permit No.: 19,219-IW Salt Waste Processing Facility – Phase 2  
Notification of Change in Permit Expiration Date by Operation of Law: Act 297


Dear Mr. Mullinax:

At the direction of the Department of Energy-Savannah River Operations Office (DOE-SR), and in accordance with discussions between DOE-SR and the South Carolina Department of Health and Environmental Control (SCDHEC) on December 13, 2010, this letter documents our notification to SCDHEC that the expiration date contained in the referenced construction permit for the Salt Waste Processing Facility (September 30, 2011) is automatically extended to February 25, 2016 by operation of law (specifically Act 297, the “Permit Extension Joint Resolution of 2010,” which “suspends the running of the normal time periods of development approvals issued by DHEC”).

If you have any questions, please do not hesitate in contacting Ron Campbell (803-557-6585) of my staff.

Sincerely,

Patricia M. Allen, Manager  
Environment, Safety, Health, and Quality Assurance and Contractor Assurance





Mr. Barry S. Mullinax, P.E.

SRR-ESH-2010-00154

Page Two

cc: M. D. Wilson, SCDHEC – Columbia  
C. D. Rippy, SCDHEC – Columbia  
J. R. Hughes, SCDHEC – Aiken  
J. C. Yon, SCDHEC – Aiken

(via electronic transmission):

Spears, T.J., DOE-SR  
Suggs, P.C., DOE-SR  
Ross, S. R., DOE-SR  
Seitz, J. K., DOE-SR  
Polk, P.A., DOE-SR  
Southern, S.L., DOE-SR  
Hoel, D. F., DOE-SR  
Watson, A. I., DOE-SR

Hyatt, J. E., SRNS  
Millings, V. E. III, SRNS

Breor, M.R., Parsons  
Gurske, R.H., Parsons

Bethurem, N. L., SRR  
Borders, M. N., SRR  
Cantrell, J. R., SRR  
Clark, W. C., Jr., SRR  
Dickenson, J. E., SRR  
England, T. F., SRR  
Franklin, V. A., SRR  
Freed, E. J., SRR  
Harp, K. D., SRR  
Liner, K. R., SRR  
Little, D. B., SRR  
Skiff, D. P., SRR  
Stevens, O. D., SRR  
Tseng, J. C., SRR  
Wilkerson, S. W., SRR  
Winkler, C. J., SRR

File Information:

SCDHEC, Industrial Wastewater Treatment Facility Permit  
Modular Caustic-Side Solvent Extraction Unit  
1066, DOE/ADM  
16-1.5(a) Permanent

BOARD:  
Paul C. Aughtry, III  
Chairman  
Edwin H. Cooper, III  
Vice Chairman  
Steven G. Kisner  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment*

BOARD:  
Henry C. Scott  
M. David Mitchell, MD  
Glenn A. McCall  
Coleman F. Buckhouse, MD

August 30, 2010

Mr. Ron Campbell  
Savannah River Remediation, LLC  
Bldg. 705-1C  
Aiken, SC 29808

RE: Modification of SWPF Effluent Discharge Rate Dated August 25, 2010  
Construction Permit No. 19,219-IW SWPF Phase 2  
Savannah River Site  
Aiken County

Dear Mr. Campbell:

This Office has reviewed the referenced letter regarding the average flow and the design capacity flow for the Salt Waste Processing Facility (SWPF). The flow rate listed in the construction permit application submittal was the influent average flow rate and did not accurately list the average flow and design capacity flow for effluent discharged from the SWPF. Based on the information submitted in your letter, the flow correct flow rates for the SWPF are listed below to reflect the design capability and normal operation of the SWPF:

System Nominal Daily Flow: 35,840 gallons per day

System Design Capacity Flow: 185,736 gallons per day

There are no modifications due to this change for Construction Permit No. 19,219-IW for the SWPF. This letter provides the Department's approval of the flow rates that reflect the actual design capacity flow and nominal daily operating flow for the SWPF. This information will be submitted as a supplemental record for this construction permit.

If there are any questions, please contact me by telephone at 803.898.4012 or contact me by e-mail at [mullinbs@dhec.sc.gov](mailto:mullinbs@dhec.sc.gov).

Sincerely,

Barry Mullinax, PE  
Environmental Engineer  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division

cc: Josh Yon, Region 5 EQC – Aiken Office



SAVANNAH RIVER REMEDIATION LLC

We do the right thing.

Savannah River Site, Aiken, SC 29808

SRR-CES-2010-00055

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

**AUG 25 2010**

Re: Construction Permit No.: 19,219-IW SRS / Salt Waste Processing Facility / Phase 2  
Modification of Effluent Discharge Rate

Dear Mr. Mullinax:

In 2008, on behalf of the U. S. Department of Energy, the referenced industrial wastewater treatment permit was applied for and received from the South Carolina Department of Health and Environmental Control, which allowed the Salt Waste Processing Facility to commence construction of this facility. Part of the 2008 submittal consisted of the Bureau of Water's Construction Permit Application for Wastewater Facilities (Form DHEC 1970 (06/2003), since revised) which contained an entry of 26,000 gallons per day in response to the question of total average design flow for this facility. This value accurately stated the rate of flow into the facility (the influent rate), but was not intended to reflect the gallons per day which could potentially be discharged from the Salt Waste Processing Facility to the Defense Waste Processing Facility or the Saltstone Production Facility (the effluent rate).

As detailed in the attached letter from Parsons to the U. S. Department of Energy, we respectfully request the permit be amended to indicate an effluent discharge to the Defense Waste Processing Facility and Saltstone Production Facility at a rate not to exceed 190,000 gallons per day. The nominal daily flow rate is approximately 35,840 gallons per day (estimated daily volumes of Decontaminated Salt Solution of 33,106 gal, Strip Effluent 2,074 gal, and MST/Sludge Solids 660 gal). This permit modification does not involve a change to any equipment or processing rates, but merely corrects the maximum permitted gallons per day that could be transferred out of the facility based on the design originally described in the construction permit application for which the permit was issued. If you have any questions, please contact Ron Campbell (803-557-6585) of my staff.

Sincerely,

Patricia M. Allen, Manager  
Environment, Safety, Health, and Quality Assurance and Contractor Assurance

Enc.

cc: J. M. Ridley, DOE-SR  
S. L. Southern, DOE-SR  
P. A. Polk, DOE-SR  
M. R. Breor, Parsons  
R. H. Gurske, Parsons  
C. D. Rippy, SCDHEC - Columbia  
M. D. Wilson, SCDHEC - Columbia  
J. C. Yon, SCDHEC - Aiken  
V. E. Millings III, SRNS  
K. D. Harp, SRR

# PARSONS

1080 Silver Bluff Road • Aiken, South Carolina 29803 • (803) 643-7100 • Fax: (803) 643-7101 • [www.parsons.com](http://www.parsons.com)

June 14, 2010

Ref. No.: 00-700-15631

Mr. Phillip A. Polk  
Federal Project Director  
U.S. Department of Energy  
Savannah River Operations Office  
P.O. Box A  
Aiken, South Carolina 29802

Subject: Contract No. DE-AC09-02SR22210  
Salt Waste Processing Facility (SWPF) Project  
Request to Amend Wastewater Construction Permit #19219-IW to Increase  
Effluent Throughput

Reference: Wastewater Construction Permit Number 19219-IW issued to SRS/Salt Waste  
Processing Facility/Phase 2

Dear Mr. Polk:

In consultation and agreement with DOE Savannah River Remediation LLC (SRR), Parsons is submitting a request to amend the permitted throughput in the Wastewater Construction Permit Number 19219-IW issued by the Bureau of Water, South Carolina Department of Health and Environmental Control (SCDHEC). Specifically, Parsons is requesting to raise the permitted throughput to more accurately reflect design capacity discharge of the Salt Waste Processing Facility.

Attached is the justification for the increase in throughput. This request needs to be submitted to SRR, Ron Campbell, Environmental Services Section, in accordance with ICD-19, for submission to the SCDHEC.

If you have any questions concerning this response, please contact Richard Gurske at (803)208-6791.

Very respectfully,



Mark R. Breor  
Vice President and Project Manager

MRB/dw



cc: L. Zalants, DOE-SR  
S. McMullin, DOE-SR  
D. Bender, DOE-SR  
K. Harp, SRR  
R. Campbell, SRR  
B. Brasel, SWPF  
A. Doswell, SWPF  
SWFDCA  
File 3.4.1

### IWTF Construction Permit Modification Request

The Salt Waste Processing Facility (SWPF) wishes to amend the SCDHEC Construction Permit 19219-IW, issued 06 August 2008, to change the permit condition limiting the discharge rate of 26,000 gallons per day (gpd). The rationale behind this request is, because SWPF understood the SCDHEC Construction Permit Application form in block "X. Wastewater Systems: B) Total average design flow of the project not to exceed \_\_\_ GPD" as being the influent, SWPF put in the number 26,000 gpd which equates to the design annual design capacity of 9.4 M gallons per year divided by 365. This number is not the effluent proposed to discharge to the Defense Waste Processing Facility (DWPF) and the Saltstone Processing Facility (SPF). Because SWPF is a wastewater treatment facility, a large amount of specialty chemicals will be introduced and mixed with the influent for treatment and separation purposes. This will create wastewater effluent in quantities much greater than the influent. Since it is a batch process, the amount transferred on any given calendar day can greatly exceed the average rate.

SWPF's batch discharge of Decontaminated Salt Solution (DSS) will occur on an approximate daily basis, but once a week, the MST/Sludge and Strip Effluent streams could be transferred on the same day as a DSS transfer. The table below summarizes the waste streams and rate or amount anticipated to be discharged. Pump capacities are shown in parentheses to demonstrate the ability to achieve the volumes per day shown. The total daily volume discharged on a day when all streams are transferred is anticipated to be 36,000 gpd, rounded up.

| <b>Stream</b>   | <b>Rate or Amount</b>  | <b>Volume per day</b> |
|---|--|-----------------------|
| <b>MST/Sludge Solids Receipt Tank (SSRT)(TK-104)to DWPF</b> | 4,158 gallons/7 batches/21.6 hours<br>(Washing filter feed /sludge solids transfer pump P-104-1 150 gpm) | 660 gal               |
| <b>Strip Effluent Hold Tank (SEHT) (TK-205)to DWPF</b>      | 1.44gpm(Strip effluent transfer pumps P-205A/B 300 gpm)  | 2,074 gal             |
| <b>DSS Hold Tank (DSSHT) (TK-207)to SPF</b>                 | 22.99 gpm (DSS Hold Tank transfer pumps P-207A/B – max. cap. 400 gpm)                                    | 33,106 gal            |
| <b>Total</b>  |  | <b>35,840 gal</b>     |

Another scenario could occur warranting a number even higher than the 36,000 gpd mentioned above. Because the 36,000 gpd number does not take into account any outages occurring at DWPF or SPF, there will be a need to store as much treated material as possible pending concurrent discharge to DWPF or SPF. As a worst case scenario, during an outage at DWPF and SPF, SWPF could store DSS in up to 4 large Alpha Finishing Facility vessels (Decontaminated Salt Solution Hold Tank [DSSHT], Intermediate Storage Tank [IST], Alpha Sorption Tank-B [AST-B] and Filter Feed Tank-B [FFT-B]), and strip effluent in the Strip Effluent Hold Tank (SEHT), and the MST/Sludge stored in the Sludge Solids Receipt Tank (SSRT). Additionally, the DSSHT and the SEHT would be normally filling while the transfers are going on. This scenario assumes that coming out of an outage from either DWPF or SPF, the 4 AFF vessels, the SSRT and the SEHT are full of conforming product and SEHT and an AFF vessel (DSSHT)

continue to receive product at design rates for the entire 24 hours. SWPF could discharge all of these tanks within a 24 hour period and a discharge of almost 190,000 gallons in one day could occur. As this number would be the maximum amount that could be transferred in one day, SWPF is requesting 190,000 gallons per day for a limiting permit condition. This would avoid the need for a permit variance request or reduction in throughput. Please see the table below that details this scenario.

| <i>Vessel</i>                         | <i>Working Volume (gal)</i> | <i>Influent during transfer (gal)</i> | <i>Total (gal) discharged within 24 Hours</i> |
|---------------------------------------|-----------------------------|---------------------------------------|---|
| <i>SSRT (TK-104)</i>                  | 5,200                       | 0                                     | To DWPF 5,200                                 |
| <i>SEHT (TK-205)</i>                  | 16,600                      | 2,016                                 | To DWPF 18,616                                |
| <i>Alpha Finishing Facility tanks</i> |                             |                                       |   |
| <i>DSSHT (TK-207)</i>                 | 35,900                      | 33,120                                | To SPF 69,020                                 |
| <i>IST (TK-220)</i>                   | 30,300                      | 0                                     | To SPF 30,300                                 |
| <i>AST-B (TK-221)</i>                 | 30,700                      | 0                                     | To SPF 30,700                                 |
| <i>FFT-B (TK-222)</i>                 | 31,900                      | 0                                     | To SPF 31,900                                 |
| <b>Grand Total</b>                    |                             |                                       | <b>Total 185,736</b>                          |

BOARD:

Paul C. Aughtry, III  
Chairman

Edwin H. Cooper, III  
Vice Chairman

Steven G. Kisner  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment*

BOARD:

Henry C. Scott

M. David Mitchell, MD

Glenn A. McCall

Coleman F. Buckhouse, MD

August 06, 2008

Mark R Breor  
US DEPT OF ENERGY SAVANNAH RIVER SITE  
742-A  
AIKEN, SC 29808

Re: Construction Permit No. 19219-IW  
SRS/SALT WASTE PROCESSING FACILITY/PHASE 2  
Aiken County

Dear Mark R Breor:

Enclosed is a SC Wastewater Construction Permit for the above referenced project. Construction is to be performed in accordance with this permit and supporting engineering report, plans, and specifications approved by this Office.

This system cannot be placed into operation until final approval is granted by the appropriate Environmental Quality Control (EQC) Regional Office. Your Regional contact is Joshua C Yon, in the Aiken EQC Office. This regional office should be notified when construction begins at the following address and phone number: 206 Beaufort St NE, Aiken, SC 29801, 803-641-7670.

Upon completion of any construction, a letter must be submitted to the EQC Regional Office from the registered engineer certifying that the construction has been completed in accordance with the approved plans and specifications. An inspection may then be scheduled. The EQC Regional Office will approve the system for operation upon successful completion of this project.

Sincerely,

*Barry Mullinax*

Barry Mullinax, PE,  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division

cc: Joshua C Yon - Region 5, Aiken EQC Office  
James Somma, Parsons, 1080 Silver Bluff Rd., AIKEN, SC 29803

WW-1498-19



# Wastewater Construction Permit Bureau of Water



|   |                      |
|---|----------------------|
| <b>PROJECT NAME:</b> SRS/SALT WASTE PROCESSING<br><b>FACILITY/PHASE 2</b> | <b>COUNTY:</b> AIKEN |
|---|----------------------|

PERMISSION IS HEREBY GRANTED TO: **US DEPT OF ENERGY SAVANNAH RIVER SITE**  
Srs  
Aiken SC 29808

in accordance with the construction plans, specifications, engineering report and the Construction Permit Application signed by James Somma, Registered Professional Engineer, S.C. Registration Number: .

**PROJECT DESCRIPTION:** Phase 2 construction of the SWPF which pre-treats salt waste from Tank Farm by extracting Cs, Sr, and actinides from the salt waste to render effluents acceptable for DWPF and the Saltstone Production Facility. See Attachment A for a list of the SWPF equipment. This list was submitted in SRS letter ESH-EPG-2008-00101 (dated July 28, 2008) and is in addition to the piping and appurtenances for this facility.


The effluent will be discharged to the Saltstone Production Facility (SPF) and the Defense Waste Processing Facility (DWPF) at a rate not to exceed 26000 gallons per day.

The effluent concentrations of those constituents the wastewater treatment system is designed to remove or reduce for wastewater transferred from Tank 50 to the SPF are contained in Construction Permit # 18,801-IW for the SPF. The solid waste from the SPF will be disposed in the Saltstone Disposal Facility (SDF) in accordance with Industrial Permit # 025500-1603.

**CONDITIONS:** See page 2.

In accepting this permit, the owner agrees to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection. This is a permit for construction only and does not constitute DHEC approval, temporary or otherwise, to place the system in operation. An Approval to Place in Operation is required and can be obtained following the completion of construction by contacting the AIKEN EQC OFFICE at 803-641-7670. Additional permits may be required prior to construction (e.g., Stormwater).

|                          |  |
|--------------------------|--|
| <b>PERMIT NUMBER:</b>    | 19219-IW   |
| <b>ISSUANCE DATE:</b>    | August 06, 2008  |
| <b>EXPIRATION DATES:</b> | August 06, 2010 (to begin construction)<br>September 30, 2011 (to obtain Approval to Place in Operation) |

  
Jeffrey P. deBessonnet, P.E., Director  
Water Facilities Permitting Division

### CONDITIONS

1. The permittee shall continue to maintain at the permitted facility a complete Operations and Maintenance (O&M) Manual for the SWPF. The manual shall be made available for on-site review during normal working hours. The manual shall contain operation and maintenance instructions for all equipment and appurtenances associated with the wastewater treatment system. The manual shall contain a general description of the treatment process(es), operating characteristics that will produce maximum treatment efficiency and corrective action to be taken should operating difficulties be encountered. The O&M Manual shall be developed no later than six (6) months after issuance of the Construction Permit.
2. The permittee shall provide for the performance of routine daily inspections of the SWPF when the systems are in operation. The inspections shall include, but are not limited to, areas which require a visual observation to determine efficient operations, and for which immediate corrective measures can be taken using the O&M Manual as a guide. All inspections shall be recorded and shall include the date, time, and name of the person making the inspection, corrective measures taken, and routine equipment maintenance, repair or replacement performed. The permittee shall maintain all records of inspections at the permitted facility and the records shall be made available for on-site review during normal working hours.
3. All wastewater treatment facilities and land application systems shall be closed out within one hundred eighty (180) days in accordance with applicable regulations, when the facility is closed or the effluent disposal permit is inactivated, terminated or revoked, unless determined by the Department that a greater time is necessary. As a prerequisite to closure, the Department must approve the closure plan.
4. If necessary, final as-built drawings shall be submitted to the Department when you submit a request to perform an inspection of the SWPF to obtain the Approval to Place into Operation.
5. This construction permit supercedes Construction Permit No. 19,164-IW and includes the waste transfer line segments.
6. The jumpers that will tie the SWPF in with the SPF and the DWPF will be covered in a future construction permit. There shall be no actual radioactive salt solution received from the HLW tanks for processing and transfer to the SPF and/or the DWPF until these jumpers have been installed and the Department has issued the Approval to Place into Operation.
7. NPDES Permit No. SC0000175 Part V.E.1 allows the disposal of "scavenger" wastewater. If the wastewater is not considered to be scavenger wastewater, a written request shall be submitted to the Department describing this wastewater and no discharge of this wastewater may be performed without written approval from the Department.
8. All waste oil and solid and hazardous waste shall be properly disposed of in accordance with the rules and regulations of the Bureau of Land and Waste Management.
9. The use of water, chemicals, and non-radioactive materials to support SWPF activities such as flushing, cleaning, start-up testing, and demonstrations to validate performance of components and/or systems is allowed as long as the jumpers in Item #6 have not been installed and the requirements in Item #7 have been met. Without the installation of these jumpers, there will be physical isolation from the High Level Waste (HLW) tanks in F-Area and H-Area and there is no ability to receive, process, or transfer actual salt solution from the HLW tanks.

Attachment A

**SWPF Equipment List (Drawing No. G-P1-J-00001)**

**PROCESS BUILDING – PROCESS EQUIPMENT**

| <b>Tank Number</b>              | <b>Tank Name</b>                           |
|---------------------------------|--|
| <b>Process Cell Area</b>        |  |
| TK-101                          | Alpha Sorption Tank-A (AST-A)              |
| TK-102                          | Filter Feed Tank-A (FFT-A)                 |
| TK-103                          | Cleaning Solution Dump Tank-A (CSDT-A)     |
| TK-104                          | Sludge Solids Receipt Tank (SSRT)          |
| TK-105                          | Wash Water Hold Tank (WWHT)                |
| TK-109                          | Salt Solution Feed Tank (SSFT)             |
| TK-121A/B/C                     | Back Pulse Tank                            |
| TK-123                          | Washing Filter Back Pulse Tank             |
| TK-127                          | Spent Oxalic Acid Storage Tank (SOAST)     |
| TK-205                          | Strip Effluent Hold Tank (SEHT)            |
| TK-208                          | Solvent Drain Tank                         |
| TK-235                          | Lab Drain Tank                             |
| TK-601                          | Alpha Sorption Drain Tank (ASDT)           |
| <b>Operating Deck</b>           |  |
| TK-122                          | Back Pulse Charge Tank-A                   |
| TK-128                          | AST-A Air Pulse Agitator Charge Tank       |
| TK-129                          | FFT-A Air Pulse Agitator Charge Tank       |
| TK-131                          | SSRT Air Pulse Agitator Charge Tank        |
| TK-132                          | SSFT Air Pulse Agitator Charge Tank        |
| TK-133                          | WWHT Air Pulse Agitator Charge Tank        |
| <b>CSSX Tank Cell</b>           |  |
| TK-202                          | Solvent Hold Tank (SHT)                    |
| TK-203                          | Strip Effluent Coalescer                   |
| TK-204                          | Caustic Wash Tank                          |
| TK-206                          | Ba-137 Decay Tank (BDT)                    |
| TK-211                          | Decontaminated Salt Solution Stilling Tank |
| TK-212                          | Strip Effluent Stilling Tank               |
| TK-215                          | Strip Effluent Pump Tank                   |
| TK-217                          | Solvent Strip Feed Tank                    |
| <b>CSSX Contactor Drop Area</b> |  |
| TK-201                          | Decon. Salt Solution Coalescer             |

| Tank Number                     | Tank Name                                |
|---------------------------------|--|
| <b>Cold Chemicals Area</b>      |  |
| TK-106                          | Oxalic Acid Feed Tank                    |
| TK-107                          | Filter Cleaning Caustic Tank             |
| TK-108                          | Caustic Dilution Feed Tank               |
| TK-301                          | Process Water Tank                       |
| TK-302                          | Caustic Receipt Tank                     |
| TK-303                          | Caustic Makeup Tank                      |
| TK-304                          | Nitric Acid Receipt Tank                 |
| TK-305                          | Process Water Pressure Tank              |
| TK-307                          | Nitric Acid Scrub Makeup Tank            |
| TK-311                          | MST Storage Tank                         |
| TK-312                          | DI Water Storage Tank                    |
| TK-313                          | Solvent Makeup Tank                      |
| TK-317                          | Neutralization Tank                      |
| TK-330                          | Argon Tank                               |
| <b>CSSX Contactor Area</b>      |  |
| EXT-201A-P                      | Solvent Extraction Contactors            |
| EXT-202A/B                      | Scrub Contactors                         |
| EXT-203A-P                      | Stripping Contactors                     |
| EXT-204A/B                      | Caustic Wash Contactors                  |
| <b>Process Filters</b>          |  |
| FLT-102A/B/C                    | Alpha Sorption Filters                   |
| FLT-104                         | Washing Filter                           |
| <b>Alpha Finishing Facility</b> |  |
| TK-207                          | DSS Hold Tank (DSSHT)                    |
| TK-220                          | Intermediate Storage Tank (IST)          |
| TK-221                          | Alpha Sorption Tank - B (AST-B)          |
| TK-222                          | Filter Feed Tank - B (FFT-B)             |
| TK-223                          | Cleaning Solution Dump Tank - B (CSDT-B) |
| TK-224                          | MST/Sludge Transfer Tank (MSTT)          |

## EQUIPMENT DESIGNATIONS

| <b>PUMPS</b>                             |   |
|--|---|
| <b>North ASP Pump and Valve Gallery</b>  |   |
| P-015A                                   | ASP Secondary Loop Pump Water Pump        |
| P-015B                                   | ASP Secondary Loop Pump Water Pump        |
| P-101A/B                                 | Alpha Sorption Tank-A Transfer Pumps      |
| P-102-1A/B/C                             | Filter Feed/Solids Trans Pumps            |
| P-102-2 A/B/C                            | Filter Recirculation Pumps                |
| P-104-1                                  | Washing FLT Feed/Sludge Solids Trans Pump |
| P-104-2                                  | Washing Filter Recirculation Pump         |
| P-110                                    | ASP Sump Trans Pump                       |
| <b>South ASP Pump and Valve Gallery</b>  |   |
| P-105A/B                                 | Wash Water Trans Pumps                    |
| P-208A/B                                 | Solvent Drain Tank Pumps                  |
| P-601A/B                                 | Alpha Sorption Drain TK Transfer Pumps    |
| <b>CSSX Pump and Valve Gallery</b>       |   |
| P-109A/B                                 | Salt Solution Feed Pumps                  |
| P-202A/B                                 | Solvent Feed Pumps                        |
| P-204A/B                                 | Caustic Wash Tank Pumps                   |
| P-205A/B                                 | Strip Effluent Trans Pumps                |
| P-206A/B                                 | Ba-137 Decay Tank Trans Pumps             |
| P-215A/B                                 | Strip Effluent Pump Tank Pumps            |
| P-217A/B                                 | Solvent Strip Feed Pumps                  |
| P-218                                    | CSSX Tank Cell Sump Transfer Pump         |
| <b>Sample Pump and Valve Gallery</b>     |   |
| SP-101                                   | Alpha Sorption Tank-A Sample Pump         |
| SP-102                                   | Filter Feed Tank-A Sample Pump            |
| SP-103                                   | Cleaning Solution Dump Tank-A Sample Pump |
| SP-104                                   | Sludge Solids Receipt Tank Sample Pump    |
| SP-105                                   | Wash Water Hold Tank Sample Pump          |
| SP-109                                   | Salt Solution Feed Tank Sample Pump       |
| SP-205                                   | Strip Effluent Hold Tank Sample Pump      |
| SP-235                                   | Lab Drain Tank Sample Pump                |
| <b>Material Staging and Storage Area</b> |   |
| P-601                                    | Low Level Drain Sump Transfer Pump        |

| <b>PUMPS (continued)</b>   |   |
|----------------------------|---|
| <b>Drum off/Decon Area</b> |   |
| P-605                      | Decon Area Sump Pump                    |
| <b>Cold Chemicals Area</b> |   |
| P-106                      | Oxalic Acid Transfer Pump               |
| P-107                      | Filter Cleaning Caustic Trans Pump      |
| P-108                      | Caustic Dilution Trans Pump             |
| P-300                      | Cold Chemicals Receiving Dock Sump Pump |
| P-301-1                    | Process Water Utility Pump              |
| P-301-2                    | Flush Pump                              |
| P-302                      | Caustic Trans Pump                      |
| P-303                      | Caustic Makeup Trans Pump               |
| P-304-1                    | Nitric Acid Metering Pump               |
| P-304-2                    | Neutralization Metering Pump            |
| P-305                      | Sodium Hypochlorite Addition Pump       |
| P-309A/B                   | Scrub Feed Pumps                        |
| P-310A/B                   | Strip Feed Pumps                        |
| P-311                      | MST Transfer Pump                       |
| P-311-1                    | MST Drum Pump                           |
| P-312-1                    | DI Water Trans Pump                     |
| P-312-2                    | Scrub Water Feed Pump                   |
| P-312-3A/B                 | Strip Water Feed Pumps                  |
| P-313                      | Solvent Makeup Trans Pump               |
| P-313-1                    | Solvent Drum Pump                       |
| P-317                      | Neutralization Tank Discharge Pump      |
| P-318                      | Caustic Sump Pump                       |
| P-319                      | Oxalic Acid Sump Pump                   |
| P-320                      | Neutralization Sump Pump                |
| P-321                      | Nitric Acid Sump Pump                   |
| P-322                      | Water Sump Pump                         |
| P-326                      | Pump Seal Make-up Water Supply Pump     |

| <b>AGITATORS</b>            |  |
|-----------------------------|--|
| AGT-107                     | Filter Cleaning Caustic Tank Agitator  |
| AGT-108                     | Caustic Dilution Feed Tank Agitator    |
| AGT-303                     | Caustic Makeup Tank Agitator           |
| AGT-307                     | Nitric Acid Scrub Makeup Tank Agitator |
| AGT-311                     | MST Storage Tank Agitator              |
| AGT-311-1                   | MST Drum Agitator                      |
| AGT-313                     | Solvent Makeup Tank Agitator           |
| <b>LABORATORY EQUIPMENT</b> |  |
| GB-001 – GB-012             | Glove Boxes                            |
| RH-001 – RH-017             | Radio Hoods                            |
| FH-001                      | Fume Hood                              |
| HC-001 – HC-004             | Hot Cell Windows                       |
| STS-101                     | Sample Transfer System                 |
| <b>ELECTRICAL SYSTEMS</b>   |  |
| ATS-203                     | Automatic Transfer Switch              |
| ATS-204                     | Automatic Transfer Switch              |
| ATS-205                     | Automatic Transfer Switch              |
| ATS-207                     | Automatic Transfer Switch              |
| ATS-208                     | Automatic Transfer Switch              |
| ATS-210                     | Automatic Transfer Switch              |
| MCC-203                     | Motor Control Center                   |
| MCC-204                     | Motor Control Center                   |
| MCC-205                     | Motor Control Center                   |
| MCC-206                     | Motor Control Center                   |
| SWGR-201                    | Switchgear                             |
| SWGR-202                    | Switchgear                             |
| SWGR-203                    | Switchgear                             |
| SWGR-204                    | Switchgear                             |
| USX-301                     | Uninterruptible Power Supply           |

| <b>INSTRUMENTATION</b>        |   |
|-------------------------------|---|
| ICP-001 – ICP-011             | Instrument Control Panel                      |
| ICP-014                       | Instrument Control Panel                      |
| IR-001 – IR-021               | Instrument Control Rack                       |
| <b>AIR HANDLING EQUIPMENT</b> |   |
| ACU-001                       | Wall Mounted Heat Pump                        |
| AHU-001 – AHU-005             | Air Handling Units                            |
| AHU-008 – AHU-009             | Air Handling Units                            |
| <b>Filters/Fans/Coils</b>     |   |
| CCL-401A/B                    | Process Vessel Vent Coolers                   |
| CCL-402A/B                    | Pulse Mixer Vent Coolers                      |
| FAN-401A/B                    | Process Vessel Vent Exhaust Fans              |
| FAN-402A/B                    | Pulse Mixer Vent Exhaust Fans                 |
| FAN-001                       | Exhaust Fan                                   |
| FAN-002                       | Exhaust Fan                                   |
| FAN-003                       | Exhaust Fan on Roof                           |
| FAN-004                       | Exhaust Fan on Roof                           |
| FAN-007                       | Exhaust Fan on Roof                           |
| FAN-009                       | Exhaust Fan on Roof                           |
| FAN-010                       | Exhaust Fan on Roof                           |
| FAN-013                       | Exhaust Fan on Roof                           |
| FAN-014                       | Exhaust Fan on Roof                           |
| FAN-015                       | Exhaust Fan on Roof                           |
| FLT-001 – FLT-004             | Exhaust Air HEPA Filters                      |
| FLT-009                       | Lab Exhaust Air HEPA Filter                   |
| FLT-010 – FLT-016             | Cell Inlet Air HEPA Filters                   |
| FLT-017                       | Lab Exhaust Air HEPA Filter                   |
| FLT-020                       | Hot Lab Intake Filter Above Suspended Ceiling |
| FLT-021                       | Hot Cell Exhaust Air HEPA Filter              |
| FLT-022                       | Hot Cell Exhaust Air HEPA Filter              |
| FLT-023 – FLT-034             | Glovebox Inlet Air HEPA Filters               |
| FLT-301                       | Process Water Cartridge Filter                |
| FLT-401A/B                    | Process Vessel Vent Filters                   |
| FLT-402A/B/C/D                | Pulse Mixer Vent Filters                      |
| HRC-001                       | Heat Recovery Coil                            |



**AIR HANDLING EQUIPMENT (continued)****Scrubbers**

|         |                   |
|---------|-------------------|
| SCB-001 | Scrubber          |
| SCB-002 | Scrubber          |
| SCB-003 | Hot Cell Scrubber |
| SCB-004 | Hot Cell Scrubber |

**Separators**

|         |  |
|---------|--|
| SEP-001 | Bldg Chilled Water Air Separator         |
| SEP-003 | Control Room Chilled Water Air Separator |
| SEP-005 | Process Chilled Water Air Separator      |
| SEP-007 | Heat Recovery Air Separator              |

**Pumps**

|          |                                    |
|----------|------------------------------------|
| P-001A/B | Bldg Chilled Water Supply Pumps    |
| P-003A/B | Control Room Chilled Water Pumps   |
| P-005A/B | Process Chilled Water Supply Pumps |
| P-007A/B | Heat Recovery Water Pumps          |

**Tanks**

|        |   |
|--------|---|
| TK-001 | Bldg Chilled Wtr Exp Tank               |
| TK-002 | Bldg Chilled Wtr Chem Feed Tank         |
| TK-003 | Control Room Chilled Wtr Exp Tank       |
| TK-004 | Control Room Chilled Wtr Chem Feed Tank |
| TK-005 | Process Chilled Wtr Exp Tank            |
| TK-006 | Process Chilled Wtr Chem Feed Tank      |
| TK-007 | Heat Recovery Bladder Exp Tank          |
| TK-008 | Heat Recovery Chemical Feed Tank        |
| TK-015 | Process Chilled Water Expansion Tank    |
| TK-016 | Chemical Bypass Feeder Tank             |

**Ventilators**

|         |                         |
|---------|-------------------------|
| VLR-001 | Gravity Roof Ventilator |
| VLR-002 | Gravity Roof Ventilator |

**MISCELLANEOUS ITEMS**

|             |                                     |
|-------------|-------------------------------------|
| BTR-001     | DW Pressure Booster System          |
| CMP-054     | Back Up Air Receiver Compressor     |
| DMST-401A/B | Process Vessel Vent Demisters       |
| DMST-402A/B | Pulse Mixer Vent Demisters          |
| DT-311      | MST Drum Tumbler                    |
| HTR-007     | Domestic Water Heater/Tank          |
| HTR-217A/B  | Solvent Heaters                     |
| HTR-310A/B  | Strip Feed Heaters                  |
| HTR-401A/B  | Process Vessel Vent Heaters         |
| HTR-402A/B  | Pulse Mixer Vent Heaters            |
| HX-015      | ASP Secondary Loop Cooler           |
| HX-102A/B/C | Filter Recirculation Coolers        |
| HX-104      | Washing Filter Recirculation Cooler |
| HX-201      | Salt Solution Feed Cooler           |
| HX-202A/B   | Solvent Feed Coolers                |
| IX-312      | DI Water Package Unit               |
| RMP-001     | Radiation Monitoring Panel          |
| SEP-015     | Process Chiller Water Air Separator |
| SI-210      | Steam Flash/Tank                    |
| VMP-01      | Vibration Monitor Panel             |



# Construction Permit Application Water/Wastewater Facilities

BUREAU OF WATER

DRP SUBMITTAL: No  Yes

SELECT ONE  Water Facilities  Wastewater Facilities  Water & Wastewater Facilities

I. Project Name: Salt Waste Processing Facility (SWPF) County: Aiken

II. Project Location (street names, etc.):  
Savannah River Site, Aiken, SC

III. Project Description(s): Water System:

Wastewater System:  
SWPF pre-treats salt waste from the Tank Farm by extracting cesium, strontium and actinides from the salt waste to render effluents acceptable for DWPF and the Saltstone Production Facility. This application addresses Phase 2 Construction.

Project Type (A-Z): Water:  Wastewater:  Z Other Project, not listed

IV. Initial Owner: [Time of Application] Name/Organization: USDOE/Owner  
Address: Building 730-B City: Aiken State: South Carolina Zip: 29808 Phone: (803) 952-6931

V. Final Owner: [After Construction] Name/Organization: USDOE / Owner  
Address: Building 730-B City: Aiken State: South Carolina Zip: 29808 Phone: (803) 952-6931

VI. Entity Responsible for Final Operation & Maintenance of System:  
Water System: Name: \_\_\_\_\_ Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_ Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Wastewater System: Name: USDOE/Owner Address: same as above  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_ Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

VII. Engineering Firm: Name: Parsons Corporation Address: 1080 Silver Bluff Rd.  
City: Aiken State: South Carolina Zip: 29803 Phone: (803) 643-7100 Fax: \_\_\_\_\_

VIII. Is this project: A) Part of a phased project? No  Yes . If Yes, Phase 2 of 2  
B) A revision to a previously permitted project? No  Yes . If Yes, Permit # \_\_\_\_\_  
Date Approved: \_\_\_\_\_ (MM/DD/YYYY) Project name (if different): \_\_\_\_\_  
C) Submitted based on a Schedule of Compliance or Order issued by DHEC? No  Yes . Order # \_\_\_\_\_  
D) Anticipating funding by the State Revolving Fund (SRF)? No  Yes .  
E) Crossing a water body? (e.g., river, creek) No  Yes . If Yes, Name of water body \_\_\_\_\_

IX. Are Standard Specifications approved by DHEC being used on this project? No  Yes . If Yes:  
Water: Date Approved: \_\_\_\_\_ (MM/DD/YYYY) Approved for whom: \_\_\_\_\_  
Wastewater: Date Approved: \_\_\_\_\_ (MM/DD/YYYY) Approved for whom: \_\_\_\_\_

X. Wastewater Systems: A) Type: Domestic  Process (Industrial)  Combined (Domestic & Process)   
B) Total average design flow of the project not to exceed 26,000 GPD  
C) Sewers or Pretreatment 1. Name of facility (e.g., POTW) treating the wastewater: \_\_\_\_\_  
2. NPDES/ND Number of facility in Item #1: \_\_\_\_\_  
Treatment Systems 3. Date Preliminary Engineering Report (PER) approved: \_\_\_\_\_ (MM/DD/YYYY)  
4. NPDES/ND application submitted? No  Yes . If Yes, Date: \_\_\_\_\_ (MM/DD/YYYY)  
Disposal Sites 5. Effluent Disposal Site (Description): \_\_\_\_\_  
6. Sludge Disposal Site (Description): \_\_\_\_\_

XI. Water Systems: Project located within city limits? No  Yes .  
Public water system providing water (Name & System ID No.): \_\_\_\_\_ No.: \_\_\_\_\_  
New water system (including master meter)? No  Yes . If Yes, System name: \_\_\_\_\_

RECEIVED  
APR 04 2008  
WATER FACILITIES  
PERMITTING DIVISION

**XII. Type of Submittal: Complete Section A (Standard) or Section B (Delegated Review Program - DRP).**

**A) Standard Submittal must include the following, where applicable:**

- 1. A transmittal letter outlining the submittal package.
- 2. The original construction permit application, properly completed, with three (3) copies.
- 3. Three (3) sets of signed and sealed plans and specifications. Specifications may be omitted if approved standard specifications are on file with DHEC.
- 4. One (1) additional overall plan sheet showing the proposed and existing (only in the area of proposed construction) water and wastewater lines (highlighted for identification) and their sizes.
- 5. Three (3) sets of the appropriate design calculations. **WASTEWATER:** Design flow (based on R.61-67, Appendix A), pump station calc's. and pump curve. **WATER:** Recent flow test from a location near the tie-on site, design calc's. indicating pressure maintained in the distribution system during max. instantaneous demand, fire flow and flushing velocities achieved. Number/types of service connections, well record form, pumping test results, etc.
- 6. Three (3) copies of a detailed 8½" x 11" location map, separate from the plans.
- 7. Three (3) copies of construction easements unless the project owner has the right of eminent domain.
- 8. A letter(s) from the entity supplying water and/or providing wastewater treatment stating their willingness and ability to serve the project, including pretreatment permits, if applicable. The letter should include the specific flow and, when applicable, the specific number of lots being served.
- 9. A letter(s) from the entity agreeing to be responsible for the O&M of the water and/or wastewater system.
- 10. Application fee enclosed \$ 700.00. (Refer to Instructions).
- 11. **WATER SYSTEMS:** a) A letter from the local government which has potable water planning authority over the area, if applicable, in which the project is located, stating project consistency with water supply service plan for area.  
b) For wells, four (4) copies of a wellhead protection area inventory.  
c) For new wells, a viability demonstration is required in accordance with Regulation 61-58.1.B.(4).

**Note:** Other approvals may include 208 and OCRM certification, and navigable waterway permitting.

**B) DRP submittal (treatment plants are not covered) must include the following, where applicable:**

- 1. A transmittal letter, signed by the professional engineer representing the DRP entity, noting this is a DRP submittal. The letter should state that the project has been reviewed and complies with R.61-58 and/or R.61-67.
- 2. The original construction permit application, properly completed, with two (2) copies.
- 3. Two (2) sets of the signed and sealed plans.
- 4. One (1) additional plan sheet with water and wastewater lines highlighted, as required under Sec. XII.A.4. above.
- 5. Two (2) sets of the appropriate design calculations. **WASTEWATER:** Same information as required under Section XII.A.5. above. **WATER:** Same information as required under Section XII.A.5. above.
- 6. Two (2) copies of a detailed 8½" x 11" location map, separate from the plans.
- 7. Two (2) copies of construction easements, unless the project owner has the right of eminent domain.
- 8. DHEC's Ocean and Coastal Resource Management certification (for projects in applicable counties).
- 9. DHEC's Water Quality permit or conditions for placement in navigable waters, and other Agency approvals.
- 10. **WASTEWATER SYSTEMS:** a) A letter of acceptance from the entity providing the treatment of the wastewater that includes the specific flow and, when applicable, the specific number of lots being accepted.  
b) A letter from the organization agreeing to be responsible for the O&M of the sewer system.  
c) The 208 Plan certification from the appropriate Council of Governments (designated 208 areas) or from DHEC on the non-designated 208 areas.
- 11. **WATER SYSTEMS:** A letter from the local government which has potable water planning authority, if applicable, in which the project is located, stating project consistency with water supply service plan for area.
- 12. Fee of \$75 for water and \$75 for sewer (\$150 if combined).

**Note:** The DRP entity should ensure that a copy of the final approved plans are returned to the design engineer.

**XIII.** Construction plans, material and construction specifications, the engineering report including supporting design data and calculations are herewith submitted and made a part of this application. I have placed my signature and seal on the engineering documents submitted, signifying that I accept responsibility for the design of this system, and have submitted a complete administrative package.

Engineer's Name (Printed): James Souma

Signature: [Signature]

S.C. Registration Number: 14718

**XIV.** Prior to final approval, I will submit a statement certifying that construction is complete and in accordance with the approved plans and specifications, to the best of my knowledge, information and belief. This certification will be based upon periodic observations of construction and a final inspection for design compliance by me or a representative of this office who is under my supervision.

Engineer's Name (Printed): James Souma

Signature: [Signature]

S.C. Registration Number: 14718

**XV.** I hereby make application for a permit to construct the project as described above. I have read this application and agree to the requirements and conditions and agree to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection.


Owner's Name (Printed): MARK R BREOR

Signature: [Signature]

Owner's Title: PROJECT MANAGER

Date: 3/27/08

(MM/DD/YYYY)



**From:** <rm.campbell@srs.gov>  
**To:** "Barry Mullinax" <MULLINBS@dhec.sc.gov>  
**Date:** 8/5/2008 9:30 AM  
**Subject:** Re: SWPF Equipment List

The equipment list is not OUO, and can be attached to a construction permit. You are correct that attachment 5 is the list of specifications acceptable by Mr. Somma.  
If you would call me, I'll pick up the package at your office.

Thanks,  
Ron  
803-952-7382 Direct Dial  
803-952-6316 Facsimile

"Barry Mullinax" <MULLINBS@dhec.sc.gov>  
08/04/2008 04:00 PM

To  
<rm.campbell@srs.gov>  
cc

Subject  
SWPF Equipment List

Is this equipment list OUO material? If yes, I need a redacted version to attach to the construction permit.

Also, in the June 26 letter, Somma included a letter stating that all the specs in attachment 5 were acceptable to him. I assume attachment 5 is the list of specs in the May 30 letter.

When we issue the permit, it will be a big package. I assume you want me to send it thru the regular mail or do you want to pick it up here?

**From:** Victor E. (Ted) Millings  
**To:** mullinbs  
**Date:** 7/30/2008 9:15 PM  
**Subject:** Re: SWPF Construction Permit

Not sure if Josh copied you on this e-mail.

Ted.

>>> Joshua C. Yon 07/30/08 11:01 AM >>>  
P.O. Box A  
Aiken, SC 29802

That sound right Ted?

I didn't catch anything that Ted didn't catch, and it looks good to me Barry.  
Oh and just to let you know, Ted and I went out to look at the Stannous Chloride System at the M-1 Air Stripper last week and I issued the APO for it yesterday. Let me know if you need anything else.  
I'm curious about the scavenger wastewater too.

Josh

>>> Victor E. (Ted) Millings 7/30/2008 8:43 AM >>>  
Barry,

I'm out of the office this morning, so I thought I would send my comments now. Josh will send his separately soon.

Cover Letter:

1. Something about the SRS address looks weird - I think DOE mail goes to a 29802 address and a PO Box or something - Josh help me out with this.
2. Stray comma after "PE" in your signature block

Permit:

1. Address seems odd (see comment 1 above).
2. Extra space before "in accordance" just after the DOE address.
3. In the project description, please specify which Tank Farm.
4. In the paragraph that starts "See Attachment A...", I don't think a comma is needed after "July 28, 2008".
5. Typo in first condition - "The manual shall contain a genera description..." Should be "general description".
6. Period is needed after sentence in condition 4.
7. In condition 6, has the acronym HLW been spelled out before using the acronym?
8. Period is needed after last sentence in condition 7.

Not a comment but more of a question outside of reviewing the permit - I know I should know this, but what is scavenger wastewater?

Ted.

>>> Barry Mullinax 07/29/08 3:10 PM >>>

I am about ready to issue the construction permit for the SWPF. It will include the waste transfer segment lines put in by an earlier permit. I just wanted you two to look at the draft and see if you want me to add something or change something. Note that I will be attaching a list of equipment that SRS put together for the SWPF. Including a list of equipment will be helpful when we get into the closure phase.

**SC DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL  
 And PARSONS INFRASTRUCTURE MEETING  
 CONSTRUCTION PERMIT APPLICATION - PHASE II (BUILDING)  
 2600 Bull Street, Columbia, SC - April 24, 2008**

**ATTENDEES**

| Name:                  | Company or Agency: | Signature:               |
|------------------------|--------------------|--------------------------|
| Barry S. Mullinax      | SC DHEC            | <i>Barry Mullinax</i>    |
| Crystal D. Rippy       | SC DHEC            |                          |
| William B. Brasel      | Parsons            | <i>Bill Brasel</i>       |
| Richard H. Gurske      | Parsons            | <i>Richard H. Gurske</i> |
| Arlis T. Reynolds, Jr. | Parsons            |                          |
| David R. Faubert       | DOE-SR             |                          |
| David F. Hoel          | DOE-SR             | <i>David F. Hoel</i>     |
| Phillip A. Polk        | DOE-SR             |                          |
| Larry E. Zalants       | DOE-SR             | <i>Larry Zalants</i>     |
| Keith D. Harp          | WSRC               | <i>Keith D. Harp</i>     |
| Ronald Campbell        | WSRC               | <i>Ronald Campbell</i>   |
|                        |                    |                          |
|                        |                    |                          |
|                        |                    |                          |



Department of Energy  
Savannah River Operations Office  
P.O. Box A  
Aiken, South Carolina 29802

**RECEIVED**

MAY 19 2008

MAY 15 2008

WATER FACILITIES  
PERMITTING DIVISION

Crystal Rippy, Manager  
Industrial Waste Water Permitting Section  
Water Facilities Permitting Division  
South Carolina Department of Health and  
Environmental Control

Subject: Clarification of Adequacy to Operate the Salt Waste Processing Facility (SWPF) and  
Delegation of Signature Authority to Parsons Regarding Waste Water Permitting

Reference: Letter, Rippy (SCDHEC) to Somma (Parsons) April 4, 2008, SCDHEC Application  
Tracking #818672

Dear Ms. Rippy:

The U.S. Department of Energy (DOE) wishes to respond to two comments contained in the above referenced letter. For comment #5, "*A letter of acceptance from the owner stating that they have adequate equipment and personnel to operate and maintain the proposed sewer system must be submitted.*" The Department of Energy and its operating contractor(s) will have adequate equipment and personnel to operate and maintain the proposed Salt Waste Processing Facility (SWPF).

For comment #7, "*The person who signed as owner does not appear to meet the requirements of the application instructions in Part XV. Please resubmit a revised permit application with the appropriate owner's signature (one original and 3 copies) or submit a letter describing how this person who signed meets these requirements.*" Pursuant to SC Code Ann. Reg. 61-9.122.22(b), please be advised that Parsons Infrastructure and Technology Group, Inc., the entity responsible for the overall construction and operations of the SWPF, including environmental matters, is hereby designated as the duly authorized representative of the DOE in connection with waste water permitting matters. This means those Parsons individuals (and their respective designees) who occupy the position of Project Manager may sign all applications and reports required for such permits. Also, the enclosure confirms that DOE recognizes Mr. Mark R. Breor as the Project Manager, replacing Mr. David B. Amerine.

Questions concerning this delegation of authority may be directed to Mary-Ellen Noone, Attorney, Advisor in the Office of Chief Counsel at 803-952-8414. Questions concerning technical matters may be addressed to Larry Zalants, SWPF Operations, at 803-641-8905.

Sincerely,

Jeffrey M. Allison  
Manager

SWPF-08-266

Enclosure: Amendment of Modification  
of Contract #M048



Enclosure:  
 SUBJECT: Amendment of Modification of Contract  
 #M048  
 Dated: January 17, 2008

|  |                                    |  |                                |  |
|--|------------------------------------|--|--------------------------------|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT   |                                    | 1. CONTRACT ID CODE  | PAGE OF PAGES<br>1   2         |  |
| 2. AMENDMENT/MODIFICATION NO.<br>M048  | 3. EFFECTIVE DATE<br>See Block 16C | 4. REQUISITION/PURCHASE REQ. NO.                               | 5. PROJECT NO. (if applicable) |  |
| 6. ISSUED BY<br>U. S. Department of Energy<br>Savannah River Operations Office<br>P.O. Box A<br>Aiken, SC 29802  | CODE                               | 7. ADMINISTERED BY (if other than item 6)                      | CODE                           |  |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and ZIP Code)<br>Parsons Infrastructure and Technology Group, Inc.<br>1000 Silver Bluff Road<br>Aiken, SC 29803 |                                    | 9A. AMENDMENT OF SOLICITATION NO.                              |                                |  |
|  |                                    | 9B. DATED (See Item 11)  |                                |  |
|  |                                    | X 10A. MODIFICATION OF CONTRACT/ORDER NO.<br>DE-AC00-028R22210 |                                |  |
|  |                                    | 10B. DATED (See Item 13)<br>8/17/02                            |                                |  |
| CODE   | FACILITY CODE                      |  |                                |  |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)  
N/A


13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

|   |
|---|
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.  |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:  |
| D. OTHER (Specify type of modification and authority)<br>Parsons' Letter #06-700-07644 (Replacement of Key Personnel)   |
| X E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.                                      |

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

- A. The purpose of this modification is to revise Section J, Attachment F – Key Personnel. Mr. David B. Amerine is replaced by Mr. Mark R. Bror as the Project Manager. (See page 2 hereof for the revised Key Personnel List.)
- B. All other terms and conditions of the contract remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

|   |                  |   |                             |
|---|------------------|---|-----------------------------|
| 15A. NAME AND TITLE OF SIGNER (Type or print) |                  | 15A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)<br>Charlene Smith, Contracting Officer                             |                             |
| 15B. CONTRACTOR/OFFEROR                       | 15C. DATE SIGNED | 15B. UNITED STATES OF AMERICA   | 15C. DATE SIGNED<br>1/17/08 |
| (Signature of person authorized to sign)      |                  | BY <br>(Signature of Contracting Officer) |                             |

**SECTION J – LIST OF ATTACHMENTS**

**ATTACHMENT F**

**KEY PERSONNEL**

| <b>Name</b>         | <b>Position</b>          |
|---------------------|--------------------------|
| Mark R. Breor       | Project Manager          |
| Alice C. Doswell    | ESH&Q Manager            |
| Romi W. Puckett     | Project Controls Manager |
| Dan Jensen          | Technology Manager       |
| Phil Dovaston       | Processing Engineering   |
| James C. Somma      | Engineering Manager      |
| Charles E. Swain    | Construction Manager     |
| Alois (Skip) Singer | Commissioning Manager    |
| John Kasper         | EPC Manager              |
| Paul J. Whittingham | Contracts Manager        |

BOARD:  
Paul C. Aughtry, III  
Chairman  
Edwin H. Cooper, III  
Vice Chairman  
Steven G. Kisner  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment*

BOARD:  
Henry C. Scott  
M. David Mitchell, MD  
Glenn A. McCall  
Coleman F. Buckhouse, MD

## BUREAU OF WATER

April 04, 2008

JAMES SOMMA  
PARSONS INFRASTRUCTURE AND TECHNOLOGY GROUP INC  
1080 SILVER BLUFF RD  
AIKEN SC 29803

Re: **SRS/SALT WASTE PROCESSING FACILITY/PHASE 2**  
Aiken County  
Application Tracking # 818672

Dear James Somma:

The Industrial Wastewater Permitting section received an engineering submittal on the above project on 04/04/2008. In accordance with R.61-30 we have reviewed your application for completeness. Based on our review, your project application package is administratively incomplete. For this reason, your project will not be in line for a technical review until you satisfy the deficiencies noted below. As a courtesy, we have logged in your project and will keep it here pending your complete response. To complete your application package, please provide the following items:

1. Three (3) copies of pump station calculations and pump curves need to be submitted.
2. Three (3) copies of flow calculations must be submitted justifying the sizing of the lines and/or equipment.
3. Three (3) copies of a detailed 8 ½" by 11" location map must be submitted.
4. Three (3) sets of signed and sealed specifications must be submitted. Specifications should include all materials of construction (e.g. PVC pipe or stainless steel tanks) and sizes of equipment.
5. A letter of acceptance from the owner stating that they have adequate equipment and personnel to operate and maintain the proposed sewer system must be submitted.
6. A SC registered PE must sign and seal all plans and specifications and the Certificate of Authorization (COA) from the engineering firm must also be affixed near the PE seal. Please resubmit these documents with the appropriate seals. Please note: If the plans and specifications are bound (a staple is sufficient for this purpose), then it is only necessary to place

Letter to Mr. Somma  
April 4, 2008  
Page 2 of 2

the COA and PE seal/signature on the front of the bound document. If the plans and specifications are not bound, then each page must include the COA and the PE seal/signature.


7. The person who signed as owner does not appear to meet the requirements of the application instructions in Part XV. Please resubmit a revised permit application with the appropriate owner's signature (one original and 3 copies) or submit a letter describing how the person who signed meets these requirements.

Please return the above noted items as soon as possible. Failure to submit these items will result in significant delays in the review process.

Also, please note that any land clearing activity that is being performed in relation to this project must be permitted under the State Sediment and Erosion Control Program. For more information contact Ann Clark at (803) 898-4028.

If you have any questions, please do not hesitate to contact this office at 803-898-3964.

Sincerely,



Crystal Rippy, Manager  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division



South Carolina Department of Health  
and Environmental Control

**Environmental Quality Control**

**Wastewater Application Fee**  
2600 Bull Street  
Columbia, SC 29201

US DEPT OF ENERGY SAVANNAH RIVER SITE  
SC HWY 19 & 781  
AIKEN SC 29802

Invoice Date: 04/04/2008  
Invoice Number: QY18570-2  
Invoice Amount: \$700.00  
Program ID: 818672

Department Name: BOW - IND WW PERMITTING  
Department Contact: CRYSTAL RIPPY  
Department Phone: 803-898-3964

| Qty          | Description     | Unit   | Extended        |
|--------------|-----------------|--------|-----------------|
| 1.00         | TS < 1MGD - New | 700.00 | 700.00          |
| <b>Total</b> |                 |        | <b>\$700.00</b> |

South Carolina Department of Health and Environmental Control

Facility Name: US DEPT OF ENERGY SAVANNAH RIVER  
Program ID: 818672  
Invoice Number: QY18570-2 Amount Due: \$700.00

|                        |
|------------------------|
| Amount Remitted:<br>\$ |
|------------------------|

To ensure proper credit, please return this portion of the invoice with your payment to the address below or you may go to our agency's website: [www.dhec.sc.gov](http://www.dhec.sc.gov) then click on **INVOICE PAYMENT** under **quick links** or use the reverse side of this form for credit card payments. Please include the invoice number on your remittance. **Payment due upon receipt. Past Due 30 days from invoice date. Change of address and credit card payment forms are on the reverse side.**

SC DHEC  
Attn: Bureau of Financial Management  
PO Box 100103  
Columbia, SC 29202-3103

JPMorgan Chase Bank, N.A.  
DISBURSEMENT ACCOUNT  
SYRACUSE, NEW YORK

**PARSONS**  
100 WEST WALNUT STREET  
PASADENA, CALIFORNIA 91221

**RECEIVED**  
APR 04 2008

50-937  
213

VOID AFTER 90 DAYS

| CHECK NUMBER | DATE    |
|--------------|---------|
| 0117604      | 3/13/08 |

| AMOUNT   |
|----------|
| \$700.00 |

PAY Seven Hundred DOLLARS and Zero CENTS

WATER FACILITIES  
PERMITTING DIVISION

JPMorgan Chase Bank, N.A.  
Syracuse, NY

TO THE ORDER OF  
SC DHEC  
2600 BULL STREET  
COLUMBIA, SC 29201-1708

QY18570-2

BY   
AUTHORIZED SIGNATURE

⑈0117604⑈ ⑆021309379⑆ 601868367⑈

**REMITTANCE ADVICE**

| INVOICE NO | DATE    | VOUCHER NO | DESCRIPTION | AMOUNT | DISCOUNT | NET AMOUNT   |
|------------|---------|------------|-------------|--------|----------|--------------|
| PHASE2     | 3/10/08 | 30802392   |             | 700.00 |          | 700.00       |
| CHECK NO   | DATE    | VENDOR NO  | VENDOR NAME |        |          | TOTAL AMOUNT |
| 0117604    | 3/13/08 | JW073      | SC DHEC     |        |          | 700.00       |

100 WEST WALNUT STREET

PLEASE DETACH THIS VOUCHER BEFORE DEPOSITING CHECK



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment.*

## MEMORANDUM

April 04, 2008

**TO:** Joshua C Yon  
Region 5  
Aiken EQC Office

**FROM:** Crystal Rippy  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division

**RE:** Construction Permit Application  
SRS/SALT WASTE PROCESSING FACILITY/PHASE 2  
Aiken County

Are there any problems or comments which you have on the referenced project? Copies of the application and location map are enclosed.

Please return any comments that you may have by: April 14, 2008. An e-mail response is suitable if you prefer. If you have no comments, please just note so. Thanks.

COMMENTS:



July 28, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division of the Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Re: Construction Permit No.: 19,164-IW / Salt Waste Processing Facility – Phase II (Building)  
Sixth Supplemental Industrial Wastewater Treatment Facility Construction Permit Application Information  
Ref.: Communications of July 21, 2008 with B. S. Mullinax regarding List of Equipment and Flow Rate Clarification

Dear Mr. Mullinax:

As we discussed by telephone and email on 21 July, please find (a) the original and two sets of the equipment list and (b) revised page 36 of 39 to the Engineering Report (Q-PER-J-00002, Rev. 2) for the referenced construction project.

Please substitute the enclosed Engineering Report page for the one currently in your files. This page clarifies the average production flow rate of 26,000 gallons per day. This information is considered Official Use Only which requires U.S. Department of Energy review prior to public disclosure. A redacted version of these documents, if needed, will be provided at the time request is made for the operating permit.

Please let me know if you need any additional information to assist you in the issuance of a construction permit at your earliest opportunity. If you have any questions, do not hesitate to contact me at 803-952-7382.

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

RMC/r  
Enc.

- c: M. P. Prater, 730-B
  - G. S. Hoover, 730-B
  - D. F. Hoel, 730-B\*
  - J. C. Somma, P.E., Parsons
  - V. E. Millings III, SCDHEC Region 5 EQC\*
  - J. C. Yon, SCDHEC Region 5 EQC\*
  - J. R. Hughes, SCDHEC Region 5 EQC\*
  - M. D. Sherritt, SCDHEC\*
- \* - Copy of Transmittal Letter Only

**WASHINGTON SAVANNAH RIVER COMPANY**



## SWPF Equipment List (Drawing No. G-P1-J-00001)

### PROCESS BUILDING – PROCESS EQUIPMENT

| Tank Number                     | Tank Name                                  |
|---------------------------------|--|
| <b>Process Cell Area</b>        |  |
| TK-101                          | Alpha Sorption Tank-A (AST-A)              |
| TK-102                          | Filter Feed Tank-A (FFT-A)                 |
| TK-103                          | Cleaning Solution Dump Tank-A (CSDT-A)     |
| TK-104                          | Sludge Solids Receipt Tank (SSRT)          |
| TK-105                          | Wash Water Hold Tank (WWHT)                |
| TK-109                          | Salt Solution Feed Tank (SSFT)             |
| TK-121A/B/C                     | Back Pulse Tank                            |
| TK-123                          | Washing Filter Back Pulse Tank             |
| TK-127                          | Spent Oxalic Acid Storage Tank (SOAST)     |
| TK-205                          | Strip Effluent Hold Tank (SEHT)            |
| TK-208                          | Solvent Drain Tank                         |
| TK-235                          | Lab Drain Tank                             |
| TK-601                          | Alpha Sorption Drain Tank (ASDT)           |
| <b>Operating Deck</b>           |  |
| TK-122                          | Back Pulse Charge Tank-A                   |
| TK-128                          | AST-A Air Pulse Agitator Charge Tank       |
| TK-129                          | FFT-A Air Pulse Agitator Charge Tank       |
| TK-131                          | SSRT Air Pulse Agitator Charge Tank        |
| TK-132                          | SSFT Air Pulse Agitator Charge Tank        |
| TK-133                          | WWHT Air Pulse Agitator Charge Tank        |
| <b>CSSX Tank Cell</b>           |  |
| TK-202                          | Solvent Hold Tank (SHT)                    |
| TK-203                          | Strip Effluent Coalescer                   |
| TK-204                          | Caustic Wash Tank                          |
| TK-206                          | Ba-137 Decay Tank (BDT)                    |
| TK-211                          | Decontaminated Salt Solution Stilling Tank |
| TK-212                          | Strip Effluent Stilling Tank               |
| TK-215                          | Strip Effluent Pump Tank                   |
| TK-217                          | Solvent Strip Feed Tank                    |
| <b>CSSX Contactor Drop Area</b> |  |
| TK-201                          | Decon. Salt Solution Coalescer             |

| <b>Tank Number</b>              | <b>Tank Name</b>                         |
|---------------------------------|--|
| <b>Cold Chemicals Area</b>      |  |
| TK-106                          | Oxalic Acid Feed Tank                    |
| TK-107                          | Filter Cleaning Caustic Tank             |
| TK-108                          | Caustic Dilution Feed Tank               |
| TK-301                          | Process Water Tank                       |
| TK-302                          | Caustic Receipt Tank                     |
| TK-303                          | Caustic Makeup Tank                      |
| TK-304                          | Nitric Acid Receipt Tank                 |
| TK-305                          | Process Water Pressure Tank              |
| TK-307                          | Nitric Acid Scrub Makeup Tank            |
| TK-311                          | MST Storage Tank                         |
| TK-312                          | DI Water Storage Tank                    |
| TK-313                          | Solvent Makeup Tank                      |
| TK-317                          | Neutralization Tank                      |
| TK-330                          | Argon Tank                               |
| <b>CSSX Contactor Area</b>      |  |
| EXT-201A-P                      | Solvent Extraction Contactors            |
| EXT-202A/B                      | Scrub Contactors                         |
| EXT-203A-P                      | Stripping Contactors                     |
| EXT-204A/B                      | Caustic Wash Contactors                  |
| <b>Process Filters</b>          |  |
| FLT-102A/B/C                    | Alpha Sorption Filters                   |
| FLT-104                         | Washing Filter                           |
| <b>Alpha Finishing Facility</b> |  |
| TK-207                          | DSS Hold Tank (DSSHT)                    |
| TK-220                          | Intermediate Storage Tank (IST)          |
| TK-221                          | Alpha Sorption Tank - B (AST-B)          |
| TK-222                          | Filter Feed Tank - B (FFT-B)             |
| TK-223                          | Cleaning Solution Dump Tank - B (CSDT-B) |
| TK-224                          | MST/Sludge Transfer Tank (MSTT)          |

## EQUIPMENT DESIGNATIONS

| <b>PUMPS</b>                             |   |
|--|---|
| <b>North ASP Pump and Valve Gallery</b>  |   |
| P-015A                                   | ASP Secondary Loop Pump Water Pump        |
| P-015B                                   | ASP Secondary Loop Pump Water Pump        |
| P-101A/B                                 | Alpha Sorption Tank-A Transfer Pumps      |
| P-102-1A/B/C                             | Filter Feed/Solids Trans Pumps            |
| P-102-2 A/B/C                            | Filter Recirculation Pumps                |
| P-104-1                                  | Washing FLT Feed/Sludge Solids Trans Pump |
| P-104-2                                  | Washing Filter Recirculation Pump         |
| P-110                                    | ASP Sump Trans Pump                       |
| <b>South ASP Pump and Valve Gallery</b>  |   |
| P-105A/B                                 | Wash Water Trans Pumps                    |
| P-208A/B                                 | Solvent Drain Tank Pumps                  |
| P-601A/B                                 | Alpha Sorption Drain TK Transfer Pumps    |
| <b>CSSX Pump and Valve Gallery</b>       |   |
| P-109A/B                                 | Salt Solution Feed Pumps                  |
| P-202A/B                                 | Solvent Feed Pumps                        |
| P-204A/B                                 | Caustic Wash Tank Pumps                   |
| P-205A/B                                 | Strip Effluent Trans Pumps                |
| P-206A/B                                 | Ba-137 Decay Tank Trans Pumps             |
| P-215A/B                                 | Strip Effluent Pump Tank Pumps            |
| P-217A/B                                 | Solvent Strip Feed Pumps                  |
| P-218                                    | CSSX Tank Cell Sump Transfer Pump         |
| <b>Sample Pump and Valve Gallery</b>     |   |
| SP-101                                   | Alpha Sorption Tank-A Sample Pump         |
| SP-102                                   | Filter Feed Tank-A Sample Pump            |
| SP-103                                   | Cleaning Solution Dump Tank-A Sample Pump |
| SP-104                                   | Sludge Solids Receipt Tank Sample Pump    |
| SP-105                                   | Wash Water Hold Tank Sample Pump          |
| SP-109                                   | Salt Solution Feed Tank Sample Pump       |
| SP-205                                   | Strip Effluent Hold Tank Sample Pump      |
| SP-235                                   | Lab Drain Tank Sample Pump                |
| <b>Material Staging and Storage Area</b> |   |
| P-601                                    | Low Level Drain Sump Transfer Pump        |

| <b>PUMPS (continued)</b>   |   |
|----------------------------|---|
| <b>Drum off/Decon Area</b> |   |
| P-605                      | Decon Area Sump Pump                    |
| <b>Cold Chemicals Area</b> |   |
| P-106                      | Oxalic Acid Transfer Pump               |
| P-107                      | Filter Cleaning Caustic Trans Pump      |
| P-108                      | Caustic Dilution Trans Pump             |
| P-300                      | Cold Chemicals Receiving Dock Sump Pump |
| P-301-1                    | Process Water Utility Pump              |
| P-301-2                    | Flush Pump                              |
| P-302                      | Caustic Trans Pump                      |
| P-303                      | Caustic Makeup Trans Pump               |
| P-304-1                    | Nitric Acid Metering Pump               |
| P-304-2                    | Neutralization Metering Pump            |
| P-305                      | Sodium Hypochlorite Addition Pump       |
| P-309A/B                   | Scrub Feed Pumps                        |
| P-310A/B                   | Strip Feed Pumps                        |
| P-311                      | MST Transfer Pump                       |
| P-311-1                    | MST Drum Pump                           |
| P-312-1                    | DI Water Trans Pump                     |
| P-312-2                    | Scrub Water Feed Pump                   |
| P-312-3A/B                 | Strip Water Feed Pumps                  |
| P-313                      | Solvent Makeup Trans Pump               |
| P-313-1                    | Solvent Drum Pump                       |
| P-317                      | Neutralization Tank Discharge Pump      |
| P-318                      | Caustic Sump Pump                       |
| P-319                      | Oxalic Acid Sump Pump                   |
| P-320                      | Neutralization Sump Pump                |
| P-321                      | Nitric Acid Sump Pump                   |
| P-322                      | Water Sump Pump                         |
| P-326                      | Pump Seal Make-up Water Supply Pump     |

| <b>AGITATORS</b>            |  |
|-----------------------------|--|
| AGT-107                     | Filter Cleaning Caustic Tank Agitator  |
| AGT-108                     | Caustic Dilution Feed Tank Agitator    |
| AGT-303                     | Caustic Makeup Tank Agitator           |
| AGT-307                     | Nitric Acid Scrub Makeup Tank Agitator |
| AGT-311                     | MST Storage Tank Agitator              |
| AGT-311-1                   | MST Drum Agitator                      |
| AGT-313                     | Solvent Makeup Tank Agitator           |
| <b>LABORATORY EQUIPMENT</b> |  |
| GB-001 – GB-012             | Glove Boxes                            |
| RH-001 – RH-017             | Radio Hoods                            |
| FH-001                      | Fume Hood                              |
| HC-001 – HC-004             | Hot Cell Windows                       |
| STS-101                     | Sample Transfer System                 |
| <b>ELECTRICAL SYSTEMS</b>   |  |
| ATS-203                     | Automatic Transfer Switch              |
| ATS-204                     | Automatic Transfer Switch              |
| ATS-205                     | Automatic Transfer Switch              |
| ATS-207                     | Automatic Transfer Switch              |
| ATS-208                     | Automatic Transfer Switch              |
| ATS-210                     | Automatic Transfer Switch              |
| MCC-203                     | Motor Control Center                   |
| MCC-204                     | Motor Control Center                   |
| MCC-205                     | Motor Control Center                   |
| MCC-206                     | Motor Control Center                   |
| SWGR-201                    | Switchgear                             |
| SWGR-202                    | Switchgear                             |
| SWGR-203                    | Switchgear                             |
| SWGR-204                    | Switchgear                             |
| USX-301                     | Uninterruptible Power Supply           |

| <b>INSTRUMENTATION</b>        |   |
|-------------------------------|---|
| ICP-001 – ICP-011             | Instrument Control Panel                      |
| ICP-014                       | Instrument Control Panel                      |
| IR-001 – IR-021               | Instrument Control Rack                       |
| <b>AIR HANDLING EQUIPMENT</b> |   |
| ACU-001                       | Wall Mounted Heat Pump                        |
| AHU-001 – AHU-005             | Air Handling Units                            |
| AHU-008 – AHU-009             | Air Handling Units                            |
| <b>Filters/Fans/Coils</b>     |   |
| CCL-401A/B                    | Process Vessel Vent Coolers                   |
| CCL-402A/B                    | Pulse Mixer Vent Coolers                      |
| FAN-401A/B                    | Process Vessel Vent Exhaust Fans              |
| FAN-402A/B                    | Pulse Mixer Vent Exhaust Fans                 |
| FAN-001                       | Exhaust Fan                                   |
| FAN-002                       | Exhaust Fan                                   |
| FAN-003                       | Exhaust Fan on Roof                           |
| FAN-004                       | Exhaust Fan on Roof                           |
| FAN-007                       | Exhaust Fan on Roof                           |
| FAN-009                       | Exhaust Fan on Roof                           |
| FAN-010                       | Exhaust Fan on Roof                           |
| FAN-013                       | Exhaust Fan on Roof                           |
| FAN-014                       | Exhaust Fan on Roof                           |
| FAN-015                       | Exhaust Fan on Roof                           |
| FLT-001 – FLT-004             | Exhaust Air HEPA Filters                      |
| FLT-009                       | Lab Exhaust Air HEPA Filter                   |
| FLT-010 – FLT-016             | Cell Inlet Air HEPA Filters                   |
| FLT-017                       | Lab Exhaust Air HEPA Filter                   |
| FLT-020                       | Hot Lab Intake Filter Above Suspended Ceiling |
| FLT-021                       | Hot Cell Exhaust Air HEPA Filter              |
| FLT-022                       | Hot Cell Exhaust Air HEPA Filter              |
| FLT-023 – FLT-034             | Glovebox Inlet Air HEPA Filters               |
| FLT-301                       | Process Water Cartridge Filter                |
| FLT-401A/B                    | Process Vessel Vent Filters                   |
| FLT-402A/B/C/D                | Pulse Mixer Vent Filters                      |
| HRC-001                       | Heat Recovery Coil                            |

**AIR HANDLING EQUIPMENT (continued)**

| <b>Scrubbers</b>   |  |
|--------------------|--|
| SCB-001            | Scrubber                                 |
| SCB-002            | Scrubber                                 |
| SCB-003            | Hot Cell Scrubber                        |
| SCB-004            | Hot Cell Scrubber                        |
| <b>Separators</b>  |  |
| SEP-001            | Bldg Chilled Water Air Separator         |
| SEP-003            | Control Room Chilled Water Air Separator |
| SEP-005            | Process Chilled Water Air Separator      |
| SEP-007            | Heat Recovery Air Separator              |
| <b>Pumps</b>       |  |
| P-001A/B           | Bldg Chilled Water Supply Pumps          |
| P-003A/B           | Control Room Chilled Water Pumps         |
| P-005A/B           | Process Chilled Water Supply Pumps       |
| P-007A/B           | Heat Recovery Water Pumps                |
| <b>Tanks</b>       |  |
| TK-001             | Bldg Chilled Wtr Exp Tank                |
| TK-002             | Bldg Chilled Wtr Chem Feed Tank          |
| TK-003             | Control Room Chilled Wtr Exp Tank        |
| TK-004             | Control Room Chilled Wtr Chem Feed Tank  |
| TK-005             | Process Chilled Wtr Exp Tank             |
| TK-006             | Process Chilled Wtr Chem Feed Tank       |
| TK-007             | Heat Recovery Bladder Exp Tank           |
| TK-008             | Heat Recovery Chemical Feed Tank         |
| TK-015             | Process Chilled Water Expansion Tank     |
| TK-016             | Chemical Bypass Feeder Tank              |
| <b>Ventilators</b> |  |
| VLR-001            | Gravity Roof Ventilator                  |
| VLR-002            | Gravity Roof Ventilator                  |

**MISCELLANEOUS ITEMS**

|             |                                     |
|-------------|-------------------------------------|
| BTR-001     | DW Pressure Booster System          |
| CMP-054     | Back Up Air Receiver Compressor     |
| DMST-401A/B | Process Vessel Vent Demisters       |
| DMST-402A/B | Pulse Mixer Vent Demisters          |
| DT-311      | MST Drum Tumbler                    |
| HTR-007     | Domestic Water Heater/Tank          |
| HTR-217A/B  | Solvent Heaters                     |
| HTR-310A/B  | Strip Feed Heaters                  |
| HTR-401A/B  | Process Vessel Vent Heaters         |
| HTR-402A/B  | Pulse Mixer Vent Heaters            |
| HX-015      | ASP Secondary Loop Cooler           |
| HX-102A/B/C | Filter Recirculation Coolers        |
| HX-104      | Washing Filter Recirculation Cooler |
| HX-201      | Salt Solution Feed Cooler           |
| HX-202A/B   | Solvent Feed Coolers                |
| IX-312      | DI Water Package Unit               |
| RMP-001     | Radiation Monitoring Panel          |
| SEP-015     | Process Chiller Water Air Separator |
| SI-210      | Steam Flash/Tank                    |
| VMP-01      | Vibration Monitor Panel             |





**RECEIVED**  
JUL 18 2008

WATER FACILITIES  
PERMITTING DIVISION ESH-EPG-2008-00093

July 17, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division of the Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Re: Construction Permit No.: 19,164-IW / Salt Waste Processing Facility – Phase II (Building)  
Fifth Supplemental Industrial Wastewater Treatment Facility Construction Permit Application Information  
Ref.: Email from B. S. Mullinax, P.E., dated July 16, 2008 regarding Thermal Insulation Specification No.: 15080

Dear Mr. Mullinax:

As requested by your email yesterday, enclosed please find three sets of compact disks containing thermal insulation specification number 15080. As with the three disks transmitted to you yesterday, these disks are classified as Official Use Only requiring U. S. Department of Energy approval before any release to the public can be made.

If you have any questions, please call me at 803-952-7382.

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

RMC/r  
Enc.

- |                              |  |
|------------------------------|--|
| c: D. P. Ryan, 730-B         | V. E. Millings III, SCDHEC Region 5 EQC* |
| G. S. Hoover, 730-B          | J. C. Yon, SCDHEC Region 5 EQC*          |
| D. F. Hoel, 730-B*           | J. R. Hughes, SCDHEC Region 5 EQC*       |
| J. C. Somma, P.E., Parsons   | M. D. Sherritt, SCDHEC*                  |
| B. S. Mullinax, P.E., SCDHEC | * - Copy of Transmittal Letter Only      |

**WASHINGTON SAVANNAH RIVER COMPANY**



**SAVANNAH RIVER SITE**  
Aiken, SC 29808 • www.srs.gov

ESH-EPG-2008-00087

June 26, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

**RECEIVED**

JUN 30 2008

WATER FACILITIES  
PERMITTING DIVISION

Re: Construction Permit No.: 19,164-IW / Salt Waste Processing Facility – Phase II (Building)  
Third Supplemental Industrial Wastewater Treatment Facility Construction Permit Application Information  
Ref.: Telephone Conversation June 23, 2008 with B. S. Mullinax, P.E.

Dear Mr. Mullinax:

In response to our discussion on June 23, please find enclosed the original and three copies of the Project Engineer's acceptance of the list of material and construction specifications (Attachment 5) submitted to you on May 30, 2008.

In addition, we have enclosed revised pages 3 and 9 of the Engineering Report (Q-PER-J-00002, Rev. 2, 03/25/2008) submitted to you under cover letter dated April 2, 2008. Please insert these two pages into the Engineering Report and discard the original pages 3 and 9 of that report.

Washington Savannah River Company requests your continued review and issuance of a construction permit for the proposed building at your earliest opportunity. If you have any questions, please call me at 803-952-7382.

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

RMC/r  
Enc.

c: M. P. Prater, 730-B  
G. S. Hoover, 730-B  
D. F. Hoel, 730-B


V. E. Millings III, SCDHEC Region 5 EQC  
J. C. Yon, SCDHEC Region 5 EQC  
J. R. Hughes, SCDHEC Region 5 EQC

WASHINGTON SAVANNAH RIVER COMPANY

**The WSRC Team:** Washington Savannah River Company LLC • Bechtel Savannah River, Inc. • BNG America Savannah River Corporation • BWXT Savannah River Company • CH2 Savannah River Company

# PARSONS

I, James Somma, P.E., attest that the SWPF SPECIFICATIONS (Attachment 5) stamped by the individual Professional Engineers are acceptable to me.



S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

## WASTEWATER FACILITIES APPROVED FOR CONSTRUCTION

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008

  
\_\_\_\_\_  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

Facility features described herein, including numerical values assigned to process parameters or equipment specifications, may be subject to change as the design is further refined and finalized. Construction of the SWPF will begin after SCDHEC issues approval. The scheduled construction start date is June 2008 and Construction is currently projected to be completed by December 2011.

Limited Construction activities commenced in September 2007. Limited Construction includes: site preparation, including site clearing and grubbing; site utilities; electrical; excavation; grading; installation of the mud and base mat for the Process Building; and installation of stormwater control structures. Additionally, under SCDHEC Phase 1 Waste Transfer Line (WTL) Construction Permit No. 19,164-IW, the WTL segments will be installed in July 2008. SWPF stormwater control structures have been permitted by SCDHEC (Permit # SCR10H152<sup>2</sup>) under a Notice of Intent for Stormwater Discharges from Large and Small Construction Activities, National Pollutant Discharge Elimination System General Permit SCR100000<sup>3</sup>.

During Construction, the Engineering, Procurement and Construction (EPC) Contractor (Parsons) will contact SCDHEC representatives on a periodic basis to witness the construction progress occurring in J-Area. The EPC will provide notification to SCDHEC of the schedule for final closure of major process areas, such as the dark cells. SCDHEC is requested to identify any other specific areas that they may wish to observe before covering the excavations. Quarterly updates will be issued on progress, as well as on scheduled activity.

Following completion of Construction, initial testing (Cold Commissioning) will be performed prior to the tie-ins to the liquid waste processing facilities to confirm that all major processes and equipment perform as designed. Water runs will be followed by non-radioactive simulant runs. The products from this testing will be disposed in accordance with SCDHEC's Wastewater or Solid and Hazardous Waste Management Regulations. After SCDHEC issues an operating permit following Cold Commissioning, the tie-ins to the liquid waste processing facilities will be performed and Hot Commissioning will begin. Hot Commissioning is planned to commence as described in the quarterly status reports submitted to SCDHEC. SWPF Design, Construction, Commissioning, and one year of Operations will be completed by the EPC.

## **2.0 BACKGROUND INFORMATION**

Nuclear material production and processing at SRS generated millions of gallons of liquid radioactive waste (LRW) that is presently stored in underground waste storage tanks in the SRS F- and H-Area Tank Farms. Approximately 37 Mgal of the waste remains in the F- and H-Area Tank Farms and includes approximately 3 Mgal of sludge, comprising insoluble and precipitated solids, and 34 Mgal of salt solution and crystallized salts. The SWPF's function is to extract and concentrate the radioactive constituents from the salt solution and crystallized salts. The 3 Mgal of sludge will be retrieved and sent to the Extended Sludge Processing facilities and then to DWPF.

The SRS *Approved Site Treatment Plan* (WSRC-TR-94-0608<sup>4</sup>) (STP) and the *Federal Facility Agreement for the Savannah River Site* (WSRC-OS-94-92<sup>5</sup>) (FFA) require DOE to remove the LRW from the non-compliant LRW tanks. The high-level waste portion of liquid waste is

The SRS Tank Farm will prepare blended macro-batches for SWPF feed that range in size up to 1.2 Mgal. The SWPF ASP receives a small batch of SRS Tank Farm waste that is approximately 23,200 gallons. Upon receipt of a small batch, MST is added to the waste to sorb Sr and actinides, including isotopes of plutonium, americium, neptunium, and uranium. The MST and waste are mixed for several hours, during which time the MST selectively sorbs the Sr and actinides from the wastewater. The resulting MST slurry is then filtered to produce a concentrate of MST slurry and solids that contains most of the Sr and actinides, and a clarified salt solution (CSS) filtrate. The concentrated MST solids are transferred to a holding vessel and washed to reduce the sodium (Na) concentration, prior to transfer to the DWPF. The CSS filtrate is routed to the CSSX process for Cs removal. Section 4.3.1 describes the ASP in more detail.

CSSX is a continuous process that utilizes 36 centrifugal contactors for extraction, scrubbing, stripping, and washing of the aqueous and organic process streams. The Cs is removed by contacting the aqueous CSS with an organic solvent in 16 extraction stage contactors.

Cs is captured in the organic phase by the extractant and then released into a low-volume, slightly acidic strip solution via 16 stripping stages. The strip effluent is collected in the Strip Effluent Hold Tank (SEHT) prior to transfer to the DWPF for vitrification. The decontaminated salt solution (DSS) from the extraction stages is sent to the AFP for either an additional MST strike or for sampling and analysis prior to transfer to the SPF, where it will be solidified into a grout matrix known as saltstone grout. Section 4.3.2 provides a more detailed description of the CSSX process.

The AFP provides the capability to perform an additional MST strike if the Sr and actinide levels present in the CSS after the first MST strike in the ASP are too high to meet the SPF waste acceptance criteria (WAC). For the single-strike processing mode, one of the AFP tanks collects DSS from the CSSX for verification sampling and analysis, prior to transfer to the DSS Hold Tank (DSSHT). DSS that meets the SPF WAC is transferred from the DSSHT to SPF. The basic process steps for the AFP are described in more detail in Section 4.3.3.

#### **4.1 Waste Transfer Line Segments**

A construction application form, engineering report, and application fee for Phase I WTL Segments of the SWPF Project were submitted to SCDHEC and Phase 1 WTL Construction Permit No. 19, 164-IW was issued on January 02, 2008. This application detailed the WTL segments to be constructed before actual construction of the SWPF. These line segments are illustrated in Figure 4-2. Discussion of the operational use of each WTL follows.

The EPC will work with SCDHEC in the transition from the Phase 1 WTL Construction Permit to the Phase II SWPF Construction Permit including closeout notifications, letters, and drawings needed by SCDHEC.

#### **4.2 Wastewater Receipt from Tank Farms**

Wastewater is transferred from a tank in the H-Area Tank Farm to Alpha Sorption Tank-A (AST-A), located in the SWPF AST-A Process Vessel Cell. New transfer lines are required to



May 30, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

**RECEIVED**

MAY 30 2008

WATER FACILITIES  
PERMITTING DIVISION

Re: Construction Permit No.: 19,164-IW / Salt Waste Processing Facility – Phase II (Building)  
Second Supplemental Industrial Wastewater Treatment Facility Construction Permit Application Information  
Ref.: Telephone Conversation May 20, 2008 with B. S. Mullinax, P.E.

Dear Mr. Mullinax:

As discussed in the referenced telephone conversation with you in which you requested approval by the Salt Waste Processing Facility's Project Engineer of the specifications submitted with the Phase II Construction Permit Application, enclosed are three (3) original sets of lists of material and construction specifications bearing South Carolina Registered Engineer stamps and signatures in compliance with your request. These originals replace the sets previously transmitted to you.

Washington Savannah River Company requests your continued review and issuance of a construction permit for the proposed building at your earliest opportunity. If you have any questions, please call me at 803-952-7382.

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

RMC/r  
Enc.

c: M. P. Prater, 730-B  
G. S. Hoover, 730-B  
D. F. Hoel, 730-B

V. E. Millings III, SCDHEC Region 5 EQC  
J. C. Yon, SCDHEC Region 5 EQC  
J. R. Hughes, SCDHEC Region 5 EQC

**WASHINGTON SAVANNAH RIVER COMPANY**

# PARSONS

1080 Silver Bluff Road • Aiken, South Carolina 29803 • (803) 643-7100 • Fax: (803) 643-7118 • www.parsons.com

May 30, 2008

Ref. No.: 00-700-09103

**RECEIVED**

MAY 30 2008

WATER FACILITIES  
PERMITTING DIVISION

Mr. T. Zack Smith.  
Federal Project Director  
U.S. Department of Energy  
Savannah River Operations Office  
P.O. Box A  
Aiken, SC 29802

Subject: Contract No. DE-AC09-02SR22210  
Salt Waste Processing Facility (SWPF) Project  
Construction Permit No.: 19,164-IW - Phase II (Building)  
*Supplemental Industrial Wastewater Treatment Facility Engineering Report  
Information*

Reference: Letter with attachments, Campbell (WSRC) to Mullinax (SCDHEC) Reference  
Number ESH-EPG-2008-00071 dated May 15, 2008

Reference: C. Rippy (SCDHEC) to J. Somma (Parsons) dated 04 April 2008 SCDHEC  
Tracking No. #818672


Dear Mr. Smith:

As discussed during a conversation between Mr. Ron Campbell, Washington Savannah River Company LLC and SCDHEC on 20 May 2008, SCDHEC requested that the list of specifications submitted as referenced above be resubmitted with the appropriate professional engineer signature and seal per R.61-67.100.E.4.a.(5).

Three (3) sets (originals) of a list of material and construction specifications signed and sealed by professional engineers, are found in the attachment (identified as Attachment 5) and need to replace the three (3) copies previously submitted to SCDHEC as referenced above. This attachment needs to be submitted to Washington Savannah River Company (WSRC), Environmental Services Section, in accordance with ICD-19, for their submission to the SCDHEC.

Should you have any questions, please feel free to contact Richard Gurske at (803) 643-1602.

Very truly yours,

  
Mark R. Beor  
Project Manager



*RHS*  
MRB/RHG/cs

Attachment

cc: L. Zalants, DOE-SR  
D. Hoel, DOE-SR  
K. Harp, WSRC  
R. Campbell, WSRC  
J. Somma, SWPF  
A. Doswell, SWPF  
R. Gurske, SWPF  
SWPFDCA  
File No.: 3.4.1



**PARSONS**

**Salt Waste Processing Facility (SWPF)**

| Number | Description  | Quantity | Discipline |
|--------|--|----------|------------|
| 03100  | Structural Concrete Formwork                         | 0        | Structural |
| 03200  | Concrete Reinforcement                               | 0        | Structural |
| 03250  | Expansion Joints, Contraction Joints, and Waterstops | 0        | Structural |
| 03300  | Cast-In-Place Concrete                               | 0        | Structural |
| 03315  | Non-Shrink Grout                                     | 0        | Structural |
| 03410  | Plant Pre-cast Structural Concrete                   | 0        | Structural |
| 05055  | Welding, Structural                                  | 0        | Structural |
| 05120  | Structural Steel                                     | 0        | Structural |
| 05310  | Steel Roof Decking                                   | 0        | Structural |
| 05320  | Composite Steel Decking                              | 0        | Structural |
| 05505  | Miscellaneous Metals                                 | 0        | Structural |



S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19219-IW DATE Aug. 6, 2008

*Jeff D. DeB...*  
\_\_\_\_\_  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

| Number | Title   | Rev | Discipline            |
|--------|---|-----|-----------------------|
| 11811  | ASME Small Vessels                                      | 1   | Mechanical            |
| 11812  | Steel Tanks   | 0   | Mechanical            |
| 11813  | ASME Large Vessels (PP-17A)                             | 1   | Mechanical            |
| 11814  | Polyethylene Tanks                                      | 0   | Mechanical            |
| 11817  | Positive Material Identification                        | 0   | Mechanical            |
| 11818  | ASME Vessels - Carbon Steel                             | E2  | Mechanical            |
| 11819  | Seismic Qualification Criteria for Mechanical Equipment | 0   | Mechanical            |
| 11852  | Shell and Tube Heat Exchangers                          | E3  | Mechanical            |
| 11903  | Cross-Flow Filters                                      | F   | Engineering Mechanics |
| 11904  | Tank Mixing Eductors                                    | 0   | Mechanical            |
| 15140  | Waste Transfer Line Casing Spacer                       | 0   | Mechanical            |



*James C. Somers*  
5/20/08

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19219-1W DATE Aug. 6, 2008

*Jeff S. DePon*  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

| Number | Description                                   | Quantity | Discipline |
|--------|---|----------|------------|
| 11815  | Fabrication of Stainless Steel Sumps          | 0        | Mechanical |
| 11821  | Centrifugal Pumps (PC-1)                      | 0A2      | Mechanical |
| 11822  | Seismic Qualification Criteria for PC-3 Pumps | 0        | Mechanical |
| 11823  | Rotary Gear Pumps (PC-1)                      | 1        | Mechanical |
| 11824  | Air Diaphragm Pumps                           | 0A2      | Mechanical |
| 11825  | Centrifugal Pumps (PC-3)                      | 0        | Mechanical |
| 11826  | Rotary Gear Pumps (PC-3)                      | 0        | Mechanical |
| 11827  | Rotary Gear Pumps (PC-1, GS-2, PL-4)          | 1        | Mechanical |
| 11831  | Mechanical Agitators                          | 0        | Mechanical |
| 11841  | Compressed Air System                         | 0        | Mechanical |
| 11842  | Backup Air Receivers Compressor               | 0        | Mechanical |
| 11855  | Heaters (Electric)                            | 0        | Mechanical |
| 15080  | Thermal Insulation                            | 1        | Piping     |
| 15085  | Bolting Procurement (Piping)                  | 0        | Piping     |
| 15111  | Pipe Fabrication                              | 0A2      | Piping     |
| 15112  | Pipe Leak Testing                             | 0        | Piping     |
| 15113  | Piping Specialty Item Procurement             | 0        | Piping     |
| 15114  | General Piping Material Procurement           | 0        | Piping     |
| 15115  | Valve Procurement                             | 0        | Piping     |
| 15116  | Pipe Procurement                              | 0        | Piping     |
| 15117  | Fitting Procurement                           | 0        | Piping     |
| 15118  | Flange Procurement                            | 0        | Piping     |
| 15119  | Gasket Procurement                            | 0        | Piping     |
| 15120  | Piping Material Specification                 | 1        | Piping     |
| 15121  | Field Installation of Process Piping          | 0        | Piping     |
| 15123  | Protective Coatings - Underground Steel Pipe  | 0        | Piping     |

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)



FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.



PERMIT NO. 19,219-IW DATE Aug 6, 2008

*Jul P. DeBon*

| Item No. | Description   | Rev. | Disc.  |
|----------|---|------|--------|
| 15185    | Hydronic Pumps  | C2   | Piping |
| 15201    | Seismic Restraint of Mechanical Systems and Equipment | B1   | HVAC   |

**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER**

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**



(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008

*Jeff P. LeBon*  
\_\_\_\_\_  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

| WPP SPECIFICATIONS |   |     |                 |
|--------------------|---|-----|-----------------|
|                    | Title   | Rev | Category        |
| 15330              | Fire Protection Wet Pipe Sprinkler System       | 0   | Fire Protection |
| 15331              | Fire Protection Interior Distribution System    | 0   | Fire Protection |
| 15332              | Fire Protection Underground Water Supply System | 0   | Fire Protection |
| 16721              | Fire Alarm and Detection System                 | 0   | Fire Protection |

**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER**

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**



(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008

*[Signature]*  
\_\_\_\_\_  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION

| TITLES |                                  |          |            |
|--------|----------------------------------|----------|------------|
| Number | Description                      | Quantity | Category   |
| 16231  | Standby Diesel Generator Package | 0        | Electrical |
| 16641  | Cathodic Protection              | 0        | Electrical |

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19219-IW DATE Aug. 6, 2008

*Jul. D. LeBon*

DIRECTOR, WATER FACILITIES PERMITTING DIVISION

| Number | Description                        | Quantity | Discipline        |
|--------|------------------------------------|----------|-------------------|
| 14510  | Sample Transfer System             | 0        | Material Handling |
| 14513  | Drum Tumbler                       | 0        | Material Handling |
| 14516  | Gloveboxes                         | 0        | Material Handling |
| 14518  | Hot Cell Stainless Steel Lining    | 0        | Material Handling |
| 14519  | Fabrication of Specialty Equipment | 0        | Material Handling |



*Michael D. Vaughn, P.E.*  
5/29/08

**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER**

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19219-IW DATE Aug. 6, 2008

*John J. DeB...*  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION



May 15, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Re: Construction Permit No.: 19,164-IW / Salt Waste Processing Facility – Phase II (Building)  
Supplemental Industrial Wastewater Treatment Facility Engineering Report Information  
Ref.: Letter, C. Rippey (SCDHEC) to J. Somma (Parsons) dated April 04, 2008

Dear Mr. Mullinax:

As discussed at the meeting with you in Columbia on April 24, 2008, enclosed are three (3) sets of supplemental documents to the proposed Salt Waste Processing Facility's Engineering Report (Q-PER-J-00002, Revision 2 dated 03/25/2008) in compliance with Ms. Crystal Rippey's letter referenced above.

These documents include the following:

- Letter from the Department of Energy-Savannah River Office regarding the recognition of the Project Manager, Mr. Mark R. Breor, on behalf of Parsons Infrastructure and Technology Group, Inc., and the adequacy of personnel and equipment to maintain and operate the proposed treatment facility;
- Responses to the eight items contained in Ms. Rippey's April 04 letter;
- Lists of major items of equipment and specifications, along with example specifications and calculations as discussed at the April 24 meeting; and
- Proposed Salt Waste Processing Facility Location Map.

Accordingly, Washington Savannah River Company requests your review and issuance of a construction permit for the proposed building at your earliest opportunity. If you have any questions, please call me at 803-952-7382.

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

RMC/r  
Enc.

c: M. P. Prater, 730-B  
G. S. Hoover, 730-B  
D. F. Hoel, 730-B

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL

**APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST BE OBTAINED FROM THIS OFFICE AFTER COMPLETION OF CONSTRUCTION.

PERMIT NO. 19219-IW DATE Aug. 6, 2008

V. E. Millings III, SCDHEC Region 5 EQC  
J. C. Yon, SCDHEC Region 5 EQC  
J. R. Hughes, SCDHEC Region 5 EQC

**WASHINGTON SAVANNAH RIVER COMPANY**





**Department of Energy**  
Savannah River Operations Office  
P.O. Box A  
Aiken, South Carolina 29802

MAY 15 2008

Crystal Rippy, Manager  
Industrial Waste Water Permitting Section  
Water Facilities Permitting Division  
South Carolina Department of Health and  
Environmental Control

**Subject:** Clarification of Adequacy to Operate the Salt Waste Processing Facility (SWPF) and Delegation of Signature Authority to Parsons Regarding Waste Water Permitting

**Reference:** Letter, Rippy (SCDHEC) to Somma (Parsons) April 4, 2008, SCDHEC Application Tracking #818672

Dear Ms. Rippy:

The U.S. Department of Energy (DOE) wishes to respond to two comments contained in the above referenced letter. For comment #5, *"A letter of acceptance from the owner stating that they have adequate equipment and personnel to operate and maintain the proposed sewer system must be submitted."* The Department of Energy and its operating contractor(s) will have adequate equipment and personnel to operate and maintain the proposed Salt Waste Processing Facility (SWPF).

For comment #7, *"The person who signed as owner does not appear to meet the requirements of the application instructions in Part XV. Please resubmit a revised permit application with the appropriate owner's signature (one original and 3 copies) or submit a letter describing how this person who signed meets these requirements."* Pursuant to SC Code Ann. Reg. 61-9.122.22(b), please be advised that Parsons Infrastructure and Technology Group, Inc., the entity responsible for the overall construction and operations of the SWPF, including environmental matters, is hereby designated as the duly authorized representative of the DOE in connection with waste water permitting matters. This means those Parsons individuals (and their respective designees) who occupy the position of Project Manager may sign all applications and reports required for such permits. Also, the enclosure confirms that DOE recognizes Mr. Mark R. Breor as the Project Manager, replacing Mr. David B. Amerine.

Questions concerning this delegation of authority may be directed to Mary-Ellen Noone, Attorney, Advisor in the Office of Chief Counsel at 803-952-8414. Questions concerning technical matters may be addressed to Larry Zalants, SWPF Operations, at 803-641-8905.


Sincerely,

Jeffrey M. Allison  
Manager

SWPF-08-266

Enclosure: Amendment of Modification  
of Contract #M048

Enclosure  
 SUBJECT: Amendment of Modification of Contract  
 #M048  
 Dated: January 17, 2008

|  |                                    |   |                                |  |
|--|------------------------------------|---|--------------------------------|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT   |                                    | 1. CONTRACT ID CODE   | PAGE OF PAGES<br>1 2           |  |
| 2. AMENDMENT/MODIFICATION NO.<br>M048  | 3. EFFECTIVE DATE<br>See Block 16C | 4. REQUISITION/PURCHASE REQ. NO.  | 5. PROJECT NO. (If applicable) |  |
| 6. ISSUED BY<br>U. S. Department of Energy<br>Savannah River Operations Office<br>P.O. Box A<br>Aiken, SC 29802  | CODE                               | 7. ADMINISTERED BY (If other than item 6)   | CODE                           |  |
| 8. NAME AND ADDRESS OF CONTRACTOR (No. street, county, State, and ZIP Code)<br>Parsons Infrastructure and Technology Group, Inc.<br>1080 Silver Bluff Road<br>Aiken, SC 29803  |                                    | 9A. AMENDMENT OF SOLICITATION NO.   |                                |  |
|  |                                    | 9B. DATED (See item 11)   |                                |  |
|  |                                    | X 10A. MODIFICATION OF CONTRACT/ORDER NO.<br>DE-AC09-028R22210                          |                                |  |
|  |                                    | 10B. DATED (See item 13)<br>8/17/02   |                                |  |
| CODE   | FACILITY CODE                      |   |                                |  |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS  |                                    |   |                                |  |
| <input type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended.<br>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:<br>(a) By completing items 8 and 15, and returning ___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. |                                    |   |                                |  |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required)<br>N/A   |                                    |   |                                |  |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.<br>IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.  |                                    |   |                                |  |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.   |                                    |   |                                |  |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).  |                                    |   |                                |  |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:   |                                    |   |                                |  |
| X D. OTHER (Specify type of modification and authority)<br>Parsons' Letter #00-700-07844 (Replacement of Key Personnel)  |                                    |   |                                |  |
| E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.   |                                    |   |                                |  |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible)   |                                    |   |                                |  |
| A. The purpose of this modification is to revise Section J, Attachment F - Key Personnel. Mr. David B. Amerina is replaced by Mr. Mark R. Bror as the Project Manager. (See page 2 hereof for the revised Key Personnel List.)   |                                    |   |                                |  |
| B. All other terms and conditions of the contract remain unchanged.  |                                    |   |                                |  |
| Except as provided herein, all terms and conditions of the document referenced in item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.   |                                    |   |                                |  |
| 15A. NAME AND TITLE OF SIGNER (Type or print)  |                                    | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)                              |                                |  |
|  |                                    | Charlene Smith, Contracting Officer   |                                |  |
| 15B. CONTRACTOR/OFFEROR  | 15C. DATE SIGNED                   | 16B. UNITED STATES OF AMERICA   | 16C. DATE SIGNED               |  |
| (Signature of person authorized to sign)   |                                    | BY  | 1/17/08                        |  |
|  |                                    | (Signature of Contracting Officer)  |                                |  |

**SECTION J - LIST OF ATTACHMENTS**

**ATTACHMENT F**

**KEY PERSONNEL**

| <b>Name</b>         | <b>Position</b>          |
|---------------------|--------------------------|
| Mark R. Breor       | Project Manager          |
| Alice C. Doswell    | ESH&Q Manager            |
| Romi W. Puckett     | Project Controls Manager |
| Dan Jensen          | Technology Manager       |
| Phil Dovaston       | Processing Engineering   |
| James C. Somma      | Engineering Manager      |
| Charles E. Swain    | Construction Manager     |
| Alois (Skip) Singer | Commissioning Manager    |
| John Kasper         | EPC Manager              |
| Paul J. Whittingham | Contracts Manager        |

# PARSONS

1080 Silver Bluff Road • Aiken, South Carolina 29803 • (803) 643-7100 • Fax: (803) 643-7118 • www.parsons.com

May 7, 2008

Ref. No.: 00-700-08904

Mr. T. Zack Smith  
Federal Project Director  
U.S. Department of Energy  
Savannah River Operations Office  
P.O. Box A  
Aiken, SC 29802

Subject: Contract No. DE-AC09-02SR22210  
Salt Waste Processing Facility (SWPF) Project  
*SCDHEC Construction Permit Application for Water/Wastewater Facilities and Engineering Report for an Industrial Wastewater Treatment Facility, Document No.: Q-PER-J-00002, Revision 2*

Reference: Letter, Rippy (SCDHEC) to Somma (Parsons), April 04, 2008, SCDHEC Application Tracking # 818672

Dear Mr. Smith:

Parsons received the above referenced letter from the South Carolina Department of Health and Environmental Control (SCDHEC) declaring the permit application package administratively incomplete. Comment resolution was reached during a meeting with SCDHEC, the U.S. Department of Energy (DOE), Washington Savannah River Company (WSRC), and Parsons on April 24, 2008. The comments and responses are provided below and need to be submitted to WSRC, Environmental Services Section, in accordance with Interface Control Document (ICD)-19 for their submission to SCDHEC.

**1. Three (3) pump station calculations and pump curves need to be submitted.**

Response: Pump stations as described in SCDHEC Regulation 61-67.300.C are not an integral part of the proposed SWPF. Operation of the batch processing within SWPF utilizes small pumps to transfer the batches at low flow rates between the respective process units inside the building. These pumps are identified on the General Arrangement Drawing Index (page A2 of the Engineering Report).

Three copies of a table listing the process pumps, their capacity and the basis for the minimum flow rate to be used for the SWPF are provided in Attachment 1. Additionally, we attached an example of a pump data sheet for one of the centrifugal pumps to be used within the SWPF (see Attachment 2). A complete set of data sheets and calculations is available on file at the site.



2. **Three (3) copies of flow calculations must be submitted justifying the sizing of the lines and/or equipment.**

Response: The basis of the minimum flow rate is provided in Attachment 1.

3. **Three (3) copies of a detailed 8½" by 11" location map must be submitted.**

Response: Three copies of a detailed 8½" by 11" location map, cleared for public release, are attached (see Attachment 3).

4. **Three (3) sets of signed and sealed specifications must be submitted. Specifications should include all materials of construction (e.g., PVC pipe or stainless steel tanks) and sizes of equipment.**

Response: All tanks, pumps and piping that will contain radioactive materials are constructed of stainless steel. All other tanks and piping used for nonradioactive chemicals, process water, etc. are stainless steel or polyethylene. Sizes and specifications of the various tanks proposed for the SWPF are described in the General Arrangement Drawing Index (see page A2 of the Engineering Report) and in Attachment 4 of this letter (the SWPF Process Tanks list). Three copies of the SWPF List of Specifications are provided in Attachment 5 and are not signed and Professional Engineer (PE) stamped as agreed to with SCDHEC during the meeting on April 24, 2008. A complete set of specifications is available on file at the site.

5. **A letter of acceptance from the owner stating that they have adequate equipment and personnel to operate and maintain the proposed sewer system must be submitted.**

Response: The owner of SWPF is the DOE. A letter of acceptance from DOE verifying that equipment and personnel are adequate to operate and maintain the proposed wastewater treatment facility is being submitted under separate cover.

6. **A SC registered PE must sign and seal all plans and specifications and the Certificate of Authorization (COA) from the engineering firm must also be affixed near the PE seal. Please resubmit these documents with the appropriate seals. Please note: If the plans and specifications are bound (a staple is sufficient for this purpose), then it is only necessary to place the COA and PE seal/signature on the front of the bound document. If the plans and specifications are not bound, then each page must include the COA and PE seal/signature.**

Response: The Plans (i.e., Engineering Report for an Industrial Wastewater Treatment Facility, Q-PER-J-00002, Rev. 2) were signed and sealed by a SC registered PE, and a COA was also affixed to the bound document.

7. **The person who signed as owner does not appear to meet the requirements of the application instructions in Part XV. Please resubmit a revised permit application with the appropriate owner's signature (one original and 3 copies) or submit a letter describing how the person who signed meets these requirements.**

Response: Amendment of DOE Contract DE-AC09-02SR22210 approved Mark R. Breor as the SWPF Project Manager thus meeting the requirements of the application instructions found in Part XV. DOE is addressing this response under separate cover.

**Unnumbered Comment:** Also, please note that any land clearing activity that is being performed in relation to this project must be permitted under the State Sediment and Erosion Control Program.

Response: A Notice of Intent for stormwater and sediment control management under SCDHEC's General Permit for Storm Water Discharges from Large and Small Construction Activities was properly filed with the SCDHEC on August 23, 2007. This Project's General Permit coverage number is SCR10H152.

Should you have any questions, please feel free to contact Richard Gurske at (803) 643-1602.

Very respectfully,

  
Mark R. Breor  
Vice President and Project Manager

  
MRB/rhg/as

Attachments

cc: L. Zalants, DOE-SR  
D. Hoel, DOE-SR  
K. Harp, WSRC  
R. Campbell, WSRC  
J. Somma, SWPF  
A. Doswell, SWPF  
R. Gurske, SWPF  
SWPFDCA  
File No.: 3.4.1

# PARSONS

## Salt Waste Processing Facility (SWPF)

| Pump Number  | Description                                     | Process Flow Diagram Number | Design Capacity (gpm) | Basis for Design Capacity   |
|--------------|---|-----------------------------|-----------------------|---|
| P-101A/B     | Alpha Sorption Tank A Transfer Pumps            | M-M5-J-0002P                | 300                   | Needed to meet AST-A cycle time requirements for "Transfer from AST-A" (see attached Table 1)   |
| P-102-1A/B/C | Filter Feed/Solids Transfer Pumps               | M-M5-J-0002P                | 60                    | Needed to meet design filtrate rate of 10.75 gpm and to provide sufficient bleed-back flow to prevent excessive solids concentration in the filter loop |
| P-102-2A/B/C | Filter Recirculation Pumps                      | M-M5-J-0003P                | 1300                  | Needed to meet design requirement of 9-13 feet/second through the filter tubes  |
| P-104-1      | Washing Filter Feed/Sludge Solids Transfer Pump | M-M5-J-0004P                | 150                   | Needed to prevent settling of solids in waste transfer line to DWPF and to minimize transfer time   |
| P-104-2      | Washing Filter Recirculation Pump               | M-M5-J-0004P                | 1300                  | Same basis as P-102-2A/B/C  |
| P-105 A/B    | Wash Water Transfer Pumps                       | M-M5-J-0004P                | 175                   | Needed to meet AST-A cycle time requirements for "Caustic Adjustment" (see attached Table 1)  |
| P-109A/B     | Salt Solution Feed Pumps                        | M-M5-J-0006P                | 30                    | Salt Solution flow of 22 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts   |
| P-206A/B     | Ba-137 Decay Tank Transfer Pumps                | M-M5-J-0007P                | 30                    | Decontaminated Salt Solution flow of 23 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-202A/B     | Solvent Feed Pumps                              | M-M5-J-0007P                | 40                    | Solvent flow of 7.2 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-217A/B     | Solvent Strip Feed Pumps                        | M-M5-J-0007P                | 15                    | Solvent flow of 7.2 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-215A/B     | Strip Effluent Pump Tank Pumps                  | M-M5-J-0008P                | 10                    | Strip Effluent flow of 1.44 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-205A/B     | Strip Effluent Transfer Pumps                   | M-M5-J-0008P                | 300                   | Transfer rate to DWPF is 100 gpm to minimize transfer time. Pump is oversized to provide sufficient flow to TK-205 mixing eductors                      |
| P-204A/B     | Caustic Wash Tank Pumps                         | M-M5-J-0008P                | 10                    | Caustic Wash flow of 1.44 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |

Note: Only pumps that are key to meeting design throughput of 94 million gallons per month are listed. Other pumps, such as filter cleaning pumps, etc. not listed.

**PARSONS****Salt Waste Processing Facility (SWPF)**

| Pump Number  | Description                           | Process Flow Diagram Number | Design Capacity (gpm) | Design Basis for Design Capacity   |
|--------------|---------------------------------------|-----------------------------|-----------------------|--|
| P-207A/B     | DSS Hold Tank Transfer Pumps          | M-M5-J-0009P                | 400                   | Transfer rate to Tank Farm Tank 50 is 150 gpm to minimize transfer time. Pump is oversized to provide sufficient flow to TK-207 mixing eductors and DSS Flush Header                   |
| P-309A/B     | Scrub Feed Pumps                      | M-M5-J-0012P                | 5                     | Scrub flow of 1.44 gpm is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-310A/B     | Strip Feed Pumps                      | M-M5-J-0012P                | 0.1                   | 0.05 M nitric acid flow at .029 gpm mixed with 1.41 gpm of Process Water is required to provide Strip flow of 1.44 gpm which is needed to meet 9.4 Mgal/year salt waste feed receipts  |
| P-220A/B     | Intermediate Storage Transfer Pumps   | M-M5-J-0015P                | 400                   | 300 gpm is needed to meet AST-B cycle time requirements for "CDCSS Delivery from IST to AST-B" (see attached Table 2). Pump is oversized to sufficient flow to TK-220 mixing eductors. |
| P-221A/B     | Alpha Sorbition Tank-B Transfer Pumps | M-M5-J-0015P                | 300                   | 300 gpm is needed to meet AST-B cycle time requirements for "Transfer from AST-B to FFT-B" (see attached Table 2).   |
| P-222-1A/B/C | Filter Feed/Solids Transfer Pumps     | M-M5-J-0015P                | 60                    | Same as for P-102-1A/B/C   |
| P-222-2A/B/C | Filter Recirculation Pumps            | M-M5-J-0016P                | 1300                  | Same as for P-102-2A/B/C   |



# PARSONS

## Salt Waste Processing Facility (SWPF)

**Table 1. Alpha Sorption Tank-A Cycle Time – Single Monosodium Titanate Strike**

| Operation/Step           | Volume <sup>1</sup><br>(gallons) | Flow Rate (gpm) | Time (hours) |
|--------------------------|----------------------------------|-----------------|--------------|
| Feed Delivery            | 23,200                           | 130             | 2.97         |
| MST Addition             | 72                               | 5               | 0.24         |
| Caustic Adjustment       | 5,003                            | 100             | 0.83         |
| Mix/Reaction             | N/A                              | N/A             | 12           |
| Operation Verification   | N/A                              | N/A             | 2            |
| Contingency <sup>2</sup> | N/A                              | N/A             | 2            |
| Transfer from AST-A      | 28,275                           | 300             | 1.57         |
| Line Flush <sup>3</sup>  | 100                              | 100             | 0.02         |
| <b>Total Cycle Time</b>  |                                  |                 | <b>21.63</b> |

**Notes:**

1. Volumes and times are based on MST concentration of 0.4 g/L in AST-A.
2. Contingency allowance is for unanticipated delays.
3. Line flush approximated. Flushing requirements to be determined following development of piping isometric drawings.

**PARSONS**  
**Salt Waste Processing Facility (SWPF)**

Table 2. Alpha Sorption Tank-B Cycle Time – Two Monosodium Titanate Strikes

| Operation                          | Volume (g/L)     | Time (min) | Number of Strikes | Time (min)   |
|------------------------------------|------------------|------------|-------------------|--------------|
| CDCSS Delivery from IST to AST-B   | 29,860           |            | 300               | 1.66         |
| MST Addition                       | 76               |            | 5                 | 0.25         |
| Mix/Reaction                       | N/A              |            | N/A               | 6            |
| Operation Verification             | N/A              |            | N/A               | 2            |
| Sampling and Analysis <sup>2</sup> | N/A              |            | N/A               | 8            |
| Contingency                        | N/A              |            | N/A               | 2            |
| Transfer from AST-B to FFT-B       | 29,936           |            | 300               | 1.66         |
| Line Flush                         | 100 <sup>3</sup> |            | 100               | 0.02         |
| <b>Total Cycle Time</b>            |                  |            |                   | <b>21.59</b> |

Notes:

1. Volumes and times are based on MST loading of 0.4 g/L.
2. It is assumed that the sample collection will be performed in AST-B.
3. Line flush approximated. Flushing requirements to be determined following development of piping isometric drawings.

**Attachment 2**

**Strip Effluent Transfer Pumps  
P-205A & P-205B**

**Data Sheets  
Centrifugal Pumps General Specifications  
Sizing Calculation**

**For Example Only**


# PARSONS

## Data Sheet

| <b>PARSONS</b>   |          | Job Number | Document Number   | Rev                | Date                                   | Sheet          |
|--|----------|------------|---|--------------------|--|----------------|
| Data Sheet   |          | 745253     | M-DS-J-00132  | 0                  | 2/28/2008                              | 1 of 4         |
| Salt Waste Processing Facility<br>US Department of Energy<br>Aiken, South Carolina   |          |            | Title<br><br>STRIP EFFLUENT TRANSFER PUMPS<br>P-205A & P-205B |                    |  |                |
| <input type="checkbox"/> Quotation <input type="checkbox"/> Purchase <input type="checkbox"/> Construction <input checked="" type="checkbox"/> Use <input type="checkbox"/> Other  |          |            |   |                    |  |                |
| Functional Classificator   |          | SS         | Procurement Level: 2  |                    | Performance Category: PC-3             |                |
| Approvals  |          |            |   |                    |  |                |
| Rev  | Date     | By         | Check   | Lead Disc.<br>Eng. | Func. Area Mgr /<br>Eng. and Des. Mgr. | Remarks        |
| 0  | 02/28/08 | JKJ        | CJH   | GCH                | JS                                     | Issued for Use |
| This sheet is a record of each issue or revision to the subject document. The exact sheets changed and the nature of the change should be noted under Remarks. All sheets, including revised sheets, shall be compiled and issued in their entirety. |          |            |   |                    |  |                |

Indicates supplier is to provide the information of the furnished item


|   |  |                                     |   |                      |  |
|---|--|-------------------------------------|---|----------------------|--|
| No. Required  | Two (2)  | Pump size                           | Type  | Model                | Manufacturer                                 |
| <b>GENERAL</b>  |  |                                     |   |                      |  |
| Pump Item No.   | <b>P-205A &amp; P-205B</b>   | P&ID                                | <b>M-M6-J-0033</b>                          | Motor Data Sheet No. | <b>TBD</b>                                   |
| Motor Item No.  |  | PFD                                 | <b>M-M5-J-0008</b>                          | Motor by             | <b>Supplied and mounted by pump supplier</b> |
|   |  | Pump Calc. No.                      | <b>M-CLC-J-00013</b>                        |                      |  |
| <b>OPERATING CONDITIONS (Note 5)</b>  |  |                                     | <b>LIQUID</b>                               |                      |  |
| Capacity, Normal  | <b>300 (150)</b>   | gpm                                 | Rated                                       | <b>300 (150)</b>     | gpm  |
| Other   |  |                                     |   |                      |  |
| Suction Pressure Max/Normal   | <b>21.4 / 6.1 (11.5)</b> psia  |                                     |   |                      |  |
| Discharge Pressure  | psia   | <b>53 / 98.4</b>                    |   |                      |  |
| Differential Pressure   | psi / ft   | <b>47 (86.9) / 109 (201)</b>        |   |                      |  |
| Rated TDH   | ft   | <b>121 (221)</b>                    | NPSHA                                       | <b>13 (25.4)</b>     | ft   |
| Hydraulic Power   | <b>9.2 (8.4)</b> HP  |                                     |   |                      |  |
| Service:  | <b>Continuous</b>  |                                     |   |                      |  |
| <b>SITE AND UTILITY DATA</b>  |  |                                     | <b>PERFORMANCE (Note 1)</b>                 |                      |  |
| Location:   |  |                                     |   |                      |  |
| Indoor  | <input checked="" type="checkbox"/>                                      | Heated                              | <input checked="" type="checkbox"/>         | Outdoor              | <input type="checkbox"/>                     |
| North ASP Pump & Valve Gallery  | <b>Cold Chemical area</b>  |                                     |   |                      |  |
| South ASP Pump & Valve Gallery  | <b>CSSX Pump &amp; Valve Gallery</b> <input checked="" type="checkbox"/> |                                     |   |                      |  |
| Altitude  | ft   | <b>60</b>                           | Barometer                                   | <b>14.7</b>          | psia   |
| Range of Ambient Temps. Min/Max   | <b>60 / 90</b> °F  |                                     |   |                      |  |
| NEC Area Classification   | <b>CL. I, DIV. 2, GP. D</b>  |                                     |   |                      |  |
| Temperature Classification  | <b>T3 (410 °F)</b>   |                                     |   |                      |  |
| <b>CONSTRUCTION (Note 1)</b>  |  |                                     | <b>CONSTRUCTION (Cont'd)</b>                |                      |  |
| Applicable Standard   | <b>ASME B73.1</b>  |                                     |   |                      |  |
| ■ Nozzles:  | Size   | Rating                              | Fac'g                                       | Position             |  |
| Suction   | <b>3"</b>  | <b>150 #</b>                        | <b>RF</b>                                   | <b>End</b>           |  |
| Discharge   | <b>2"</b>  | <b>150 #</b>                        | <b>RF</b>                                   | <b>Top</b>           |  |
| ■ Drain   | <b>Note 6</b>  |                                     |   |                      |  |
| ■ Seal In   |  |                                     | <b>NPT</b>                                  |                      |  |
| ■ Seal Out  |  |                                     | <b>NPT</b>                                  |                      |  |
| Casing mounting:  | <b>Foot mounted</b>  |                                     |   |                      |  |
| Base plates:  |  |                                     |   |                      |  |
| <input type="checkbox"/> API Baseplate Number   |  |                                     |   |                      |  |
| Non-Grout Construction:   |  |                                     |   |                      |  |
| Vertical Leveling Screws  | <b>Fab Steel with Drip Rim</b> <input checked="" type="checkbox"/>       |                                     |   |                      |  |
| Horizontal Positioning Screws for all Drive Train Components  |  |                                     |   |                      |  |
| Non Spark Guard   |  |                                     |   |                      |  |
| Testing   | Non-Witness  | Witness                             |   |                      |  |
| Hydrostatic   |  | <b>X</b>                            |   |                      |  |
| Performance/Vibration   | <b>X</b>   |                                     |   |                      |  |
| NPSH  | <b>X</b>   |                                     |   |                      |  |
| Complete Unit Test  | <b>X</b>   |                                     |   |                      |  |
| Sound Level Test  | <b>X</b>   |                                     |   |                      |  |
| Cleanliness Prior to Final Assembly   | <b>X</b>   |                                     |   |                      |  |
| ■ Weights (Note 1)  |  |                                     |   |                      |  |
| Weight of Pump  |  | lb                                  |   |                      |  |
| Weight of Base plate  |  | lb                                  |   |                      |  |
| Weight of Motor   |  | lb                                  |   |                      |  |
| Weight of Gear  |  | lb                                  |   |                      |  |
| Total Weight  |  | lb                                  |   |                      |  |
| Notes:  |  |                                     |   |                      |  |
| 1. Supplier to provide/verify information.  |  |                                     |   |                      |  |
| 2. Pump shall be complete with drive motor, coupling, seal flush equipment, piping and base plate.          |  |                                     |   |                      |  |
| 3. Supplier to provide pump curves and dimensioned arrangement drawings.                                    |  |                                     |   |                      |  |
| 4. Pump is exposed to radioactive fluid. Total integrated dose rate is 610 rad/hr.                          |  |                                     |   |                      |  |
| 5. Pump shall function at two operating conditions:   |  |                                     |   |                      |  |
| a) 300 gpm @ 121 ft TDH   | b) 150 gpm @ 221 ft TDH (in parenthesis)                                 |                                     |   |                      |  |
| 6. Pump shall have a 3/4" casing drain. See sheet 4.  |  |                                     |   |                      |  |
| 7. The supplier shall provide HP and RPM;   |  |                                     |   |                      |  |
| 8. Basis of Design: Pump "footprint" dimensions shall not exceed 64" x 21".                                 |  |                                     |   |                      |  |
| 9. Buyer to verify material.  |  |                                     |   |                      |  |
| 10. Supplier to provide tapped holes on the pump and motor for installation of vibration monitoring device. |  |                                     |   |                      |  |
| <b>Couplings:</b>   |  |                                     | <b>MOTOR DRIVE (Note 1)</b>                 |                      |  |
| Type  |  |                                     | Manufacturer                                |                      |  |
| ■ Make  |  |                                     | ■ Model/Size                                |                      |  |
| ■ Lubrication: <b>Constant Level Oiler</b>  |  |                                     | ■ HP, RPM (Note 7)                          |                      |  |
| <b>Mechanical Seal or Packing (Note 1)</b>  |  |                                     | ■ TEFC, Non-arcing/Non-sparking             |                      |  |
| Seal <b>Double Mechanical Seal</b>  |  |                                     | ■ Frame                                     |                      |  |
| ■ Seal Manufacturer   |  |                                     | ■ Service Factor <b>1.15</b>                |                      |  |
| ■ Size and Type   |  |                                     | Volts/Phase/Hertz <b>460 V / 3Ø / 60 Hz</b> |                      |  |
| ■ Big Bore Box  |  |                                     | Variable speed drive <b>Yes</b>             |                      |  |
| ■ Seals and Gaskets <b>Kalrez 6375 / Peek (Note 9)</b>  |  |                                     | ■ Full Load Amps                            |                      |  |
| ■ Gland Material <b>316L SS</b>   |  |                                     | ■ Locked Rotor Amps                         |                      |  |
| ■ Seal Flush Piping Plan <b>53A (No cooling, see sheet 3)</b>   |  |                                     | ■ Lubrication <b>Grease Lube for Life</b>   |                      |  |
| <b>MATERIALS (Note 1)</b>   |  |                                     |   |                      |  |
| ■ Barrel/Case   |  | <b>316L SS</b>                      | Impeller                                    |                      | <b>316L SS</b>                               |
| ■ Case/Impeller Wear Rings  |  | <b>316L SS</b>                      |   |                      |  |
| ■ Shaft/Sleeve  |  | <b>316L SS</b>                      |   |                      |  |
| Diffusers   |  |                                     |   |                      |  |
| Bearing Housing   |  |                                     |   |                      |  |
| Coupling Diaphragms (Disks)   |  |                                     |   |                      |  |
| Coupling Spacer/Hubs  |  |                                     |   |                      |  |
| Material Certification Required for   |  |                                     |   |                      |  |
| Casing  |  | <input checked="" type="checkbox"/> | Impeller                                    |                      | <input checked="" type="checkbox"/>          |
| Other   |  |                                     | Shaft                                       |                      | <input checked="" type="checkbox"/>          |
| <b>SURFACE PREPARATION AND PAINT</b>  |  |                                     |   |                      |  |
| Manufacturer's Standard and Specification <b>11825</b>  |  |                                     |   |                      |  |



|                 |              |    |   |                  |                 |
|-----------------|--------------|----|---|------------------|-----------------|
| SHEET           | 3            | OF | 4 | EQUIPMENT NUMBER | P-205A & P-205B |
| DOCUMENT NUMBER | M-DS-J-00132 |    |   |                  |                 |
| REV             | 0            |    |   |                  |                 |

STRIP EFFLUENT  
TRANSFER PUMPS

PARSONS  
CENTRIFUGAL PUMP DATA SHEET



3/4" BRAIN PIPE TO EXTEND 2" BEYOND FACE OF SUCTION FLANGE  
 WITH BEVELED END FOR BUTT WELDING.  
 WHEN REQUIRED FOR HYDROSTATIC TESTING, FABRICATE 3/4" BRAIN  
 PIPE TO 6" BEYOND FACE OF SUCTION FLANGE AND CAP THE END.

|   |   |  |            |                                 |                                     |
|---|---|--|------------|---------------------------------|-------------------------------------|
| <b>PARSONS</b><br>CENTRIFUGAL PUMP DATA SHEET | <b>STRIP EFFLUENT<br/>         TRANSFER PUMPS</b> |  | SHEET<br>4 | OF<br>4                         | EQUIPMENT NUMBER<br>P-205A & P-205B |
|   |   |  |            | DOCUMENT NUMBER<br>M-DS-J-00132 | REV<br>0                            |

Model: 3196

Size: 2x3-13

Group: MTX

60Hz

RPM: 1770

Stages: 1

Job/Inq.No. :

Purchaser : PARSONS

End User :

Issued by : Richard Warren

Item/Equip.No. : P-205A & P-205B

Quotation No. : 82595 120704

Service : Strip Effluent Transfer Pumps

Order No. :

Date : 08/20/2007


Certified By :

**Operating Conditions**

**Pump Performance**

|                   |                |                           |            |                         |                  |
|-------------------|----------------|---------------------------|------------|-------------------------|------------------|
| Liquid:           | Strip Effluent | Actual Pump Eff.:         | 61.5 %     | Suction Specific Speed: | 6,330 gpm(US) ft |
| Temp.:            | 120.0 deg F    | Actual Pump Power:        | 14.9 hp    | Min. Hydraulic Flow:    | 55.7 gpm         |
| S.G./Visc.:       | 1.000/0.900 cp | Total Power Loss:         | 0.39 hp    | Min. Thermal Flow:      | N/A              |
| Flow:             | 300.0 gpm      | Rated Total Power:        | 14.9 hp    |                         |                  |
| TDH:              | 121.0 ft       | Imp. Dia. First 1 Stg(s): | 11.5000 in |                         |                  |
| NPSHa:            | 13.0 ft        | NPSHr:                    | 5.6 ft     | Non-Overloading Power:  | 18.1 hp          |
| Solid size:       | 0.0020 in      | Shut off Head:            | 140.1 ft   |                         |                  |
| % Solids:         | 0.1            | Vapor Press:              |            |                         |                  |
| Max. Solids Size: | 0.3750 in      |                           |            |                         |                  |

Notes: 1. Elevated temperature effects on performance are not included.





|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 1 of 14 |

|  |  |
|--|--|
| Salt Waste Processing Facility<br>U.S. Department of Energy<br>Aiken, South Carolina | Section Title:<br>Centrifugal Pumps (PC-3) |
|--|--|

|                                   |                                       |                                    |   |  |
|-----------------------------------|---------------------------------------|------------------------------------|---|--|
| <input type="checkbox"/> Purchase | <input type="checkbox"/> Construction | <input type="checkbox"/> Quotation | <input checked="" type="checkbox"/> Other | <input checked="" type="checkbox"/> All Pages Attached |
|-----------------------------------|---------------------------------------|------------------------------------|---|--|

|   |                                      |
|---|--------------------------------------|
| Functional Classification:<br><u>SS</u> | Performance Category:<br><u>PC-3</u> |
|---|--------------------------------------|

| Rev | Date     | By                | Ck                | Approvals       |                                     | Remarks        |
|-----|----------|-------------------|-------------------|-----------------|-------------------------------------|----------------|
|     |          |                   |                   | Lead Disc. Eng. | Func. Area Mgr./ Eng. and Des. Mgr. |                |
| 0   | 12/10/07 | JKJ<br><i>JKJ</i> | CIH<br><i>CIH</i> | CH<br><i>CH</i> | JS<br><i>JS</i><br>8/17/08          | Issued for Use |

This document and the design it covers are the property of **PARSONS**. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, exhibited, or used in any other way, except by written consent from **PARSONS** to the borrower.

This sheet is a record of each issue or revision to the subject Section. Each time this Section document is changed, all sheets must be issued. The nature of the change should be noted in the Remarks column; however, these remarks are not a part of the Section. All changes to documents after issue as Revision 0 shall be recorded on the Revision Summary Sheet.

*JKJ*

**CENTRIFUGAL PUMPS (PC-3)****TABLE OF CONTENTS**

|                |   |           |
|----------------|---|-----------|
| <b>PART 1:</b> | <b>GENERAL .....</b>  | <b>4</b>  |
| 1.1            | <b>SECTION INCLUDES .....</b>   | <b>4</b>  |
| 1.1.1          | <b>Definitions .....</b>  | <b>4</b>  |
| 1.2            | <b>RELATED SECTIONS AND DOCUMENTS.....</b>                                      | <b>4</b>  |
| 1.3            | <b>REFERENCES .....</b>   | <b>5</b>  |
| 1.3.1          | <b>American Petroleum Institute (API) .....</b>                                 | <b>5</b>  |
| 1.3.2          | <b>American Society of Civil Engineers (ASCE).....</b>                          | <b>5</b>  |
| 1.3.3          | <b>American Society of Mechanical Engineers (ASME) .....</b>                    | <b>5</b>  |
| 1.3.4          | <b>American Welding Society (AWS).....</b>                                      | <b>5</b>  |
| 1.3.5          | <b>Code of Federal Regulations (CFR).....</b>                                   | <b>5</b>  |
| 1.3.6          | <b>American National Standards Institute/Hydraulic Institute (ANSI/HI).....</b> | <b>5</b>  |
| 1.3.7          | <b>Institute of Electrical and Electronics Engineers (IEEE).....</b>            | <b>6</b>  |
| 1.3.8          | <b>National Electrical Manufacturers Association (NEMA).....</b>                | <b>6</b>  |
| 1.3.9          | <b>National Fire Protection Association (NFPA).....</b>                         | <b>6</b>  |
| 1.3.10         | <b>U.S. Department of Energy (DOE) .....</b>                                    | <b>6</b>  |
| 1.4            | <b>QUALITY ASSURANCE.....</b>   | <b>6</b>  |
| 1.5            | <b>SUBMITTALS.....</b>  | <b>6</b>  |
| 1.5.1          | <b>Drawings.....</b>  | <b>6</b>  |
| 1.5.2          | <b>Calculations.....</b>  | <b>6</b>  |
| 1.5.3          | <b>Reports .....</b>  | <b>6</b>  |
| 1.5.4          | <b>Spare Parts Data.....</b>  | <b>7</b>  |
| 1.5.5          | <b>Operation and Maintenance Manuals.....</b>                                   | <b>7</b>  |
| 1.5.6          | <b>Seismic Qualification Report.....</b>  | <b>7</b>  |
| <b>PART 2:</b> | <b>PRODUCTS .....</b>   | <b>8</b>  |
| 2.1            | <b>GENERAL REQUIREMENTS .....</b>   | <b>8</b>  |
| 2.2            | <b>TECHNICAL REQUIREMENTS.....</b>  | <b>8</b>  |
| 2.2.1          | <b>General .....</b>  | <b>8</b>  |
| 2.2.2          | <b>Capacities .....</b>   | <b>9</b>  |
| 2.2.3          | <b>Net Positive Suction Head.....</b>   | <b>9</b>  |
| 2.2.4          | <b>Seismic Design.....</b>  | <b>9</b>  |
| 2.3            | <b>MATERIALS AND EQUIPMENT .....</b>  | <b>9</b>  |
| 2.3.1          | <b>General .....</b>  | <b>9</b>  |
| 2.3.2          | <b>Pump Drivers.....</b>  | <b>10</b> |
| 2.3.3          | <b>Couplings and Guards .....</b>   | <b>10</b> |
| 2.3.4          | <b>Baseplates .....</b>   | <b>10</b> |
| 2.3.5          | <b>Auxiliary Piping.....</b>  | <b>10</b> |
| 2.3.6          | <b>Anchor Bolts .....</b>   | <b>11</b> |
| 2.3.7          | <b>Flanges.....</b>   | <b>11</b> |
| 2.3.8          | <b>Gaskets and O-Rings.....</b>   | <b>11</b> |
| 2.3.9          | <b>Shaft Sealing Flush Plans.....</b>   | <b>11</b> |
| 2.3.10         | <b>Pump Casing.....</b>   | <b>11</b> |

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 3 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

|                |  |           |
|----------------|--|-----------|
|                | <b>2.3.11 Bolting.....</b>                               | <b>12</b> |
|                | <b>2.3.12 Nozzles and Miscellaneous Connections.....</b> | <b>12</b> |
|                | <b>2.3.13 Rotating Elements .....</b>                    | <b>12</b> |
|                | <b>2.3.14 Bearings.....</b>                              | <b>12</b> |
|                | <b>2.3.15 Sealing Devices.....</b>                       | <b>13</b> |
|                | <b>2.3.16 Nameplate.....</b>                             | <b>13</b> |
| <b>PART 3:</b> | <b>EXECUTION.....</b>                                    | <b>13</b> |
| <b>3.1</b>     | <b>FABRICATION.....</b>                                  | <b>13</b> |
|                | <b>3.1.1 Welding.....</b>                                | <b>14</b> |
|                | <b>3.1.2 Positive Material Identification.....</b>       | <b>14</b> |
|                | <b>3.1.3 Painting.....</b>                               | <b>14</b> |
|                | <b>3.1.4 Assembly.....</b>                               | <b>14</b> |
| <b>3.2</b>     | <b>TESTING AND INSPECTION.....</b>                       | <b>14</b> |
| <b>3.3</b>     | <b>PACKAGING, SHIPPING, AND STORAGE.....</b>             | <b>14</b> |

**INDEX OF TABLES**

|   |           |
|---|-----------|
| <b>Table 1 – Nameplate Information.....</b> | <b>13</b> |
|---|-----------|

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 4 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

**PART 1: GENERAL**

**1.1 SECTION INCLUDES**

- A. This section covers the minimum requirements for the mechanical design, materials, fabrication, testing, inspection and preparation for shipment of Seismic Performance Category 3 (PC-3) centrifugal pumps to be installed in the Salt Waste Processing Facility (SWPF).
- B. This section is supplemented by pump data sheets, which may indicate specific design conditions in addition to the requirements of this section. If the SUPPLIER's interpretation presents a conflict among this section, the equipment data sheets, standards, or supplemental sections, the SUPPLIER shall contact the BUYER and obtain a written clarification before proceeding with work affected by the conflict.

**1.1.1 Definitions**

- A. Approval (and approved) shall be understood as written approval (approved in writing by the BUYER).
- B. Approved equal shall be a substitution to the specified product and be approved in writing by the BUYER. A manufacturer's name or figure number specified in an individual item description is only a reference; an approved-equal substitution may be made, subject to the BUYER's written approval.
- C. BUYER: Parsons SWPF project.
- D. Contract documents shall be the purchase order along with its attachments and references.
- E. SUPPLIER: Any individual or organization who furnishes items or services in accordance with a procurement document. An all-inclusive term used in place of any of the following: vendor, seller, contractor, subcontractor, fabricator, consultant, and their sub-tier levels.
- F. Performance Category (PC): In accordance with DOE G420.1-2, a classification using a graded approach in which structures, systems, or components in a category are designed to ensure similar levels of protection (i.e., meet the same performance goal and damage consequences) during natural phenomena hazard events.

**1.2 RELATED SECTIONS AND DOCUMENTS**

- A. The sections/specifications and/or other documents listed herein form a part of this document to the extent specified. In the event of a conflict between the referenced section/document and the contents of this document, the BUYER shall be notified to resolve the conflict prior to proceeding with items or services affected by the conflict.
  - 1. Section 01300 – Supplier Submittals
  - 2. Section 01610 – Packaging, Shipping, and Storage of Items
  - 3. Section 11817 – Positive Material Identification
  - 4. Section 11822 – Seismic Qualification Criteria for PC-3 Pumps
  - 5. Section 15120 – Piping Material Specification

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 5 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

1.3 REFERENCES

- A. The codes and standards/documents listed herein form a part of this section. In the event of a conflict between the referenced item and the contents of this section, the BUYER shall be notified to resolve the conflict prior to proceeding with items or services affected by the conflict. Unless otherwise specified, use the latest edition of a referenced item.

1.3.1 American Petroleum Institute (API)

- A. API-682-2002, Pumps – Shaft Sealing systems for Centrifugal and Rotary Pumps

1.3.2 American Society of Civil Engineers (ASCE)

- A. ASCE 4-98, *Seismic Analysis of Safety-Related Nuclear Structures, 2000*
- B. ASCE 7-02, *Minimum Design Loads for Buildings and Other Structures, 2002*

1.3.3 American Society of Mechanical Engineers (ASME)

- A. ASME B 1.1–1989, *Unified Inch Screw Threads (UN and UNR Thread Form)*
- B. ASME B16.5–1996 (A1998), *Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24*
- C. ASME B16.11–1996, *Forged Fittings, Socket-Welding and Threaded*
- D. ASME B1.20.1–1983 (A1992), *Pipe Threads, General Purpose (Inch)*
- E. ASME B31.3–2002, *Process Piping*
- F. ASME B73.1–2001, *Specification for Horizontal End Suction Centrifugal Pumps for Chemical Process*
- G. ASME B73.2M–1991, *Vertical In-Line Centrifugal Pumps for Chemical Process*
- H. 2004 ASME Boiler and Pressure Vessel Code, Section VIII: Division 1, *Rules for Construction of Pressure Vessels*
- I. 2004 ASME Boiler and Pressure Vessel Code, Section IX: *Welding and Brazing Qualifications*

1.3.4 American Welding Society (AWS)

- A. AWS D1.1–2004, *Structural Welding Code – Steel*
- B. AWS D1.6–1999, *Structural Welding Code – Stainless Steel*

1.3.5 Code of Federal Regulations (CFR)

- A. 29 CFR 1910, *Occupational Safety and Health Standards, 2004*
- B. 29 CFR 1910.95, *Occupational Safety and Health Standards, Occupational Noise Exposure, 2004*

1.3.6 American National Standards Institute/Hydraulic Institute (ANSI/HI)

- A. ANSI/HI 9.6.1 – 1998, American National Standard for Centrifugal and Vertical Pumps
- B. ANSI/HI 9.6.2 – 2001, American National Standard for Centrifugal and Vertical Pumps for Allowable Nozzle Loads

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 6 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

1.3.7 Institute of Electrical and Electronics Engineers (IEEE)

- A. IEEE 841-2001, *Standard for Petroleum and Chemical Industry - Severe Duty Totally Enclosed Fan-Cooled (TEFC) Squirrel Cage Induction Motors - Up to and Including 370 kW (500 hp)*

1.3.8 National Electrical Manufacturers Association (NEMA)

- A. NEMA MG1-1998, Chg: w/Rev. 3, 2002, *Motors and Generators*

1.3.9 National Fire Protection Association (NFPA)

- A. NFPA 70-2005, *National Electrical Code (NEC)*

1.3.10 U.S. Department of Energy (DOE)

- A. DOE G 420.1-2, *Guide for the Mitigation of Natural Phenomena Hazards for DOE Facilities and Nonnuclear Facilities, 2000*

1.4 QUALITY ASSURANCE

- A. Quality Assurance requirements are specified in the contract documents.

1.5 SUBMITTALS

- A. SUPPLIER shall submit to the BUYER documents shown in Section III of the Material Requisition/PO in accordance with Section 01300.

- B. The SUPPLIER will be required to submit detailed design, fabrication and testing documentation sufficient to verify the adequacy and compliance of design, fabrication methods and testing procedures and results.

1.5.1 Drawings

- A. The SUPPLIER shall submit shop drawings to the BUYER for approval.

1. Shop drawings shall consist of outline drawings, parts lists, schedules, performance charts, installation instructions, brochures, diagrams, and other information to illustrate equipment, piping, wiring, and related components.
2. The shop drawings shall indicate clearance requirements and weights.

1.5.2 Calculations

- A. Seismic qualification shall be provided for pump baseplate and anchorage as detailed in ASCE 4.
- B. Calculations shall bear the signature and seal of a professional engineer.

1.5.3 Reports

- A. Certified performance curves shall be provided depicting pump capacity, total discharge head (TDH), differential pressure, net positive suction head required (NPSHR), and efficiency. These performance curves shall provide such information as necessary to determine compliance to the specified and indicated requirements and shall include minimum capacity for stable operation of each pump.

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 7 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

- B. Factory testing and test reports, including hydro pressure test report and noise level test report, shall be submitted for approval to the BUYER.
- C. Mill test reports for pressure containing parts, and certificate of material compliance, shall be submitted.
- D. Welding procedure specifications (WPS), procedure qualification reports (PQR), and weld repair procedures shall be submitted to the BUYER for approval before any welding is performed. SUPPLIER shall also provide welder performance qualification test records to the BUYER for information and records.
- E. All required data for materials subject to positive material identification (PMI) shall be documented and submitted in accordance with Section 11817.
- F. Pump and motor shaft actual alignment reading and pump assembly actual clearance readings shall be submitted to the BUYER.

**1.5.4 Spare Parts Data**

- A. After approval of the shop drawings, the SUPPLIER shall furnish recommended spare parts data for each different item of materials and equipment specified. The data shall include a complete list of recommended parts and supplies, with current unit prices and source of supplies.

**1.5.5 Operation and Maintenance Manuals**

- A. The SUPPLIER shall furnish to the BUYER for concurrence, complete copies of operating instructions outlining the step-by-step procedures required for pump startup, operation, and shutdown. The instructions shall include the manufacturer's name, model number, service manual, parts list, and brief description of all items of equipment and their basic operating features.
- B. The SUPPLIER shall furnish to the BUYER for concurrence, complete copies of maintenance instructions listing routine maintenance procedures, recommended lubricants, and standard materials for nonmetallic parts typically consumed during operation or maintenance, possible breakdowns and repairs, and troubleshooting guides.

**1.5.6 Seismic Qualification Report**

- A. The SUPPLIER shall submit an outline of the proposed methods and procedures for seismic qualification of the equipment in accordance with Section 11822.
- B. The SUPPLIER shall submit a seismic qualification report. The submittal shall include support reactions at equipment supports for the design of anchorage and displacement of nozzles due to seismic and concurrent loadings.

|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 8 of 14 |

### CENTRIFUGAL PUMPS (PC-3)

#### **PART 2: PRODUCTS**

##### **2.1 GENERAL REQUIREMENTS**

- A. The equipment SUPPLIER shall offer standard equipment, where possible, to fulfill the requirements stated in this section, on the design drawings and data sheets. The SUPPLIER must identify any variations of the SUPPLIER's standard equipment from the stated requirements; otherwise it will be assumed that all equipment offered is in compliance.
- B. Material and equipment shall be a standard product of the SUPPLIER engaged in the manufacture of the products. Materials used shall be those proven by service in similar pump designs and for similar operating conditions.
- C. Pumps shall be suitable for operation at indicated temperature without vapor binding and without cavitation under entire range of system operating conditions. The only acceptable means of rectification of cavitation shall be the replacement of entire pump assembly.

##### **2.2 TECHNICAL REQUIREMENTS**

###### **2.2.1 General**

- A. Pumps shall conform to ASME B73.1. Each pump shall be a complete unit, including driver, coupling, shaft sealing with seal flush/cooling (when required), coupling guard, mounting base, finish coating, special features, and accessories as specified.
- B. When solids are present in the pumping fluid, as specified in the data sheet, a low shear pump design shall be provided.
- C. Unless otherwise specified in the data sheet, pump selection shall be based on an impeller design requiring not more than 90 percent of full impeller diameter to meet the specified operating conditions.
- D. When operating at rated conditions, the pump operating point is preferred to be within 10 percent of the best efficiency point flow as shown on the pump performance curve. The impeller shall have the characteristic of increasing head from rated capacity to shutoff.
- E. Pump operating speed shall not be greater than 70 percent of the first critical speed of the combined rotating elements at the specified maximum operating conditions.
- F. Pump units shall be capable of specified discharge capacities and heads when operating at the suction conditions, temperatures, specific gravities, and viscosities shown on the data sheet. Pump units shall not overload the drivers at any operating point along the head capacity curve from shutoff head to maximum capacity for the impeller provided. At rated conditions and at maximum horsepower along the pump curve, the horsepower requirements shall not exceed the rating of the driver nameplate horsepower.
- G. Pumps with the same rating and service shall be identical. Component parts of the same end function shall be interchangeable.
- H. Maximum noise level shall be 85 dBA at a distance of 3 feet from the equipment, as detailed in 29 CFR 1910.95, Occupation Noise Exposure, unless otherwise specified in the data sheets.



|                       |            |                |     |          |         |
|-----------------------|------------|----------------|-----|----------|---------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet   |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 9 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

2.2.2 Capacities

- A. Capacities of pumps shall be not less than those specified on the data sheets. No additional capacity margin need be added.

2.2.3 Net Positive Suction Head

- A. There should be no less than a 25 percent margin between net positive suction head available and net positive suction head required at the maximum sustained capacity.

2.2.4 Seismic Design

- A. The pump supporting structure and anchorages shall be designed to withstand seismic loads. Seismic calculations shall be performed per ASCE 4, Importance Factor I per Section 11822.
- B. These calculations shall incorporate any allowable nozzle loads imposed by piping connections.

2.3 MATERIALS AND EQUIPMENT

2.3.1 General

- A. All pressure containing parts of pumps shall be fabricated and inspected in accordance with ANSI/HI, ASME and other industry standards for heavy-duty rugged construction.
- B. Maximum interchangeability of pump components is desired among similar pump designs. Parts in identical pump designs shall be completely interchangeable.
- C. Each pump and motor combination shall include all external piping, when required for cooling or flushing, and base for each pump and driver.
- D. The equipment furnished shall be a complete package of components required to develop the performance conditions described in this section. The design of the equipment shall be heavy duty, suitable for intermittent or continuous operation at the minimum and maximum capabilities of the furnished pump.
- E. Environmental conditions and seismic design requirements shall be in accordance with the data sheet requirements.
- F. The materials shall be new and conform as specified on the BUYER's equipment data sheets, or as specified in this section. Any alternates or deviations shall be specifically approved by the BUYER.
- G. Castings used for any part of pumps shall be sound and free of shrink or blowholes, scale blisters, and other casting defects. The materials used shall be those proven by service in similar pump designs and for similar operating conditions. The SUPPLIER shall maintain certifications of material compliance for the specific pumps being furnished in their files.
- H. Pressure containing parts shall be repaired only if permitted by the material specification. No repair of defects by peening or impregnation shall be permitted for any castings.
- I. Products which contain asbestos are prohibited. This prohibition includes items such as packing or gaskets even though the item is encapsulated or the asbestos fibers are impregnated with binder material.

|                       |            |                |     |          |          |
|-----------------------|------------|----------------|-----|----------|----------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet    |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 10 of 14 |

### CENTRIFUGAL PUMPS (PC-3)

#### 2.3.2 Pump Drivers

- A. All motors shall be a minimum totally enclosed, fan cooled, severe duty with integral horsepower NEMA frames and shall meet requirements of IEEE 841.
- B. Electric motor drivers shall conform to NEMA MG1. Motors shall be sized to be non-overloading over the entire pump operating range.
- C. Pump motors located in hazardous areas shall be suitable for use in those areas as shown on the pump data sheet.
- D. Motors used with variable frequency drives (VFDs), as specified on the data sheets, shall be inverter duty rated. All ratings, characteristics and features shall be coordinated with, and approved by, the VFD manufacturer.
- E. Inverter duty motors shall be provided with Class H insulation (NEC), with Class B temperature rise characteristics or better (NEC).
- F. Motors furnished shall be rated to produce the required torque at the maximum operating condition specified on the data sheet.

#### 2.3.3 Couplings and Guards

- A. Couplings shall be of the flexible-spacer type, keyed and locked to the shaft. Disconnecting the couplings shall be accomplished without removing the driver of the pump from the shaft.
- B. A normal service factor rating of 1.5 shall be applied to all couplings.
- C. All moving or rotating parts of equipment, i.e. motors, couplings, etc., shall be provided with guards, in accordance with 29 CFR 1910, guidelines.

#### 2.3.4 Baseplates

- A. Fabricated baseplate with full drip rim and drain shall be furnished and shall have a raised lip. Connections for drains shall be tapped in the raised lip at the pump end. The pan or upper surface of the baseplate shall be sloped toward the drain end of the pan. Unless otherwise specified on the data sheets, the baseplate shall be sized to accommodate the next size larger motor frame and shall extend under the pump and driver. Baseplate and pump supports shall be of rigid construction and shall be designed to minimize misalignment caused by mechanical forces such as normal piping strains, internal differential thermal expansion, and hydraulic piping thrust.

#### 2.3.5 Auxiliary Piping

- A. Auxiliary piping and tubing (per ASME B31.3), when furnished by the pump manufacturer, shall be securely supported to resist vibration and damage. Auxiliary tubing shall be heavy-wall steel per Section 15120, suitable for the service conditions (e.g. carbon steel or stainless steel, as required per data sheet). Connections in auxiliary systems shall be as specified on the data sheets. A means for disassembly (unions, flanges, connectors, etc.) shall be provided.

|                       |            |                |     |          |          |
|-----------------------|------------|----------------|-----|----------|----------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet    |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 11 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

2.3.6 Anchor Bolts

- A. Anchor bolts will be furnished and installed by the BUYER. SUPPLIER shall provide anchor bolt size, quantity and location. SUPPLIER shall also provide loadings on anchor bolts for anchorage design.

2.3.7 Flanges

- A. All flanges and flanged fittings shall be per ASME B16.5. Flange face finish shall be 125 to 250 arithmetic average roughness height, unless otherwise noted. All flanges shall conform to ASME standards for the pressures and temperatures involved.
- B. The thickness of the hub of a welding neck flange, where it is welded to the nozzle neck, shall not be less than that of the nozzle neck.
- C. Slip-on flanges, when used, shall be drilled and tapped through the hub for air and soapsuds testing of attaching fillet welds.
- D. When specified on the data sheet, flanges 2 inches and smaller shall be 300 pound minimum flange rating. Larger nozzles shall be 150 pound flange rating or rating based on temperature/pressure requirements.

2.3.8 Gaskets and O-Rings

- A. Gasket and O-Ring type and material shall be as required by the pump data sheet or per the manufacturer's standard suitable for the application. Gaskets and O-Rings used for the shop hydrotest shall be of the same type as used for operation and shall be replaced before shipment with new gaskets and O-Rings.
- B. Gaskets and O-Rings used on units located in the North ASP Pump and Valve Gallery, the South ASP Pump and Valve Gallery, and the CSSX Pump and Valve Gallery areas of the facilities, as identified on the data sheets, shall be selected to withstand radiation exposure of a minimum of  $10^7$  rad (radiation absorbed dose).

2.3.9 Shaft Sealing Flush Plans

- A. All pumps shall be provided with shaft sealing provisions suitable for the service application. Flush plan selection shall be in accordance with the data sheets. All seal flush accessories and auxiliary piping shall be in accordance with API standard 682.
- B. All parts of the seal flush assemblies shall be shop hydrostatically tested and furnished assembled with the pump for shipment.

2.3.10 Pump Casing

- A. Under maximum suction pressure condition, maximum allowable casing working pressure shall exceed maximum discharge pressure by 10 percent, or 15 psi, whichever is greater.
- B. Unless otherwise specified in the data sheet, pump casings shall be top discharge design with horizontal-end suction, foot mounting, and shall be self venting with fully confined gasket. A casing drain shall be incorporated into the design.

|                       |            |                |     |          |          |
|-----------------------|------------|----------------|-----|----------|----------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet    |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 12 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

2.3.11 Bolting

- A. Threading shall conform to ASME B1.1.
- B. Bolted piping connections shall be through-bolted. Internal connections may use tapped connections for studs.
- C. Bolt length shall be kept to a minimum for easy removal. Metal washers shall be used under all nuts and bolt heads. Bolting shall be long enough to assure full thread engagement of the nut.

2.3.12 Nozzles and Miscellaneous Connections

- A. In general, suction and discharge nozzle connections should be provided with flanged or welded connections as indicated on the data sheet. Threaded pipe connections shall not be used for pumps handling acid or agent solutions unless approved by the BUYER.
- B. Pipe threads shall be taper pipe threads in conformance with ASME B1.20.1. Tapped openings and bosses for pipe threads shall conform to ASME B16.5.
- C. Flanges shall conform to ASME B16.5 and shall be as specified in the data sheets. All flanges shall conform to ASME standards for the pressures and temperatures involved. The back surface of all flanges shall be full or spot-faced at the bolt circle. The suction nozzle flanges (ratings) shall be designed for the same pressure as the discharge flange. Allowable flange loading shall be provided.
- D. Casing vent connections shall be provided if the pump is not self-venting. Casing drain connections shall also be provided. Vent and drain connections shall be tapped, where permissible, for taper pipe threads.

2.3.13 Rotating Elements

- A. Impellers shall be either fully open or enclosed single-piece castings and shall be positively secured to the pump shaft and keyed wherever practicable. Securing devices shall be threaded to tighten during normal rotation.
- B. Shafts shall be sized for maximum torque required under any specified operating conditions. Shafts shall be provided with sleeves locked or clamped to the shaft when mechanical seals are used. The sleeves shall be of material resistant to wear, corrosion and erosion. Sleeves shall extend beyond packing or mechanical seal face. Sleeves shall be ground and polished on outside surfaces. Sleeves exposed to packing will be hard-faced to a surface hardness of 600 Brinell hardness number minimum.

2.3.14 Bearings

- A. Bearing frames shall be oversized, heavy cast construction. Where specified oil reservoir with water jacket shall be provided. The radial bearing shall be single row and inboard mounted. The thrust bearings shall be double row, shouldered, and mounted outboard. Vented sight glass level indication shall be provided for each pump when oil reservoirs are provided.
- B. Bearing lubrication shall be oil bath type with constant level oil feed regulator as per ASME B15.1, section 4.7.5, unless indicated otherwise on the data sheet.

|                       |            |                |     |          |          |
|-----------------------|------------|----------------|-----|----------|----------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet    |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 13 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

2.3.15 Sealing Devices

- A. When required, each pump shall be fitted with a complete seal flush system including all parts required to cool and flush the working part of the seal assembly as specified on the data sheet. Where no seal plan is specified on the data sheet, SUPPLIER shall provide a suitable seal flush plan.
- B. Stuffing boxes shall be designed for use with mechanical seals or packing with little modification. Ample space shall be provided for replacement of packing without removing or dismantling any part other than the packing gland. Auxiliary sealing devices, such as throttle bushings, shall be applied to prevent massive escape of fluid if the primary sealing device fails. When auxiliary packing is used as a secondary sealing device, a tapped opening shall be provided to detect primary seal leakage. Throttle bushings shall be of a non-sparking material.
- C. Shaft sealing devices shall be designed to operate satisfactorily under a full range of pump operating conditions, including maximum discharge pressure, except where such requirement is impracticable. Hydraulically balanced mechanical seals shall be provided, as required, considering fluid specific gravity and lubricating properties at stuffing box temperature, seal diameter, rotating speed, and sealing pressure. Mechanical seals shall be cartridge type unless indicated otherwise on the data sheets. Instruments required for the seal system, if any, shall also be furnished by SUPPLIER.

2.3.16 Nameplate

- A. Equipment supplied under this section shall have a stainless steel nameplate, permanently attached to the equipment at an easily readable location. The nameplate shall be stamped or engraved as a minimum with the information shown in Table 1. Equipment tag numbers shall be as specified on the data sheets.
- B. Nameplate letter heights shall be as shown in Table 1 except where the size of the equipment is too small, in which case the SUPPLIER shall propose the nameplate letter size to the BUYER.

**Table 1 – Nameplate Information**

| Information           | Minimum Letter Height |
|-----------------------|-----------------------|
| Item Description      | 1/8 inch              |
| Item/Tag Number       | 1/2 inch              |
| Supplier's Name       | 1/8 inch              |
| Purchase Order Number | 1/8 inch              |
| Date of Manufacture   | 1/2 inch              |

**PART 3: EXECUTION**

3.1 FABRICATION

- A. The following fabrication requirements shall be complied with unless otherwise specified on the BUYER's design drawings or data sheets.

|                       |            |                |     |          |          |
|-----------------------|------------|----------------|-----|----------|----------|
| <b>PARSONS</b>        | Job Number | Section Number | Rev | Date     | Sheet    |
| Specification Section | 745253     | 11825          | 0   | 12/10/07 | 14 of 14 |

**CENTRIFUGAL PUMPS (PC-3)**

3.1.1 Welding

- A. All welding shall be in accordance with ASME Section IX and ASME B31.3. Structural welding for carbon steel shall be in accordance with AWS D1.1. Structural welding for stainless steel shall be in accordance with AWS D1.6.
- B. Welding repairs shall not be performed without the written approval of the BUYER.

3.1.2 Positive Material Identification

- A. The alloy content of all drive shafts, pressure boundary materials, welding rods, welding wire and welds of alloy materials shall be verified in accordance with Section 11817.

3.1.3 Painting

- A. All equipment and components shall be painted per the manufacturer's standard. Paint shall be suitable for a radiation environment and decontamination wash down. Use of the standards from the Society for Protective Coatings (SSPC) is recommended for surface preparation, selection and application of paint. Stainless steel surfaces shall not be painted.

3.1.4 Assembly

- A. All equipment and associated instruments, controls, piping and valving for the pump assembly shall be skid mounted. Lifting lugs shall be provided on the skids.

3.2 TESTING AND INSPECTION

- A. All pump units shall be factory tested for hydrostatic integrity and mechanical operability in accordance with ASME B73.1 and ANSI/HI standards. If adjustable speed equipment is provided, the working range of the pump shall be demonstrated, recorded, and submitted for approval. Upon completion of such tests, a visual inspection of critical sealing and mechanical parts shall be performed.
- B. All pump units shall be tested for noise level and test results shall be provided.

3.3 PACKAGING, SHIPPING, AND STORAGE

- A. Packaging, shipping, and storage shall be per Section 01610, Level C.

END OF SECTION

**PARSONS**  
Calculation Cover Sheet

|   |  |  |
|---|--|--|
| <b>Project:</b><br>Salt Waste Processing Facility (SWPF)                    | <b>Calculation No.:</b><br>M-CLC-J-00013 | <b>Project Number:</b><br>744910   |
| <b>Title:</b><br>Strip Effluent Transfer Pumps Sizing Calculation, P-205A/B | <b>Functional Classification</b><br>SS   | Sheet 1 of 30  |
| <b>Security Classification:</b><br>Unclassified                             | <b>Discipline:</b><br>Mechanical/Process | <input checked="" type="checkbox"/> Preliminary <input type="checkbox"/> Confirmed |
| <b>Computer Program:</b> <input checked="" type="checkbox"/> N/A            | <b>Version / Release No.</b><br>N/A      |  |

**Purpose and Objective:**  
The purpose of this calculation is to evaluate the design criteria for the Strip Effluent Transfer Pumps, P-205A/B.  
  
The objective of this calculation is to size the pumps P-205A/B.

**Summary of Conclusion:**

The pump will need to be sized for the following design points:

**Tank Mixing:**

The design point is 300 gpm and 121 ft TDH. Estimated required brake horse power is 18.34 hp.

**Transfer:**

The design point is 150 gpm and 221 ft TDH. Estimated required brake horse power is 16.74 hp.

**Revisions**

| Rev. No. | Revision Description -                          |
|----------|---|
| A        | Issued for Preliminary Design 30% Design Review |
| B        | Issued for Enhanced Preliminary Design          |
|          |   |

**Sign Off**

| Rev. No. | Originator (Print)<br>Sign / Date | Verification /<br>Checking Method | Verifier / Checker<br>(Print)<br>Sign / Date | Technical Specialist<br>/ Lead Discipline<br>Engineer (Print)<br>Sign / Date |
|----------|-----------------------------------|-----------------------------------|--|--|
| A        | Kyle Bray                         | Independent Review/<br>Math Check | Donna Yarbrough                              | Kevin Bartling   |
|          | 12/13/2004                        |                                   | 12/14/2004                                   | 12/16/2004   |
| B        | Nicholas DesRocher                | Independent Review/<br>Math Check | Donna Yarbrough                              | Cliff Conner   |
|          | <i>Nicholas DesRocher</i> 4/12/06 |                                   | <i>Donna Yarbrough</i> 4-12-06               | <i>Cliff Conner</i> 4/12/06  |
|          |                                   |                                   |  |  |

| This Document Affected By |              |
|---------------------------|--------------|
| Design Change Document    | Initial/Date |
| DCR-0124                  | 5/23/07      |
|                           |              |
|                           |              |
|                           |              |
|                           |              |

# Calculation Continuation Sheet

Sheet No. 2 of 30

|  |   |            |                 |            |                                   |              |           |                 |         |
|--|---|------------|-----------------|------------|-----------------------------------|--------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      |            |                 |            | Calculation No.<br>M-CLC-J- 00013 |              |           |                 |         |
|  | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |            |                 |            |                                   |              |           |                 |         |
| Rev  | Originator  | Date       | Checker         | Date       | Rev                               | Originator   | Date      | Checker         | Date    |
| A  | Kyle Bray   | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B                                 | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

### Table of Contents

|   | Sheet |
|---|-------|
| <b>1.0 Purpose and Objectives</b>                               | 3     |
| <b>2.0 Open Items</b>   | 3     |
| <b>3.0 References</b>   | 5     |
| <b>4.0 Input Data</b>   | 6     |
| <b>5.0 Design Basis</b>   | 7     |
| <b>6.0 Codes and Standards</b>                                  | 8     |
| <b>7.0 Calculations</b>   | 9     |
| <b>8.0 Results</b>  | 16    |
| <b>9.0 Conclusions</b>  | 17    |
| <b>10.0 Notes</b>   | 17    |
| <b>11.0 Attachments</b>   | 17    |
| 11.1 Pump Suction Line Loss Calculation, Tank Mixing            | 18    |
| 11.2 Pump Discharge Line Loss Calculation, Tank Mixing          | 19    |
| 11.3 Pump Suction Line Loss Calculation, Transfer               | 20    |
| 11.4 Pump Discharge Line Loss Calculation, Transfer, 4" section | 21    |
| 11.5 Pump Discharge Line Loss Calculation, Transfer, 3" section | 22    |
| 11.6 Pump Calculation Data Sheet                                | 23    |
| 11.7 Xomox Valve Data   | 26    |



# Calculation Continuation Sheet

Sheet No. 3 of 30

|  |   |            |                 |            |                                   |              |           |                 |         |
|--|---|------------|-----------------|------------|-----------------------------------|--------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      |            |                 |            | Calculation No.<br>M-CLC-J- 00013 |              |           |                 |         |
|  | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |            |                 |            |                                   |              |           |                 |         |
| Rev  | Originator  | Date       | Checker         | Date       | Rev                               | Originator   | Date      | Checker         | Date    |
| A  | Kyle Bray   | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B                                 | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

**1.0 Purpose and Objectives**

The purpose of this calculation is to evaluate the design criteria for the Strip Effluent Transfer Pumps, P-205A/B.

The objective of this calculation is to size the pumps P-205A/B.

**2.0 Open Items**

- 2.1 The viscosity of the pumped fluid is assumed to be equal to the viscosity of 0.001M nitric acid at 77°F, ~0.9 cP (Ref 3.15). This is a bounding assumption that does not require verification.
- 2.2 Line lengths, configuration of piping, components and elevations are assumed based on preliminary General Arrangements. They will be confirmed once the isometrics are complete.
- 2.3 Vessel Vent setting is 14.56 psia based on preliminary design. This will be confirmed once the PVV System design is complete.
- 2.4 Piping for the entire system is PS200C. For line sizes < 6", this piping is Schedule 40S. This will be verified when the pipe spec is issued Rev. 0.
- 2.5 The vapor pressure of the fluid is assumed equal to water at 77°F, which is the normal operating fluid temperature. This is a bounding assumption that does not require verification as the design proceeds.
- 2.6 The delivery pressure is assumed to be 0 psig at the SEFT in DWPF. Since the Strip Effluent Feed Tank in DWPF is maintained at a slight vacuum, this assumption is conservative and does not require verification.
- 2.7 The pump centerline is assumed to be 4 ft 4 inches above the floor. This will be confirmed when piping isometrics are complete.
- 2.8 The pressure drop from the flow meter is estimated to be 1 psi. This will be confirmed when a vendor is selected.
- 2.9 The tank bottom elevation is assumed to be 9" from the floor and the heel height is assumed to be 2x the nominal suction pipe diameter (4") from the bottom of the tank. This comprises the tank low low level. This will be confirmed when the tank data sheet is issued Rev. 0.

# Calculation Continuation Sheet

Sheet No. 4 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

2.10 It is assumed that highest pipe elevation is 30 ft for tank mixing and for discharge to DWPF, from the floor elevation. This will be confirmed when piping isometrics are complete.

2.11 It is assumed that the bottom of the source tank overflow is located 20 ft from the floor elevation. This will be confirmed when piping isometrics are complete.

2.12 These pumps are used for three purposes: to mix TK-205, to transfer strip effluent to DWPF, and to flush out the sludge transfer line to DWPF. For flushing out the sludge line, P-104-1 is assumed to be used to aid in transfer, so that case will not be modeled. The other two cases will be modeled, and the results for both will be listed in order to find an appropriate pump.

2.13 The discharge length to DWPF is assumed to be 3,000 ft from the Waste Transfer Enclosure. This will be confirmed when the piping isometrics are complete.

2.14 The pressure required at the eductor is assumed to be 20 psig. This will be verified when the eductor vendor is chosen. (Ref 3.14)

# Calculation Continuation Sheet

Sheet No. 5 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

**3.0 References**

3.1 P-DB-J-00001, Rev. E, SWPF Salt Waste Processing Facility Project Basis of Design

3.2 M-M5-J-0008, Rev. 1, SWPF Solvent Stripping and Caustic Wash PFD

3.3 M-M6-J-0033, Rev. G, SWPF Process Building Strip Effluent Transfer Pumps P-205A/B P&ID

3.4 M-M6-J-0032, Rev. G, SWPF Process Building Strip Effluent Hold Tank TK-205 P&ID

3.5 DSG-MP-03, Parsons Engineering Department Design Guide: Pump Head Calculations

3.6 Peters, Elementary Chemical Engineering, McGraw Hill, 1954

3.7 M-CLC-J-00033, Rev. C, Strip Effluent Hold Tank Sizing Calculation, TK-205

3.8 M-M6-J-0002, Rev. G, SWPF Process Building Waste Transfer Enclosure P&ID

3.9 Crane, Flow of Fluids through Valves, Fittings and Pipe, Technical Paper No. 410

3.10 WSRC-TR-2003-00471, Rev. 0, MST/Sludge Agitation Studies for Actinide Removal Process & DWPF

3.11 Cameron Hydraulic Data, 19<sup>th</sup> edition

3.12 P-PG-J-0003, Rev. G2, SWPF Process Building General Arrangement Central Processing Area Plan at Elevation 92'-0" and 100'-0"

3.13 M-CLC-J-00008, Rev. B, SWPF Washing Filter Feed/Sludge Solids Transfer Pump Sizing Calculation, P-104-1

3.14 M-CLC-J-00074, Rev. A, SWPF Tank Eductors Sizing Calculation

3.15 Lauterbach Verfahrenstechnik Properties Program, Version 8.3 (0002)

3.16 M-CLC-J-00074, Rev. A, Tank Eductors Sizing Calculation

# Calculation Continuation Sheet

Sheet No. 6 of 30

|  |   |            |                 |            |     |                                   |           |                 |         |
|--|---|------------|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      |            |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |            |                 |            |     |                                   |           |                 |         |
| Rev  | Originator  | Date       | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray   | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

## 4.0 Input Data

### 4.1 Fluid Properties:

|                         |      |      |  | Notes       |
|-------------------------|------|------|--|-------------|
| • Fluid: Strip Effluent |      |      |  | 3.1, p. 37  |
| • Operating Temperature | 77   | °F   |  | 3.2         |
| • Minimum Temperature   | 60   | °F   |  | 3.1, p. 107 |
| • Maximum Temperature   | 95   | °F   |  | 3.1, p. 107 |
| • Design Temperature    | 120  | °F   |  |             |
| • Viscosity             | 0.9  | cP   |  | 2.1         |
| • Percent Solids        | 0.0% |      |  |             |
| • Specific Gravity      | 1.00 |      |  | 3.2         |
| • Vapor Pressure        | 0.46 | psia |  | 2.5         |

### 4.2 Service Conditions

Radioactive liquid, no solids, tank mixing and periodic transfer out of the SWPF 3.1

### 4.3 Operating Conditions:

|  |                     |      |      |      |
|--|---------------------|------|------|------|
| • Normal Flow Rate, Tank Mixing        | 300                 | gpm  |      | 3.16 |
| • Overcapacity, All cases              | 0%                  |      |      |      |
| • Design Flow Rate, Tank Mixing        | 300                 | gpm  |      |      |
| • Design Flow at Max T,P, Tank Mixing  | 300                 | gpm  |      |      |
| • Normal Flow Rate, Transfer           | 150                 | gpm  |      | 3.2  |
| • Design Flow Rate, Transfer           | 150                 | gpm  |      |      |
| • Design Flow at Max T,P, Transfer     | 150                 | gpm  |      |      |
| • Source Pressure                      | 14.56               | psia |      | 2.3  |
| • Suction Static Head From Low Level   | -2.91               | ft   | 10.2 |      |
| • Delivery Pressure, EDT-205           | 34.7                | psia |      | 2.14 |
| • Delivery Pressure, DWPF              | 14.7                | psia |      | 2.6  |
| • Discharge Static Head                | 25.67               | ft   | 10.2 |      |
| • Control Valve CV                     | na                  |      |      |      |
| • Orifice Diameter                     | na                  |      |      |      |
| • Overplus                             | 10% or 5 psi (min.) |      |      | 3.5  |
| • Vessel PSV or Vent Setting           | 14.56               | psia |      | 2.3  |
| • High Level (maximum operating level) | 20                  | ft   | 10.1 | 2.11 |
| • Suction Static Head from High Level  | 15.67               | ft   | 10.2 |      |
| • Low Level                            | 1.42                | ft   | 10.1 | 2.9  |

# Calculation Continuation Sheet

Sheet No. 7 of 30

|  |            |   |                 |            |     |                                  |           |                 |         |
|--|------------|---|-----------------|------------|-----|----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J-00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                  |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                       | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                     | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|   |                                |                                |                                 |                                   |
|---|--------------------------------|--------------------------------|---------------------------------|-----------------------------------|
| <ul style="list-style-type: none"> <li>• Pump Centerline</li> <li>• Flow Meter Pressure Drop</li> <li>• Highest Pipe Elevation on Discharge Line</li> </ul> | <p>4.33</p> <p>1</p> <p>30</p> | <p>ft</p> <p>psi</p> <p>ft</p> | <p>10.1</p> <p></p> <p>10.1</p> | <p>2.7</p> <p>2.8</p> <p>2.10</p> |
|---|--------------------------------|--------------------------------|---------------------------------|-----------------------------------|

**5.0 Design Basis**

**5.1 General:**

This calculation will follow the Parsons Engineering Department Design Guide for Pump Head Calculations. Ref 3.5

Required pump head is calculated by determining the suction pressure taking into account line losses and static changes, and by determining required discharge pressure taking into account frictional and static change to the delivery point. NPSH, maximum system pressure, maximum suction pressure, and required horsepower are also calculated.

The misc. pressure drop is accounted for in the contingency added to the calculation in the form of overplus.

For pumps with multiple suction and/or discharges, all runs will be modeled, unless otherwise specified), and the most conservative cases will be used for the pump sizing.

**5.2 Definitions:** (see attachment 11.6 for clarification)

|                               |  |
|-------------------------------|--|
| Suction Static Head           | Level of fluid in source vessel to pump centerline   |
| Discharge Static Head         | Pump centerline to maximum discharge elevation       |
| NPSHA                         | Net positive suction head available                  |
| Suction Line Loss             | Friction loss from source vessel to pump suction     |
| Discharge Line Loss           | Friction loss from pump discharge to delivery vessel |
| Source Pressure               | Pressure in source vessel excluding static head      |
| Delivery Pressure             | Pressure at delivery point in delivery vessel        |
| Differential Pressure         | Discharge pressure minus the suction pressure        |
| Normal Flow                   | Required process design flow rate                    |
| Rated Flow                    | Normal flow plus overcapacity                        |
| Overcapacity                  | Percentage of normal flow                            |
| Total Differential Head (TDH) | Total discharge head minus total suction head        |

# Calculation Continuation Sheet

Sheet No. 8 of 30

|  |   |                                   |
|--|---|-----------------------------------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      | Calculation No.<br>M-CLC-J- 00013 |
|  | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                                   |

| Rev | Originator | Date       | Checker         | Date       | Rev | Originator   | Date      | Checker         | Date    |
|-----|------------|------------|-----------------|------------|-----|--------------|-----------|-----------------|---------|
| A   | Kyle Bray  | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|                             |   |
|-----------------------------|---|
| Overplus                    | Percentage of TDH or differential pressure                |
| Total Dynamic Pressure Drop | Sum of all dynamic pressure drops (Suction and Discharge) |
| Static Head                 | Discharge static head minus the suction static head       |

**5.3 Process Design Requirements:**

The pumps are supplied with VFDs and are designed to allow operation at two points within their operating envelope.

**6.0 Codes and Standards**

ASME B73.1, Specification for Horizontal End Suction Centrifugal Pumps for Chemical Process

# Calculation Continuation Sheet

Sheet No. 9 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

## 7.0 Calculations

### 7.1 Suction Pressure:

Suction Pressure = source pressure + the suction static head from low level - the suction line losses.

Source Pressure = 14.56 psia Sec 4.3

Suction Static Head from Low Level = -2.91 ft Sec 4.3

Convert Suction Static Head from feet of liquid to psi using Equation 7.1

$$P = SG \times \rho \times \left( \frac{g}{g_c} \right) \times h$$

where

$\rho$  = density of water = 62.4 lb<sub>m</sub>/ft<sup>3</sup>  
 $g$  = gravitational acceleration = 32.2 ft/s<sup>2</sup>  
 $g_c$  = universal constant = 32.2 (ft - lb<sub>m</sub>)/(lb<sub>f</sub> - s<sup>2</sup>)  
 1 ft<sup>2</sup> = 144 in<sup>2</sup>

$P = SG \times 0.433 \times h$  Eq. 7.1

$P = -1.26$  psi

Suction Line Loss = 7.21 psi (tank mixing) Att 11.1  
 = 1.84 psi (transfer) Att 11.3

Suction Pressure = 14.56 psia Source Pressure  
 Tank mixing + -1.26 psi Suction Static Head From Low Level  
 - 7.21 psi Suction Line loss  
 = 6.09 psia

Suction Pressure = 14.56 psia Source Pressure  
 Transfer + -1.26 psi Suction Static Head From Low Level  
 - 1.84 psi Suction Line loss  
 = 11.46 psia

# Calculation Continuation Sheet

|  |   |            |                 |            |     |              |                                   |                 |         |
|--|---|------------|-----------------|------------|-----|--------------|-----------------------------------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      |            |                 |            |     |              | Calculation No.<br>M-CLC-J- 00013 |                 |         |
|  | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |            |                 |            |     |              |                                   |                 |         |
| Rev  | Originator  | Date       | Checker         | Date       | Rev | Originator   | Date                              | Checker         | Date    |
| A  | Kyle Bray   | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006                         | Donna Yarbrough | 4-12-06 |

**7.2 Net Positive Suction Head Available (NPSHA):**

The Net Positive Suction Head Available = source pressure + the suction static head from low level - suction line loss - the fluid's vapor pressure

Suction Static Head From Low Level = -2.91 ft Sec 4.3

Suction Line Loss = 7.21 psi (tank mixing) Att 11.1  
 1.84 psi (transfer) Att 11.3

Convert Suction Line Loss from psi to feet of liquid rearranging Equation 7.1

$h = P / 0.433 / SG$  Eq. 7.2

h = 16.65 ft (tank mixing)

h = 4.25 ft (transfer)

Source Pressure = 14.56 psia Sec 4.3

Convert Source Pressure from psia to feet of liquid using Eq. 7.2

Source Pressure = 33.63 ft

Vapor Pressure = 0.46 psia Sec 4.1

Convert Vapor Pressure from psia to feet of liquid using Eq. 7.2

Vapor Pressure = 1.06 ft

|              |   |          |  |
|--------------|---|----------|--|
| <b>NPSHA</b> | = | -2.91 ft | Suction Static Head From Low level         |
| Tank Mixing  | - | 16.65 ft | Suction Line Loss in feet of liquid        |
|              | + | 33.63 ft | Source Pressure in terms of feet of liquid |
|              | - | 1.06 ft  | Vapor Pressure in terms of feet of liquid  |
|              |   | 13.01 ft |  |

|              |   |          |  |
|--------------|---|----------|--|
| <b>NPSHA</b> | = | -2.91 ft | Suction Static Head From Low level         |
| Transfer     | - | 4.25 ft  | Suction Line Loss in feet of liquid        |
|              | + | 33.63 ft | Source Pressure in terms of feet of liquid |
|              | - | 1.06 ft  | Vapor Pressure in terms of feet of liquid  |
|              |   | 25.41 ft |  |



# Calculation Continuation Sheet

Sheet No. 11 of 30

|  |                         |   |                            |                    |          |                                   |                   |                            |                 |
|--|-------------------------|---|----------------------------|--------------------|----------|-----------------------------------|-------------------|----------------------------|-----------------|
| <b>PARSONS</b><br>Engineering<br>Calculation |                         | Project: Salt Waste Processing Facility (SWPF)                      |                            |                    |          | Calculation No.<br>M-CLC-J- 00013 |                   |                            |                 |
|  |                         | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                            |                    |          |                                   |                   |                            |                 |
| Rev<br>A                                     | Originator<br>Kyle Bray | Date<br>12/13/2004  | Checker<br>Donna Yarbrough | Date<br>12/14/2004 | Rev<br>B | Originator<br>N. DesRocher        | Date<br>3/23/2006 | Checker<br>Donna Yarbrough | Date<br>4-12-06 |

**7.3 Discharge Pressure:**

Discharge Pressure = Delivery Pressure + Discharge Static Head + Dynamic line and component losses

|                       |   |                         |         |
|-----------------------|---|-------------------------|---------|
| Delivery Pressure     | = | 34.7 psia (tank mixing) | Sec 4.3 |
|                       |   | = 14.7 psia (transfer)  | Sec 4.3 |
| Discharge Static Head | = | 25.67 ft                | Sec 4.3 |

Convert Discharge Static Head from feet of liquid to psi using Eq. 7.1

Discharge Static Head = 11.12 psi

|                           |   |            |                            |          |
|---------------------------|---|------------|----------------------------|----------|
| <u>Discharge Pressure</u> | = | 34.7 psia  | Delivery Pressure          |          |
| Tank Mixing               | + | 11.12 psi  | Discharge Static Pressure  |          |
|                           | + | 1 psi      | Flow Meter Pressure Drop   | Sec 4.3  |
|                           | + | 6.25 psi   | Pump Discharge Line Losses | Att 11.2 |
|                           |   | 53.07 psia |                            |          |

|                           |   |            |                            |                |
|---------------------------|---|------------|----------------------------|----------------|
| <u>Discharge Pressure</u> | = | 14.7 psia  | Delivery Pressure          |                |
| Transfer                  | + | 11.12 psi  | Discharge Static Pressure  |                |
|                           | + | 1 psi      | Flow Meter Pressure Drop   | Sec 4.3        |
|                           | + | 71.54 psi  | Pump Discharge Line Losses | Att 11.4, 11.5 |
|                           |   | 98.36 psia |                            |                |

**7.4 Differential Pressure:**

The Differential Pressure = the Discharge Pressure - the Suction Pressure

Tank Mixing:

|                              |   |            |         |
|------------------------------|---|------------|---------|
| Discharge Pressure           | = | 53.07 psia | Sec 7.3 |
| Suction Pressure             | = | 6.09 psia  | Sec 7.1 |
| <u>Differential Pressure</u> | = | 46.98 psi  |         |

Convert Differential Pressure from psi to feet of liquid using Eq. 7.2

Differential Pressure = 108.50 ft

Round up to 109 ft

# Calculation Continuation Sheet

Sheet No. 12 of 30

|  |            |   |                 |            |     |                                  |           |                 |         |
|--|------------|---|-----------------|------------|-----|----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J-00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                  |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                       | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                     | 3/23/2006 | Donna Yarbrough | 4-12-06 |

Transfer:

Discharge Pressure = 98.36 psia Sec 7.3

Suction Pressure = 11.46 psia Sec 7.1

Differential Pressure = 86.90 psi

Convert Differential Pressure from psi to feet of liquid using Eq. 7.2

Differential Pressure = 200.69 ft

Round up to 201 ft

7.5 Rated Differential Pressure & Rated Differential Head (TDH):

Rated Differential Pressure = the Differential Pressure + Overplus

Overplus is 10 % of the Differential Pressure or a minimum of 5 psi. Sec 4.3

Tank Mixing:

10% of Diff. Pressure = 0.1 x 46.98 psi = 4.698 psi

Overplus = 5 psi

Rated Differential Pressure = 46.98 psi + 5 psi = 51.98 psi

Convert Rated Differential Pressure from psi to feet of liquid using Eq. 7.2

Rated Differential Pressure = 120.05 ft

Round to 121 ft

Transfer:

10% of Diff. Pressure = 0.1 x 86.90 psi = 8.69 psi

Overplus = 8.69 psi

Rated Differential Pressure = 86.90 psi + 8.69 psi = 95.59 psi

Convert Rated Differential Pressure from psi to feet of liquid using Eq. 7.2

Rated Differential Pressure = 220.76 ft

Round to 221 ft

# Calculation Continuation Sheet

Sheet No. 13 of 30

|  |            |   |                 |            |     |              |                                   |                 |         |
|--|------------|---|-----------------|------------|-----|--------------|-----------------------------------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     |              | Calculation No.<br>M-CLC-J- 00013 |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |              |                                   |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator   | Date                              | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006                         | Donna Yarbrough | 4-12-06 |

**7.6 Maximum Suction Pressure:**

The Maximum Suction Pressure = Vessel PSV or Vent Setting + the Suction Static Head from High Level Ref. 3.5

Vessel PSV or Vent Setting = 14.56 psia Sec 4.3

Suction Static Head from High Level = 15.67 ft Sec 4.3

Convert Suction Static Head From High Level from feet of liquid to psi using Eq. 7.1

Suction Static Head from High Level = 6.79 psi

Maximum Suction Pressure = 14.56 psia + 6.79 psi = 21.35 psia

**7.7 Maximum Discharge Pressure:**

The Maximum Discharge Pressure = Shut off Pressure = 1.25 x Rated Differential Pressure + Maximum Suction Pressure

Maximum Suction Pressure = 21.35 psia Sec 7.6

Rated Differential Pressure = 51.98 psi (tank mixing) Sec 7.5

Rated Differential Pressure = 95.59 psi (transfer) Sec 7.5

Tank Mixing:

Maximum Discharge Pressure = 1.25 x 51.98 psi + 21.35 psia = 86.33 psia

Transfer:

Maximum Discharge Pressure = 1.25 x 95.59 psi + 21.35 psia = 140.84 psia

**7.8 Required Brake Horse Power:**

Required Brake Horse Power = Hydraulic Horse Power / Estimated Hydraulic Efficiency

Hydraulic Horse Power = 
$$\frac{(Q)(TDH)(SG)}{3,960}$$

Where

Q = design flow rate = 300 gpm (tank mixing) Sec 4.3

Q = design flow rate = 150 gpm (transfer) Sec 4.3

# Calculation Continuation Sheet

Sheet No. 14 of 30

|  |                         |   |                            |                    |          |                                   |                   |  |                 |
|--|-------------------------|---|----------------------------|--------------------|----------|-----------------------------------|-------------------|--|-----------------|
| <b>PARSONS</b><br>Engineering<br>Calculation |                         | Project: Salt Waste Processing Facility (SWPF)                      |                            |                    |          | Calculation No.<br>M-CLC-J- 00013 |                   |  |                 |
|  |                         | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                            |                    |          |                                   |                   |  |                 |
| Rev<br>A                                     | Originator<br>Kyle Bray | Date<br>12/13/2004  | Checker<br>Donna Yarbrough | Date<br>12/14/2004 | Rev<br>B | Originator<br>N. DesRocher        | Date<br>3/23/2006 | Checker<br><i>DWB</i><br>Donna Yarbrough | Date<br>4-12-06 |

|   |   |   |               |           |                |
|---|---|---|---------------|-----------|----------------|
| TDH = rated differential head                       | = | 121 ft                                      | (tank mixing) |           | Sec 7.5        |
| TDH = rated differential head                       | = | 221 ft                                      | (transfer)    |           | Sec 7.5        |
| SG = fluid specific gravity                         | = | 1.00  |               |           |                |
| 3,960 = conversion constant                         |   |   |               |           | Ref 3.11       |
| $\eta$ = estimated hydraulic efficiency             | = | 0.50  |               |           |                |
|   |   |   |               |           |                |
| Hydraulic Horse Power                               | = | 9.17 hp                                     | (tank mixing) |           |                |
| Hydraulic Horse Power                               | = | 8.37 hp                                     | (transfer)    |           |                |
|   |   |   |               |           |                |
| Required Brake Horse Power                          | = | $\frac{\text{Hydraulic Horse Power}}{\eta}$ |               |           |                |
|   |   |   |               |           |                |
| Tank Mixing:  |   |   |               |           |                |
| Required Brake Horse Power                          | = | $\frac{9.17}{0.50}$ hp                      | =             | 18.34 hp  |                |
|   |   |   |               |           |                |
| Transfer:   |   |   |               |           |                |
| Required Brake Horse Power                          | = | $\frac{8.37}{0.50}$ hp                      | =             | 16.74 hp  |                |
|   |   |   |               |           |                |
| <b>7.9 Total Dynamic Pressure Drop: Tank Mixing</b> |   |   |               |           |                |
| = Suction Line Loss                                 |   |   | =             | 7.21 psi  | Att 11.1       |
| + Discharge Line Loss                               |   |   | =             | 6.25 psi  | Att 11.2       |
| + Control Valve Pressure Drop                       |   |   | =             | 0 psi     |                |
| + Flow meter Pressure Drop                          |   |   | =             | 1 psi     | Sec 4.3        |
| + Heater Pressure Drop                              |   |   | =             | 0 psi     |                |
| + Filter Pressure Drop                              |   |   | =             | 0 psi     |                |
| + Spare Pressure Drop                               |   |   | =             | 0 psi     |                |
| <b>Total Dynamic Pressure Drop</b>                  |   |   | =             | 14.46 psi |                |
|   |   |   |               |           |                |
| <b>Total Dynamic Pressure Drop: Transfer</b>        |   |   |               |           |                |
| = Suction Line Loss                                 |   |   | =             | 1.84 psi  | Att 11.3       |
| + Discharge Line Loss                               |   |   | =             | 71.54 psi | Att 11.4, 11.5 |
| + Control Valve Pressure Drop                       |   |   | =             | 0 psi     |                |
| + Flow meter Pressure Drop                          |   |   | =             | 1 psi     | Sec 4.3        |
| + Heater Pressure Drop                              |   |   | =             | 0 psi     |                |
| + Filter Pressure Drop                              |   |   | =             | 0 psi     |                |
| + Spare Pressure Drop                               |   |   | =             | 0 psi     |                |
| <b>Total Dynamic Pressure Drop</b>                  |   |   | =             | 74.38 psi |                |

# Calculation Continuation Sheet

Sheet No. 15 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|      |  |   |          |         |
|------|--|---|----------|---------|
| 7.10 | Minimum Static Head:                       |   |          |         |
|      | = Discharge Static Head                    | = | 25.67 ft | Sec 4.3 |
|      | - Suction Static Head From High Level      | - | 15.67 ft | Sec 4.3 |
|      | <u>Minimum Static Head</u>                 | = | 10.00 ft |         |
|      |  |   |          |         |
| 7.11 | Maximum Static Head:                       |   |          |         |
|      | = Discharge Static Head                    | = | 25.67 ft | Sec 4.3 |
|      | - Suction Static Head From Low Level       | - | -2.91 ft | Sec 4.3 |
|      | <u>Maximum Static Head</u>                 | = | 28.58 ft |         |
|      |  |   |          |         |
| 7.12 | Maximum Control Valve Pressure Drop:       |   | N/A      |         |
|      | = Total Dynamic Pressure Drop              | = | 0.00     |         |
|      | - Maximum Total Static Head                | = | 0.00     |         |
|      | <u>Maximum Control Valve Pressure Drop</u> | = | N/A      |         |
|      |  |   |          |         |
| 7.13 | Minimum Control Valve Pressure Drop:       |   | N/A      |         |
|      | = Total Dynamic Pressure Drop              | = | 0.00     |         |
|      | - Minimum Static Head                      | = | 0.00     |         |
|      | <u>Minimum Control Valve Pressure Drop</u> | = | N/A      |         |

# Calculation Continuation Sheet

Sheet No. 16 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|                        |  |  |        |      |   |     |    |  |          |
|------------------------|--|--|--------|------|---|-----|----|--|----------|
| <b>8.0 Results</b>     |  |  |        |      |   |     |    |  |          |
| <b>8.1 Tank Mixing</b> |  |  |        |      |   |     |    |  |          |
| 8.1.1                  | Suction Pressure:                            |  | 6.09   | psia |   |     |    |  | Sec 7.1  |
| 8.1.2                  | Net Positive Suction Head Available (NPSHA): |  | 13.01  | ft   |   |     |    |  | Sec 7.2  |
| 8.1.3                  | Discharge Pressure:                          |  | 53.07  | psia |   |     |    |  | Sec 7.3  |
| 8.1.4                  | Differential Pressure & Head:                |  | 46.98  | psi  | = | 109 | ft |  | Sec 7.4  |
| 8.1.5                  | Rated Differential Pressure & Head:          |  | 51.98  | psi  | = | 121 | ft |  | Sec 7.5  |
| 8.1.6                  | Maximum Suction Pressure:                    |  | 21.35  | psia |   |     |    |  | Sec 7.6  |
| 8.1.7                  | Maximum Discharge Pressure:                  |  | 86.33  | psia |   |     |    |  | Sec 7.7  |
| 8.1.8                  | Required Brake Horsepower:                   |  | 18.34  | hp   |   |     |    |  | Sec 7.8  |
| 8.1.9                  | Total Dynamic Pressure Drop:                 |  | 14.46  | psi  |   |     |    |  | Sec 7.9  |
| 8.1.1                  | Minimum Static Head:                         |  | 10.00  | ft   |   |     |    |  | Sec 7.10 |
| 8.1.11                 | Maximum Static Head:                         |  | 28.58  | ft   |   |     |    |  | Sec 7.11 |
| 8.1.12                 | Maximum Control Valve Pressure Drop:         |  | N/A    | psi  |   |     |    |  | Sec 7.12 |
| 8.1.13                 | Minimum Control Valve Pressure Drop:         |  | N/A    | psi  |   |     |    |  | Sec 7.13 |
| <b>8.2 Transfer</b>    |  |  |        |      |   |     |    |  |          |
| 8.2.1                  | Suction Pressure:                            |  | 11.46  | psia |   |     |    |  | Sec 7.1  |
| 8.2.2                  | Net Positive Suction Head Available (NPSHA): |  | 25.41  | ft   |   |     |    |  | Sec 7.2  |
| 8.2.3                  | Discharge Pressure:                          |  | 98.36  | psia |   |     |    |  | Sec 7.3  |
| 8.2.4                  | Differential Pressure & Head:                |  | 86.90  | psi  | = | 201 | ft |  | Sec 7.4  |
| 8.2.5                  | Rated Differential Pressure & Head:          |  | 95.59  | psi  | = | 221 | ft |  | Sec 7.5  |
| 8.2.6                  | Maximum Suction Pressure:                    |  | 21.35  | psia |   |     |    |  | Sec 7.6  |
| 8.2.7                  | Maximum Discharge Pressure:                  |  | 140.84 | psia |   |     |    |  | Sec 7.7  |
| 8.2.8                  | Required Brake Horsepower:                   |  | 16.74  | hp   |   |     |    |  | Sec 7.8  |
| 8.2.9                  | Total Dynamic Pressure Drop:                 |  | 74.38  | psi  |   |     |    |  | Sec 7.9  |
| 8.2.1                  | Minimum Static Head:                         |  | 10.00  | ft   |   |     |    |  | Sec 7.10 |
| 8.2.11                 | Maximum Static Head:                         |  | 28.58  | ft   |   |     |    |  | Sec 7.11 |
| 8.2.12                 | Maximum Control Valve Pressure Drop:         |  | N/A    | psi  |   |     |    |  | Sec 7.12 |
| 8.2.13                 | Minimum Control Valve Pressure Drop:         |  | N/A    | psi  |   |     |    |  | Sec 7.13 |

# Calculation Continuation Sheet

Sheet No. 17 of 30

|  |            |   |                 |            |     |                                   |           |                 |         |
|--|------------|---|-----------------|------------|-----|-----------------------------------|-----------|-----------------|---------|
| <b>PARSONS</b><br>Engineering<br>Calculation |            | Project: Salt Waste Processing Facility (SWPF)                      |                 |            |     | Calculation No.<br>M-CLC-J- 00013 |           |                 |         |
|  |            | Title: Strip Effluent Transfer Pumps Sizing Calculation<br>P-205A/B |                 |            |     |                                   |           |                 |         |
| Rev  | Originator | Date  | Checker         | Date       | Rev | Originator                        | Date      | Checker         | Date    |
| A  | Kyle Bray  | 12/13/2004  | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006 | Donna Yarbrough | 4-12-06 |

**9.0 Conclusions**

P-205A/B will need to be sized to handle the following two conditions:

**Tank Mixing:**  
The design point is 300 gpm and 121 ft TDH. Estimated required brake horse power is 18.34 hp.

**Transfer:**  
The design point is 150 gpm and 221 ft TDH. Estimated required brake horse power is 16.74 hp.

**10.0 Notes**

10.1 Elevation with respect to the floor elevation

10.2 Elevation with respect to the pump centerline

**11.0 Attachments**

|   |        |   |
|---|--------|---|
| 11.1 Pump Suction Line Loss Calculation, Tank Mixing            | Sheets | 1 |
| 11.2 Pump Discharge Line Loss Calculation, Tank Mixing          | Sheets | 1 |
| 11.3 Pump Suction Line Loss Calculation, Transfer               | Sheets | 1 |
| 11.4 Pump Discharge Line Loss Calculation, Transfer, 4" section | Sheets | 1 |
| 11.5 Pump Discharge Line Loss Calculation, Transfer, 3" section | Sheets | 1 |
| 11.6 Pump Calculation Data Sheet                                | Sheets | 3 |
| 11.7 Xomox Valve Data   | Sheets | 5 |

## Calculation Sheet

| <b>PARSONS</b><br>Engineering<br>Calculation  |                           | Project: Salt Waste Processing Facility (SWPF)           |   |            |   | Calculation No.<br>M-CLC-J- 00013 |                |                       |         |
|---|---------------------------|--|---|------------|---|-----------------------------------|----------------|-----------------------|---------|
|   |                           | Subject: Pump Suction Line Loss Calculation, Tank Mixing |   |            |   |                                   |                | Sheet No.<br>18 of 30 |         |
| Rev   | Originator                | Date   | Checker   | Date       | Rev   | Originator                        | Date           | Checker               | Date    |
| A   | Kyle Bray                 | 12/13/2004   | Donna Yarbrough   | 12/14/2004 | B   | N. DesRocher                      | 3/23/2006      | Donna Yarbrough       | 4-12-06 |
| Line Number:  |                           | 4"-AQU-0162-PS200C                                       |   |            | Fluid:  |                                   | Strip Effluent |                       | Sec 4.1 |
| P&ID Number:  |                           | M-M6-J-0032 M-M6-J-0033 Ref. 3.3, 3.4                    |   |            | Flow Rate (Q):  |                                   | 300 gpm        |                       | Sec 4.3 |
| ISO DWG No.:  |                           | TBD  |   |            | Viscosity (μ):  |                                   | 0.9 cp         |                       | Sec 4.1 |
|   |                           |  |   |            | Specific Gravity:   |                                   | 1.00           |                       | Sec 4.1 |
| From: TK-205  |                           |  |   |            |   |                                   |                |                       |         |
| To: Pump Suction of P-205A/B  |                           |  |   |            |   |                                   |                |                       |         |
| Basis Internal Dia.(d): <u>4.026</u> in. Internal Area = <u>0.088405</u> ft <sup>2</sup> = $\pi \times 0.25 \times d^2/144$           |                           |  |   |            |   |                                   |                |                       |         |
| Surface Roughness (ε): <u>0.00015</u> ft  |                           |  |   |            |   |                                   |                |                       | [3.11]  |
| Relative Roughness ε/D: <u>0.000447</u>   |                           |  |   |            |   |                                   |                |                       |         |
| Reynolds Number: <u>261,421</u> = $\frac{50.8(Q)(SG)(62.4)}{\mu(d)}$  |                           |  |   |            |   |                                   |                |                       | [3.9]   |
| Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation. |                           |  |   |            |   |                                   |                |                       |         |
| Colebrook Equation (For Reynolds Numbers > 4,000):  |                           |  |   |            | $\frac{1}{f^{1/2}} = (-2) \text{Log} \left[ \left( \frac{\epsilon/D}{3.7} \right) + \frac{2.51}{\text{Re} (f^{1/2})} \right]$ |                                   |                |                       |         |
| Colebrook Friction Factor (f): = 0.018  |                           |  |   |            |   |                                   |                |                       | [3.11]  |
| Laminar Friction Factor f = 64/Re = 0.000 Velocity (v) = 7.56 fps   |                           |  |   |            |   |                                   |                |                       | [3.11]  |
| Friction Factor For This Calc. = 0.018  |                           |  |   |            |   |                                   |                |                       |         |
| Item  | Component                 | QTY  | "K" Formula   | [3.9]      | d <sub>1</sub>  | d <sub>2</sub>                    | β <sup>2</sup> | β <sup>4</sup>        | K       |
| 1   | Entrance                  | 1  | K = 0.78  |            |   |                                   |                |                       | 0.78    |
| 2   | Pipe*                     | 900 in.  | K = fL/d  |            |   |                                   |                |                       | 4.024   |
| 3   | Plug Valve, Straight-way  | 3  | Cv = 548 [11.7] K = 891 d <sup>4</sup> /Cv <sup>2</sup> |            |   |                                   |                |                       | 2.338   |
| 4   | Plug Valve, 3-way, T-port | 1  | Cv = 159 [11.7] K = 891 d <sup>4</sup> /Cv <sup>2</sup> |            |   |                                   |                |                       | 9.26    |
| 5   | Tee Branch                | 1  | K = 60 f  |            |   |                                   |                |                       | 1.08    |
| 6   | L.R. 90                   | 5  | K = 14 f  |            |   |                                   |                |                       | 1.26    |
| 7   | Total K                   |  |   |            |   |                                   |                |                       | 18.74   |
| * Pipe length estimated from ref. 3.12  |                           |  |   |            |   |                                   |                |                       |         |
| Pressure Drop: = $\frac{K SG \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$ = 7.21 psi                                     |                           |  |   |            |   |                                   |                |                       | [3.11]  |



## Calculation Sheet

|  |  |                                   |
|--|--|-----------------------------------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)             | Calculation No.<br>M-CLC-J- 00013 |
|  | Subject: Pump Discharge Line Loss Calculation, Tank Mixing |                                   |
|  |  | Sheet No.<br>19 of 30             |

|     |            |            |                 |            |     |              |           |                 |         |
|-----|------------|------------|-----------------|------------|-----|--------------|-----------|-----------------|---------|
| Rev | Originator | Date       | Checker         | Date       | Rev | Originator   | Date      | Checker         | Date    |
| A   | Kyle Bray  | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

**Line Number:** 4"-AQU-6693-PS200C      **Fluid:** Strip Effluent      Sec 4.1  
**P&ID Number:** M-M6-J-0032 M-M6-J-0033      Ref. 3.3, 3.4      **Flow Rate (Q):** 300 gpm      Sec 4.3  
**ISO DWG No.:** TBD      **Viscosity (μ):** 0.9 cp      Sec 4.1  
**Specific Gravity:** 1.00      Sec 4.1

**From:** Pump Discharge of P-205A/B  
**To:** EDT-205

Basis Internal Dia.(d): 4.026 in.      Internal Area = 0.088405 ft<sup>2</sup>      = π x 0.25 x d<sup>2</sup>/144

Surface Roughness (ε): 0.00015 ft      [3.11]  
 Relative Roughness ε/D: 0.000447

Reynolds Number: 261,421 =  $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$       [3.9]

Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.

Colebrook Equation (For Reynolds Numbers > 4,000) :       $\frac{1}{f^{1/2}} = [-2] \text{ Log } \left( \frac{\epsilon/D}{3.7} + \frac{2.51}{\text{Re} (f^{1/2})} \right)$

Colebrook Friction Factor (f) : = 0.018      [3.11]

Laminar Friction Factor f = 64/Re = 0.000      Velocity (v) = 7.56 fps      [3.11]

Friction Factor For This Calc. = 0.018

| Item | Component                | QTY      | "K" Formula [3.9]                        | d <sub>1</sub> | d <sub>2</sub> | β <sup>2</sup> | β <sup>4</sup> | K     |
|------|--------------------------|----------|--|----------------|----------------|----------------|----------------|-------|
| 1    | Expander                 | 1        | $K = (1 - \beta^2)^2 / \beta^4$          | 3.068          | 4.026          | 0.581          | 0.3380         | 0.519 |
| 2    | Pipe*                    | 1680 in. | $K = f L/d$                              |                |                |                |                | 7.511 |
| 3    | Plug Valve, Straight-way | 3        | $C_v = 548$ [11.7] $K = 891 d^4 / C_v^2$ |                |                |                |                | 2.338 |
| 4    | Ext                      | 1        | $K = 1.0$                                |                |                |                |                | 1     |
| 5    | Tee Run                  | 2        | $K = 20 f$                               |                |                |                |                | 0.7   |
| 6    | Tee Branch               | 2        | $K = 60 f$                               |                |                |                |                | 2.16  |
| 7    | L.R. 90                  | 8        | $K = 14 f$                               |                |                |                |                | 2.02  |
| 9    | Total K                  |          |  |                |                |                |                | 16.25 |

\* Pipe length estimated from ref. 3.12

Pressure Drop: =  $\frac{K \text{ SG } \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$  = 6.25 psi      [3.11]

## Calculation Sheet

|  |   |                                   |
|--|---|-----------------------------------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)        | Calculation No.<br>M-CLC-J- 00013 |
|  | Subject: Pump Suction Line Loss Calculation, Transfer | Sheet No.<br>20 of 30             |

|     |            |            |                 |            |     |              |           |                 |         |
|-----|------------|------------|-----------------|------------|-----|--------------|-----------|-----------------|---------|
| Rev | Originator | Date       | Checker         | Date       | Rev | Originator   | Date      | Checker         | Date    |
| A   | Kyle Bray  | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|   |                               |         |
|---|-------------------------------|---------|
| Line Number: <u>4"-AQU-0162-PS200C</u>                    | Fluid: <u>Strip Effluent</u>  | Sec 4.1 |
| P&ID Number: <u>M-M6-J-0032 M-M6-J-0033</u> Ref. 3.3, 3.4 | Flow Rate (Q): <u>150</u> gpm | Sec 4.3 |
| ISO DWG No.: <u>TBD</u>                                   | Viscosity (μ): <u>0.9</u> cp  | Sec 4.1 |
|   | Specific Gravity: <u>1.00</u> | Sec 4.1 |

From: TK-205  
 To: Pump Suction of P-205A/B

Basis Internal Dia.(d): 4.026 in. Internal Area = 0.088405 ft<sup>2</sup> =  $\pi \times 0.25 \times d^2/144$

Surface Roughness (ε): 0.00015 ft [3.11]  
 Relative Roughness ε/D: 0.000447

Reynolds Number: 130,710 =  $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$  [3.9]

Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.

Colebrook Equation (For Reynolds Numbers > 4,000):  $\frac{1}{f^{1/2}} = (-2) \log \left( \frac{\epsilon/D}{3.7} + \frac{2.51}{Re \sqrt{f}} \right)$   
 Colebrook Friction Factor (f): = 0.019 [3.11]

Laminar Friction Factor  $f = 64/Re = 0.000$  Velocity (v) = 3.78 fps [3.11]

Friction Factor For This Calc. = 0.019

| Item | Component                 | QTY     | "K" Formula [3.9]                                       | d <sub>1</sub> | d <sub>2</sub> | β <sup>2</sup> | β <sup>4</sup> | K     |
|------|---------------------------|---------|---|----------------|----------------|----------------|----------------|-------|
| 1    | Entrance                  | 1       | K = 0.78  |                |                |                |                | 0.78  |
| 2    | Pipe*                     | 900 in. | K = fL/d  |                |                |                |                | 4.247 |
| 3    | Plug Valve, Straight-way  | 3       | Cv = 548 [11.7] K = 891 d <sup>4</sup> /Cv <sup>2</sup> |                |                |                |                | 2.338 |
| 4    | Plug Valve, 3-way, T-port | 1       | Cv = 159 [11.7] K = 891 d <sup>4</sup> /Cv <sup>2</sup> |                |                |                |                | 9.26  |
| 5    | Tee Branch                | 1       | K = 60 f  |                |                |                |                | 1.14  |
| 6    | L.R. 90                   | 5       | K = 14 f  |                |                |                |                | 1.33  |
| 7    | Total K                   |         |   |                |                |                |                | 19.1  |

\* Pipe length estimated from ref. 3.12

Pressure Drop: =  $\frac{K SG \rho_{H2O} (v^2 ft^2)}{2 g_c (144 in^2)}$  = 1.84 psi [3.11]

## Calculation Sheet

|  |   |                                   |
|--|---|-----------------------------------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      | Calculation No.<br>M-CLC-J- 00013 |
|  | Subject: Pump Discharge Line Loss Calculation, Transfer, 4" section | Sheet No.<br>21 of 30             |

| Rev | Originator | Date       | Checker         | Date       | Rev | Originator   | Date      | Checker         | Date    |
|-----|------------|------------|-----------------|------------|-----|--------------|-----------|-----------------|---------|
| A   | Kyle Bray  | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|  |                                |         |
|--|--------------------------------|---------|
| Line Number: <u>4"-AQU-0119-PS200C</u>   | Fluid: <u>Strip Effluent</u>   | Sec 4.1 |
| P&ID Number: <u>M-M6-J-0033</u> Ref. 3.3 | Flow Rate (Q) : <u>150</u> gpm | Sec 4.3 |
| ISO DWG No.: <u>TBD</u>                  | Viscosity (μ): <u>0.9</u> cp   | Sec 4.1 |
|  | Specific Gravity: <u>1.00</u>  | Sec 4.1 |

From: Pump Discharge of P-205A/B

To: 4" x 3" Reducer

Basis Internal Dia.(d): 4.026 in. Internal Area = 0.088405 ft<sup>2</sup> =  $\pi \times 0.25 \times d^2/144$

Surface Roughness (ε) : 0.00015 ft [3.11]

Relative Roughness ε/D: 0.000447

Reynolds Number: 130,710 =  $\frac{(50.6)(Q)(SG)(62.4)}{(\mu)(d)}$  [3.9]

Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.

Colebrook Equation (For Reynolds Numbers > 4,000) :  $\frac{1}{f^{1/2}} = [-2] \text{ Log } \left( \frac{\epsilon/D}{3.7} + \frac{2.51}{\text{Re} (f^{1/2})} \right)$

Colebrook Friction Factor (f) : = 0.019 [3.11]

Laminar Friction Factor  $f = 64/\text{Re}$  = 0.000 Velocity (v) = 3.78 fps [3.11]

Friction Factor For This Calc. = 0.019

| Item | Component                | QTY     | "K" Formula [3.9]                      | d <sub>1</sub> | d <sub>2</sub> | β <sup>2</sup> | β <sup>4</sup> | K     |
|------|--------------------------|---------|--|----------------|----------------|----------------|----------------|-------|
| 1    | Expander                 | 1       | $K = (1 - \beta^2)^2 / \beta^4$        | 3.068          | 4.026          | 0.581          | 0.3380         | 0.519 |
| 2    | Pipe*                    | 180 in. | $K = fL/d$                             |                |                |                |                | 0.849 |
| 3    | Plug Valve, Straight-way | 1       | $C_v = 548$ [11.7] $K = 891 d^4/C_v^2$ |                |                |                |                | 0.779 |
| 4    | Tee Run                  | 4       | $K = 20f$                              |                |                |                |                | 1.52  |
| 5    | L.R. 90                  | 4       | $K = 14f$                              |                |                |                |                | 1.06  |
| 6    | Total K                  |         |  |                |                |                |                | 4.727 |

\* Pipe length estimated from ref. 3.12

Pressure Drop: =  $\frac{K \text{ SG } \rho_{H2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)}$  = 0.45 psi [3.11]

## Calculation Sheet

|  |   |                                   |
|--|---|-----------------------------------|
| <b>PARSONS</b><br>Engineering<br>Calculation | Project: Salt Waste Processing Facility (SWPF)                      | Calculation No.<br>M-CLC-J- 00013 |
|  | Subject: Pump Discharge Line Loss Calculation, Transfer, 3" section | Sheet No.<br>22 of 30             |

|     |            |            |                 |            |     |              |           |                 |         |
|-----|------------|------------|-----------------|------------|-----|--------------|-----------|-----------------|---------|
| Rev | Originator | Date       | Checker         | Date       | Rev | Originator   | Date      | Checker         | Date    |
| A   | Kyle Bray  | 12/13/2004 | Donna Yarbrough | 12/14/2004 | B   | N. DesRocher | 3/23/2006 | Donna Yarbrough | 4-12-06 |

|              |                         |                   |                |         |         |
|--------------|-------------------------|-------------------|----------------|---------|---------|
| Line Number: | 3"-AQU-0119-PS200C      | Fluid:            | Strip Effluent | Sec 4.1 |         |
| P&ID Number: | M-M6-J-0033 M-M6-J-0002 | Ref. 3.3, 3.8     | Flow Rate (Q): | 150 gpm | Sec 4.3 |
| ISO DWG No.: | TBD                     | Viscosity (μ):    | 0.9 cp         | Sec 4.1 |         |
|              |                         | Specific Gravity: | 1.00           | Sec 4.1 |         |

From: 4" x 3" Reducer  
To: DWPF

Basis Internal Dia.(d): 3.068 in.      Internal Area =  $0.051338 \text{ ft}^2 = \pi \times 0.25 \times d^2/144$

Surface Roughness (ε): 0.00015 ft [3.11]

Relative Roughness ε/D: 0.000587

Reynolds Number:  $171,525 = \frac{[50.6][Q][SG][62.4]}{[\mu][d]}$  [3.9]

Note: Since the Reynolds Number is > 4,000, the flow is turbulent and the friction factor is calculated using the Colebrook equation.

Colebrook Equation (For Reynolds Numbers > 4,000):  $\frac{1}{f^{1/2}} = [-2] \text{ Log} \left( \left[ \frac{\epsilon/D}{3.7} \right] + \frac{2.51}{[Re][f^{1/2}]} \right)$

Colebrook Friction Factor (f): = 0.020 [3.11]

Laminar Friction Factor  $f = 64/Re = 0.000$       Velocity (v) = 6.509 fps [3.11]

Friction Factor For This Calc. = 0.020

| Item | Component                | QTY        | "K" Formula <span style="float: right;">[3.9]</span> | d <sub>1</sub> | d <sub>2</sub> | β <sup>2</sup> | β <sup>4</sup> | K      |
|------|--------------------------|------------|--|----------------|----------------|----------------|----------------|--------|
| 1    | Reducer                  | 1          | $K = 0.5(1 - \beta^2)$                               | 3.068          | 4.026          | 0.581          | 0.3380         | 0.21   |
| 2    | Pipe*                    | 36,600 in. | $K = fL/d$   |                |                |                |                | 238.6  |
| 3    | Plug Valve, Straight-way | 3          | $C_v = 294$ [11.7] $K = 891 d^4/C_v^2$               |                |                |                |                | 2.74   |
| 4    | Exit                     | 1          | $K = 1.0$  |                |                |                |                | 1      |
| 5    | Tee Branch               | 1          | $K = 60 f$   |                |                |                |                | 1.2    |
| 6    | L.R. 90                  | 20         | $K = 14 f$   |                |                |                |                | 5.6    |
| 7    | Total K                  |            |  |                |                |                |                | 249.35 |

\* Pipe length estimated from ref. 3.12 and Open Item 2.13

Pressure Drop:  $= \frac{K SG \rho_{H_2O} (v^2 \text{ ft}^2)}{2 g_c (144 \text{ in}^2)} = 71.09 \text{ psi}$  [3.11]

| REV NO | DATE     | BY  | CK  | APP | DESCRIPTION                            | REV NO | DATE | BY | CK | APP | DESCRIPTION |
|--------|----------|-----|-----|-----|--|--------|------|----|----|-----|-------------|
|        |          |     |     |     |  |        |      |    |    |     |             |
| A      | 12/13/04 | KKB | DMY | KEB | Issued for Preliminary Engineering     |        |      |    |    |     |             |
| B      | 3/23/08  | NDD |     |     | Issued for Enhanced Preliminary Design |        |      |    |    |     |             |

|                   |                                 |                         |   |
|-------------------|---------------------------------|-------------------------|---|
| CLIENT & LOCATION | DOE SAVANNAH RIVER SITE         | EQUIPMENT NUMBER        | P-205A/B                                |
| PROJECT NO.       | 744910                          | PUMP CALCULATION NO.    | M-CLC-J-00013                           |
| SYSTEM            | Caustic-Side Solvent Extraction | PFD REF. DRAWING NO.    | M-M5-J-0008                             |
| AREA              | J                               | P & ID REF. DRAWING NO. | M-M6-J-0032   M-M6-J-0033   M-M6-J-0002 |

| DESIGN DATA             |                           |              |              |
|-------------------------|---------------------------|--------------|--------------|
| FLUID:                  | Strip Effluent            |              |              |
| SERVICE:                | Mbdng TK-206              |              |              |
| DISSOLVED CONTAMINANTS: | Caesium                   |              |              |
| SUSPENDED SOLIDS:       | None                      |              |              |
| OPERATION:              | Batch                     | HOURS / DAY  | Intermittent |
| PUMP TYPE:              | Centrifugal               | ORIENTATION: | Horizontal   |
| SEAL TYPE:              | Dual Cartridge Mechanical |              | PUMP SIZE:   |

| TEMPERATURE                     |    | FLUID PROPERTIES |                             |
|---------------------------------|----|------------------|-----------------------------|
| PUMPING TEMPERATURE             | °F | 77               | VAPOR PRESSURE @ P,T        |
| MIN / MAX OPERATING TEMPERATURE | °F | 60 / 95          | PSIA                        |
| DESIGN TEMPERATURE              | °F | 120              | 0.46                        |
|                                 |    |                  | SPECIFIC GRAVITY (SG) @ P,T |
|                                 |    |                  | 1.00                        |
|                                 |    |                  | VISCOSITY @ P,T             |
|                                 |    |                  | CP                          |
|                                 |    |                  | 0.9                         |

| FLOW RATE         |     |     |                       |
|-------------------|-----|-----|-----------------------|
| NORMAL FLOW @ P,T | GPM | 300 | MIN FLOW @ P,T        |
| OVERCAPACITY %    |     | 0%  | GPM                   |
|                   |     |     | TBD                   |
|                   |     |     | DESIGN FLOW @ MAX T,P |
|                   |     |     | GPM                   |
|                   |     |     | 300                   |

| PUMP CALCULATION SUMMARY          |      |      |        |                                 |       |
|-----------------------------------|------|------|--------|---------------------------------|-------|
| SUCTION PRESSURE                  |      | NORM | DESIGN | DIFFERENTIAL PRESSURE           |       |
| = VESSEL OPERATING PRESSURE       | PSIA |      | 14.56  | = DISCHARGE PRESSURE            | PSIA  |
| + SUCTION STATIC HEAD             | PSIA |      | -1.26  | - TOTAL SUCTION PRESSURE        | PSIA  |
| - LINE LOSS                       | PSI  |      | 7.21   | - DIFFERENTIAL PRESSURE         | PSI   |
| TOTAL SUCTION PRESSURE            | PSIA |      | 8.09   | DIFFERENTIAL PRESSURE           | FT    |
|                                   |      |      |        |                                 | 109   |
| NET POSITIVE SUCTION HEAD (NPSHA) |      | NORM | DESIGN | RATED DIFFERENTIAL PRESSURE     |       |
| = SUCTION STATIC HEAD             | FT   |      | -2.91  | = DIFFERENTIAL PRESSURE         | PSI   |
| - LINE LOSS                       | FT   |      | 16.65  | + OVERPLUS                      | PSI   |
| + VESSEL OPERATING PRESSURE       | FT   |      | 33.63  | RATED DIFFERENTIAL PRESSURE     | PSI   |
| - VAPOR PRESSURE                  | FT   |      | 1.08   | RATED DIFFERENTIAL HEAD         | FT    |
| NET POSITIVE SUCTION HEAD (NPSHA) | FT   |      | 13.01  |                                 | 121   |
| DISCHARGE PRESSURE                |      | NORM | DESIGN | MAXIMUM SUCTION PRESSURE        |       |
| = DELIVERY PRESSURE               | PSIA |      | 34.7   | = VESSEL PSV SETTING            | PSIA  |
| + DISCHARGE STATIC HEAD           | PSI  |      | 11.12  | + STATIC HEAD FROM HIGH LEVEL   | PSI   |
| + CONTROL VALVE ΔP                | PSI  |      | 0.0    | MAXIMUM SUCTION PRESSURE        | PSIA  |
| + HEAT EXCHANGER ΔP               | PSI  |      | 0.0    |                                 | 21.35 |
| + HEATER ΔP                       | PSI  |      | 0.0    | MAXIMUM DISCHARGE PRESSURE      |       |
| + FILTER ΔP                       | PSI  |      | 0.0    | = MAXIMUM SUCTION PRESSURE      | PSIA  |
| + FLOW METER ΔP                   | PSI  |      | 1      | + SHUT OFF ΔP (1.25 X RATED ΔP) | PSI   |
| + LINE LOSS                       | PSI  |      | 6.25   | MAXIMUM DISCHARGE PRESSURE      | PSIA  |
| + SPARE ΔP                        | PSI  |      | 0.0    |                                 | 86.33 |
| DISCHARGE PRESSURE                | PSIA |      | 53.07  | REQUIRED BRAKE HORSEPOWER       |       |
|                                   |      |      |        | = HYDRAULIC POWER               | HP    |
|                                   |      |      |        | / EST. HYDRAULIC EFFICIENCY     |       |
|                                   |      |      |        | REQUIRED BRAKE HORSEPOWER       | HP    |
|                                   |      |      |        |                                 | 18.34 |

| TOTAL DYNAMIC PRESSURE DROP |     | NORM | DESIGN | STATIC HEAD                 |    | MIN   | MAX   |
|-----------------------------|-----|------|--------|-----------------------------|----|-------|-------|
| = SUCTION LINE LOSS         | PSI |      | 7.21   | = DISCHARGE STATIC HEAD     | FT | 25.67 | 25.67 |
| + DISCHARGE LINE LOSS       | PSI |      | 6.25   | - SUCTION STATIC HEAD       | FT | 15.67 | -2.91 |
| + CONTROL VALVE ΔP          | PSI |      | 0.0    | STATIC HEAD                 |    | FT    | 10.00 |
| + HEAT EXCHANGER ΔP         | PSI |      | 0.0    |                             |    | MIN   | MAX   |
| + HEATER ΔP                 | PSI |      | 0.0    | CONTROL VALVE PRESSURE DROP |    | PSI   | N/A   |
| + FILTER ΔP                 | PSI |      | 0.0    |                             |    |       |       |
| + FLOW METER ΔP             | PSI |      | 1      |                             |    |       |       |
| + SPARE ΔP                  | PSI |      | 0.0    |                             |    |       |       |
| TOTAL DYNAMIC PRESSURE DROP | PSI |      | 14.46  |                             |    |       |       |

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

|   |              |            |
|---|--------------|------------|
| <br><b>Pump Calculation Data Sheet</b> | Sheet 1 of 3 | JOB NUMBER |
|   | Page         | 744910     |
|   |              | 23         |

| DESIGN DATA                       |                                   |              |              |                             |                                 |      |         |
|-----------------------------------|-----------------------------------|--------------|--------------|-----------------------------|---------------------------------|------|---------|
| FLUID:                            | Strip Effluent                    |              |              |                             |                                 |      |         |
| SERVICE:                          | Strip Effluent Transfer           |              |              |                             |                                 |      |         |
| DISSOLVED CONTAMINANTS:           | Cesium                            |              |              |                             |                                 |      |         |
| SUSPENDED SOLIDS:                 | None                              |              |              |                             |                                 |      |         |
| OPERATION:                        | Batch                             | HOURS / DAY  | Intermittent | DRIVER TYPE:                | Electric Motor                  | RPM  | CLASS B |
| PUMP TYPE:                        | Centrifugal                       | ORIENTATION: | Horizontal   | IMPELLER TYPE:              | Standard                        |      | HP      |
| SEAL TYPE:                        | Dual Cartridge Mechanical         |              |              | PUMP SIZE:                  |                                 |      |         |
| TEMPERATURE                       |                                   |              |              | FLUID PROPERTIES            |                                 |      |         |
| PUMPING TEMPERATURE               | *F                                | 77           |              | VAPOR PRESSURE @ P,T        | PSIA                            | 0.46 |         |
| MIN / MAX OPERATING TEMPERATURE   | *F                                | 60 / 96      |              | SPECIFIC GRAVITY (SG) @ P,T |                                 | 1.00 |         |
| DESIGN TEMPERATURE                | *F                                | 120          |              | VISCOSITY @ P.T             | CP                              | 0.9  |         |
| FLOW RATE                         |                                   |              |              |                             |                                 |      |         |
| NORMAL FLOW @ P,T                 | GPM                               | 150          |              | MIN FLOW @ P,T              | GPM                             | TBD  |         |
| OVERCAPACITY %                    |                                   | 0%           |              | DESIGN FLOW @ MAX T,P       | GPM                             | 150  |         |
| PUMP CALCULATION SUMMARY          |                                   |              |              |                             |                                 |      |         |
| SUCTION PRESSURE                  |                                   | NORM         | DESIGN       | DIFFERENTIAL PRESSURE       |                                 | NORM | DESIGN  |
| =                                 | VESSEL OPERATING PRESSURE         | PSIA         | 14.56        | =                           | DISCHARGE PRESSURE              | PSIA | 98.36   |
| +                                 | SUCTION STATIC HEAD               | PSIA         | -1.26        | -                           | TOTAL SUCTION PRESSURE          | PSIA | 11.46   |
| -                                 | LINE LOSS                         | PSI          | 1.84         |                             | DIFFERENTIAL PRESSURE           | PSI  | 86.90   |
|                                   | TOTAL SUCTION PRESSURE            | PSIA         | 11.46        |                             | DIFFERENTIAL PRESSURE           | FT   | 201     |
| NET POSITIVE SUCTION HEAD (NPSHA) |                                   | NORM         | DESIGN       | RATED DIFFERENTIAL PRESSURE |                                 | NORM | DESIGN  |
| =                                 | SUCTION STATIC HEAD               | FT           | -2.91        | =                           | DIFFERENTIAL PRESSURE           | PSI  | 86.90   |
| -                                 | LINE LOSS                         | FT           | 4.25         | +                           | OVERPLUS                        | PSI  | 8.69    |
| +                                 | VESSEL OPERATING PRESSURE         | FT           | 33.63        |                             | RATED DIFFERENTIAL PRESSURE     | PSI  | 95.59   |
| -                                 | VAPOR PRESSURE                    | FT           | 1.06         |                             | RATED DIFFERENTIAL HEAD         | FT   | 221     |
|                                   | NET POSITIVE SUCTION HEAD (NPSHA) | FT           | 25.41        |                             | MAXIMUM SUCTION PRESSURE        | NORM | DESIGN  |
| DISCHARGE PRESSURE                |                                   | NORM         | DESIGN       | =                           | VESSEL PSV SETTING              | PSIA | 14.56   |
| =                                 | DELIVERY PRESSURE                 | PSIA         | 14.7         | +                           | STATIC HEAD FROM HIGH LEVEL     | PSI  | 6.79    |
| +                                 | DISCHARGE STATIC HEAD             | PSI          | 11.12        |                             | MAXIMUM SUCTION PRESSURE        | PSIA | 21.35   |
| +                                 | CONTROL VALVE ΔP                  | PSI          | 0.0          |                             | MAXIMUM DISCHARGE PRESSURE      | NORM | DESIGN  |
| +                                 | HEAT EXCHANGER ΔP                 | PSI          | 0.0          | =                           | MAXIMUM SUCTION PRESSURE        | PSIA | 21.35   |
| +                                 | HEATER ΔP                         | PSI          | 0.0          | +                           | SHUT OFF ΔP ( 1.25 X RATED ΔP ) | PSI  | 119.49  |
| +                                 | FILTER ΔP                         | PSI          | 0.0          |                             | MAXIMUM DISCHARGE PRESSURE      | PSIA | 140.84  |
| +                                 | FLOW METER ΔP                     | PSI          | 1            |                             | REQUIRED BRAKE HORSEPOWER       | NORM | DESIGN  |
| +                                 | LINE LOSS                         | PSI          | 71.54        | =                           | HYDRAULIC POWER                 | HP   | 8.37    |
| +                                 | SPARE DP                          | PSI          | 0.0          | /                           | EST. HYDRAULIC EFFICIENCY       |      | 0.50    |
|                                   | DISCHARGE PRESSURE                | PSIA         | 98.36        |                             | REQUIRED BRAKE HORSEPOWER       | HP   | 16.74   |
| TOTAL DYNAMIC PRESSURE DROP       |                                   | NORM         | DESIGN       | STATIC HEAD                 |                                 | MIN  | MAX     |
| =                                 | SUCTION LINE LOSS                 | PSI          | 1.84         | =                           | DISCHARGE STATIC HEAD           | FT   | 25.67   |
| +                                 | DISCHARGE LINE LOSS               | PSI          | 71.54        | -                           | SUCTION STATIC HEAD             | FT   | -2.91   |
| +                                 | CONTROL VALVE ΔP                  | PSI          | 0.0          |                             | STATIC HEAD                     | FT   | 10.00   |
| +                                 | HEAT EXCHANGER ΔP                 | PSI          | 0.0          |                             |                                 | MIN  | MAX     |
| +                                 | HEATER ΔP                         | PSI          | 0.0          |                             | CONTROL VALVE PRESSURE DROP     | PSI  | N/A     |
| +                                 | FILTER ΔP                         | PSI          | 0.0          |                             |                                 |      |         |
| +                                 | FLOW METER ΔP                     | PSI          | 1            |                             |                                 |      |         |
| +                                 | SPARE DP                          | PSI          | 0.0          |                             |                                 |      |         |
|                                   | TOTAL DYNAMIC PRESSURE DROP       | PSI          | 74.38        |                             |                                 |      |         |


This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

|   |              |                      |
|---|--------------|----------------------|
| <br><b>Pump Calculation Data Sheet</b> | Sheet 2 of 3 | JOB NUMBER<br>744910 |
|   | Page         | 24                   |

|                   |                                 |                         |               |             |             |
|-------------------|---------------------------------|-------------------------|---------------|-------------|-------------|
| CLIENT & LOCATION | DOE SAVANNAH RIVER SITE         | EQUIPMENT NUMBER        | P-205A/B      |             |             |
| PROJECT NO.       | 744910                          | PUMP CALCULATION NO.    | M-CLC-J-00013 |             |             |
| SYSTEM            | Caustic-Side Solvent Extraction | PFD REF. DRAWING NO.    | M-M5-J-0008   |             |             |
| AREA              | J                               | P & ID REF. DRAWING NO. | M-M6-J-0032   | M-M6-J-0033 | M-M6-J-0002 |

**SYSTEM SKETCH**

**8.1 Sketch**




Ref. FL EL 0 ft

**NOTES**

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

|   |              |                      |
|---|--------------|----------------------|
| <p><b>PARSONS</b><br/>Pump Calculation Data Sheet</p> | Sheet 3 of 3 | JOB NUMBER<br>744910 |
|   | Page         | 25                   |



Features | Materials & Sizes | Dimensions | Torques | Flow | PT Chart | How To Order

**XP Sleeved Plug Valves  
Class 150, 2-way, Fig. 067XP  
Cv factors for valve sizing**

| Size  | 2-Way  | 3-Way<br>A, AX, C pos. | 3-Way<br>D pos.<br>0° & 180° | 3-Way<br>D pos.<br>90° | 4-Way | 5-Way |
|-------|--------|------------------------|------------------------------|------------------------|-------|-------|
| 1/2   | 9      | 7                      | 4                            | 5                      | 4     | 6     |
| 3/4   | 9      | 7                      | 4                            | 5                      | 6     | 6     |
| 1     | 43     | 20                     | 11                           | 17                     | 15    | 27    |
| 1 1/2 | 89     | 40                     | 21                           | 37                     | 30    | 42    |
| 2     | 172    | 70                     | 40                           | 47                     | 54    | 69    |
| 3     | 294    | 100                    | 54                           | 87                     | 74    | 120   |
| 4     | 548    | 175                    | 94                           | 159                    | 150   | 200   |
| 6     | 1075   | 350                    | 210                          | 255                    | 340   | 390   |
| 8     | 1591   | 475                    | 360                          | 450                    | 455   | 575   |
| 10    | 2159   | 650                    | 450                          | 750                    | 610   | 785   |
| 12    | 3200   | 965                    | 650                          | 1000                   | 900   | 1160  |
| 14    | 3200   | --                     | --                           | --                     | --    | --    |
| 16    | 5280   | --                     | --                           | --                     | --    | --    |
| 18    | 5600   | --                     | --                           | --                     | --    | --    |
| 20    | 5900   | --                     | --                           | --                     | --    | --    |
| 24    | 11,000 | --                     | --                           | --                     | --    | --    |

**Multi Port Flow Arrangement**


Attachment 11.7

Xomox Valve Data

Sheet 1 of 5

m-clc-3-00013, Rev. B





For more information on Xomox products please [Contact Us](#)

To access all of Xomox's brochures or any Installation, Operation and Maintenance manuals in PDF format please visit our [download section](#)

Copyright © 2005 Xomox Corporation.

Page Last Updated: March 21, 2005

Send comments to [xomox.webmaster@xomox.com](mailto:xomox.webmaster@xomox.com).

Attachment 11.7

Xomox Valve Data

Sheet 2 of 5

m-CLC-J-00013, Rev. B


# XOMOX

Process Valves & Actuators

## Tufline 3-Way Sleeved Plug Valves

FROM THE XOMOX SPECIAL PRODUCTS GROUP

Sheet 3 of 5



Tufline non-lubricated sleeved plug valves are available in a side-entry, 3-way configuration.

This valve incorporates the unique features and benefits of the Tufline line of valves including superior sealing performance and long service life with virtually maintenance free operation.

The Tufline side-entry 3-way valve adds the advantage of more compact, flexible, and economical system design and operation.

### No pockets or cavities.

Unlike many other 3-way valve designs, Tufline sleeved plug valves have no cavities to entrap contaminating media. This is an important consideration for food and pharmaceutical applications.

For applications such as polymers, chemicals, salts, slurries, brines, muds, plastics, or sewage, there are no cavities where the flow media can collect and solidify.

### Self cleaning.

Metal lips completely surround the valve ports. With each rotation of the valve, any scale which may have collected on the plug seal surface is broken-up and wiped away.

### Variety of materials.

For maximum versatility, the Special Products Group offers Tufline 3-way side entry sleeved plug valves in a variety of standard and high-alloy metals.

### Increased flow capacity.

As compared to Tufline's bottom entry 3-way sleeved plug valve, the side entry valve typically offers higher flow capacity.

### Pressure/temperature ratings.

Pressure and temperature ratings for standard sleeved plug valves apply with the exception that the pressure drop should not exceed 170 psig at 100°F while switching.



Tufline Side Entry 3-Way Sleeved Plug Valves  
How to specify

Cv Values

Sheet 4 of 5

| Size  | "AX" Port<br>0° & 90°<br>"D" Port<br>0° & 180° | "D" Port<br>90° |
|-------|--|-----------------|
| 1/2   | 4.5  | 9               |
| 3/4   | 4.5  | 9               |
| 1     | 17.5   | 35              |
| 1 1/2 | 37.5   | 74              |
| 2     | 64   | 146             |
| 3     | 108  | 250             |
| 4     | 193  | 468             |
| 6     | 374  | 936             |
| 8     | 515  | 1400            |
| 10    | 860  | 2159            |
| 12    | 1280   | 3200            |

Size Figure No. Option Body Plug Sleeve Operator Service  
2" - 077 - FT - 2 - 6 - P1 - W - C

**Size & Figure No.**

**Options**

- Fire Tested ..... FT
- Tertiary Top Seal ... TS
- Cage Control .... CCV
- Extended Packing . XP
- Partial Jacket ..... PJ
- Full Jacket ..... FJ

Port Arrangements  
..... "AX" or "D"

*Valve specifications may include multiple options.*

**Body**

- Alloy 20 ..... 0
- Carbon Steel ... 2
- Monel ..... 3
- Nickel ..... 5
- 316SS ..... 6
- Hastelloy B .... 8
- Hastelloy C .... 9
- Inconel ..... 40
- Other (Specify) . X

**Service**

- Chlorine .. C
- Oxygen .. O
- Vacuum .. V
- General Service ... Blank
- Other\*\* ... X

**Operator**

- Less Operator ... N
- Wrench ..... W
- Wrench with locking device . WY
- Gear ..... G
- Gear with locking device.. GZ
- Actuator\* ..... A

**Sleeve**

- PTFE ..... P1
- 15% RPTFE . P2
- 25% RPTFE . P3
- PFA ..... P6
- Xomox-7 .... P7
- UHMWPE ... P8
- Tufline-475 . P16
- Tufline-600 . P20
- Other (Specify) ... PX

**Plug**

- Alloy 20 ..... 0
- Monel ..... 3
- 304SS ..... 4
- Nickel ..... 5
- 316SS ..... 6
- Hastelloy B .... 8
- Hastelloy C .... 9
- Inconel ..... 40
- Other (Specify) . X

\* Specify actuator type and available air supply.

\*\* Consult your Xomox Sales Engineer for a wide variety of other available service options.

M-CLC-J-00013, Rev. B

# Tuffline 120° 3-Way Full Port Sleeved Plug Valve

Sheet 5 OF 5

**Facilitates more efficient and more economical system design.**

The Tuffline 120° Full Port 3-way Sleeved Plug Valve replaces conventional and cumbersome pipe "T" and twin block valve arrangements.

**Improved flow characteristics.**

In addition to the improved flow provided by the full port configuration, the 120° flow pattern provides greater flow efficiency than 90° 3-way valves.

**Additional design features.**

In addition to the unique design features found in the standard-port and 2-way full port configurations, this valve offers:

- Configuration for cleaning with a mechanical pig.
- 120° and 240° manual or automated operation.
- Visual indication of flow direction.
- Allows transflow when switching.


**Appropriate applications.**

This valve is ideal for dual safety relief valve switching and other applications where low pressure drop and high flow efficiency are important.

This design offers significant advantages for handling slurries, diversion, or blending where full flow and the ability to scrape or "pig" the line to remove solids buildup are desirable.

## Port arrangements.

In the diagrams at the right, the color indicates the path of fluid flow.




## Cv factors.

| Size  | Cv Factors For Valve Sizing | Valve Break Torques ft.lbs* (PTFE Sleeve) |
|-------|-----------------------------|---|
| 1/2   | 36                          | 25  |
| 3/4   | 90                          | 123                                       |
| 1     | 175                         | 123                                       |
| 1 1/2 | 400                         | 585                                       |
| 2     | 725                         | 630                                       |
| 3     | 1750                        | 1417                                      |
| 4     | 3200                        | 2667                                      |


\* For Tuffline-600 sleeves, multiply valve break torques by 1.35.

## Pressure-temperature ratings.



# PARSONS

## Salt Waste Processing Facility (SWPF)



Map prepared by David Hix, P&GS  
Savannah River Site, Aiken, SC

FSS-GIS-2006-00008  
Approved for Public Release

Title: Salt Waste Processing Facility Phase II  
Location Map

Doc. No: FSS-GIS-2005-00008  
Revision: 0

**PARSONS**

**Salt Waste Processing Facility (SWPF)**

**SWPF PROCESS TANKS**

| TK-<br>Number | Tank Name                              | Tank Description   | Working Volume (gallons) | Working Diameter (feet) | Height or Length (feet) | Material | Process Flow Diagram Number |
|---------------|--|--|--------------------------|-------------------------|-------------------------|----------|-----------------------------|
| TK-101        | Alpha Sorption Tank-A (AST-A)          | Receives HLW and mixes with MST for strontium/actinide adsorption process.     | 28,700                   | 19'-0"                  | 16'-10"                 | 316L SS  | M-M5-J-0002                 |
| TK-102        | Filter Feed Tank-A (FFT-A)             | Used to supply filters and store concentrated slurry.                          | 31,300                   | 19'-0"                  | 16'-10"                 | 316L SS  | M-M5-J-0002                 |
| TK-103        | Cleaning Solution Dump Tank-A (CSDT-A) | Receives spent cleaning solution during filter cleaning cycles.                | 850                      | 5'-0"                   | 7'-3"                   | 316L SS  | M-M5-J-0002                 |
| TK-104        | Sludge Solids Receipt Tank (SSRT)      | Receives sludge from the FFT-A and MST/Sludge Transfer Tank from AFF.          | 5,200                    | 9'-0" - 13'-0"          | 23'-10"                 | 316L SS  | M-M5-J-0004                 |
| TK-105        | Wash Water Hold Tank (WWHT)            | Receives and stores wash water until transfer to AST                           | 11,500                   | 12'-0"                  | 15'-11"                 | 316L SS  | M-M5-J-0004                 |
| TK-106        | Oxalic Acid Feed Tank                  | Used to mix and store oxalic acid for transfer to CSDT for filter cleaning.    | 850                      | 7'-0"                   | 15'-0"                  | 304L SS  | M-M5-J-0005                 |
| TK-107        | Filter Cleaning Caustic Tank           | Used to mix and store caustic prior to transfer to CSFT for filter cleaning.   | 850                      | 6'-0"                   | 6'-0"                   | 304L SS  | M-M5-J-0005                 |
| TK-108        | Caustic Dilution Feed Tank             | Used to mix 1.66 M caustic solution feed to TK-101 (AST-A).                    | 8,000                    | 11'-0"                  | 15'-0"                  | 304L SS  | M-M5-J-0005                 |
| TK-109        | Salt Solution Feed Tank (SSFT)         | Used to stage Clarified Salt Solution for feed to cesium extraction contactors | 41,400                   | 21'-0"                  | 16'-3"                  | 316L SS  | M-M5-J-0006                 |
| TK-127        | Spent Oxalic Acid Storage Tank         | Used to collect and store used oxalic acid from the filter cleaning cycle      | 3,400                    | 6'-0"                   | 20'-0"                  | 316L SS  | M-M5-J-0018                 |
| TK-202        | Solvent Hold Tank (SHT)                | Used to hold solvent   | 500                      | 5'-0"                   | 5'-5"                   | 316L SS  | M-M5-J-0007                 |
| TK-204        | Caustic Wash Tank                      | Used to hold caustic 0.01M wash solution                                       | 400                      | 4'-0"                   | 5'-9"                   | 316L SS  | M-M5-J-0008                 |
| TK-205        | Strip Effluent Hold Tank (SEHT)        | Used to receive strip effluent   | 16,600                   | 14'-0"                  | 16'-10"                 | 316L SS  | M-M5-J-0008                 |

## PARSONS

## Salt Waste Processing Facility (SWPF)

| SWPF PROCESS TANKS |   |  |                          |                 |                         |          |                             |
|--------------------|---|--|--------------------------|-----------------|-------------------------|----------|-----------------------------|
| Tank Number        | Tank Name                                   | Tank Description   | Working Volume (gallons) | Diameter (feet) | Height or Length (feet) | Material | Process Flow Diagram Number |
| TK-206             | Ba-137 Decay Tank (BDT)                     | Used for DSS holdup to allow <sup>137m</sup> Ba decay.   | 1,200                    | 7'-0"           | 6'-6"                   | 316L SS  | M-M5-J-0007                 |
| TK-207             | DSS Hold Tank (DSSHT)                       | Used to store decontaminated salt solution prior to transfer to Tank 50 or Saltstone.  | 35,900                   | 19'-0"          | 19'-8"                  | 316L SS  | M-M5-J-0009                 |
| TK-208             | Solvent Drain Tank                          | Used to collect drainage and flush from the CSSX contactors and to hold solvent recovered from Strip Effluent Coalescer TK-203                           | 4,300                    | 6'-0"           | 20'-0"                  | 316L SS  | M-M5-J-0006                 |
| TK-211             | Decontaminated Salt Solution Stillling Tank | Used to separate aqueous from organic liquids.   | 235                      | 2'-0"           | 10'-0"                  | 316L SS  | M-M5-J-0007                 |
| TK-212             | Strip Effluent Stillling Tank               | Used to separate aqueous from organic liquids  | 29                       | 1'-0"           | 5'-0"                   | 316L SS  | M-M5-J-0008                 |
| TK-215             | Strip Effluent Pump Tank                    | Receives strip effluent from the Strip Effluent Coalescer, allows for <sup>137m</sup> Ba ingrowth, and transfers strip effluent to TK-205 via P-215 A/B. | 50                       | 1'-6"           | 4'-11"                  | 316L SS  | M-M5-J-0008                 |
| TK-217             | Solvent Strip Feed Tank                     | Used to allow a hold-up volume for the solvent strip feed pumps  | 50                       | 1'-6"           | 4'-11"                  | 304L SS  | M-M5-J-0007                 |
| TK-220             | Intermediate Storage Tank (IST)             | Receives DSS from Ba-137 Decay Tank and sends DSS to TK-221 for second MST strike or for use as storage for sampling during single strike mode.          | 30,300                   | 19'-0"          | 16'-10"                 | 316L SS  | M-M5-J-0015                 |
| TK-221             | Alpha Sorption Tank - B (AST-B)             | Receives DSS from Intermediate Storage Tank for second MST strike or for use as a storage for sampling during single strike mode                         | 30,700                   | 19'-0"          | 16'-10"                 | 316L SS  | M-M5-J-0015                 |
| TK-222             | Filter Feed Tank - B (FFT-B)                | Used to supply filters and store concentrated slurry from second MST strike.   | 31,900                   | 19'-0"          | 16'-10"                 | 316L SS  | M-M5-J-0015                 |
| TK-223             | Cleaning Solution Dump Tank - B (CSDT-B)    | Receives cleaning solution during filter cleaning cycles.  | 850                      | 5'-0"           | 7'-3"                   | 316L SS  | M-M5-J-0015                 |

## PARSONS

## Salt Waste Processing Facility (SWPF)

| SWPF PROCESS TANKS |                                  |   |                  |                         |              |                             |
|--------------------|----------------------------------|---|------------------|-------------------------|--------------|-----------------------------|
| Tank Number        | Tank Name                        | Tank Description  | Volume (Gallons) | Height or Length (Feet) | Material     | Process Flow Diagram Number |
| TK-224             | MST/Sludge Transfer Tank (MSTT)  | Holds MST/Sludge from second strike before transfer to TK-101 or TK-104   | 1,600            | 9'-9"                   | 316L SS      | M-M5-J-0015                 |
| TK-235             | Lab Drain Tank                   | Used to collect material from lab drains.                                 | 450              | 6'-8"                   | 316L SS      | M-M5-J-0018                 |
| TK-301             | Process Water Tank               | Used to store process water.  | 8,000            | 15'-0"                  | Polyethylene | M-M5-J-0010                 |
| TK-302             | Caustic Receipt Tank             | Used to receive and store 50% caustic                                     | 8,000            | 15'-0"                  | 304L SS      | M-M5-J-0010                 |
| TK-303             | Caustic Makeup Tank              | Used to make up 0.01 M caustic.   | 2,000            | 10'-0"                  | 304L SS      | M-M5-J-0010                 |
| TK-304             | Nitric Acid Receipt Tank         | Used to receive and store 20% wt Nitric Acid                              | 2,000            | 10'-0"                  | 304L SS      | M-M5-J-0011                 |
| TK-307             | Nitric Acid Scrub Makeup Tank    | Used for make-up and storage of scrub nitric acid solution.               | 2,000            | 10'-0"                  | 304L SS      | M-M5-J-0011                 |
| TK-311             | MST Storage Tank                 | Used to mix and store MST slurry prior to transfer to the AST-A or AST-B. | 800              | 7'-0"                   | 316L SS      | M-M5-J-0005                 |
| TK-312             | DI Water Storage Tank            | Used to store DI water.   | 6,000            | 16'-0"                  | Polyethylene | M-M5-J-0010                 |
| TK-313             | Solvent Makeup Tank              | Used for solvent makeup.  | 50               | 3'-0"                   | 304L SS      | M-M5-J-0013                 |
| TK-601             | Alpha Sorption Drain Tank (ASDT) | Used to collect ASP area drains until disposition determined.             | 3,400            | 20'-0"                  | 316L SS      | M-M5-J-0018                 |



## PARSONS

## Salt Waste Processing Facility (SWPF)

| SWPF SPECIFICATIONS |   |     |                       |
|---------------------|---|-----|-----------------------|
| Number              | Title   | Sup | Discipline            |
| 03100               | Structural Concrete Formwork                            | 0   | Structural            |
| 03200               | Concrete Reinforcement                                  | 0   | Structural            |
| 03250               | Expansion Joints, Contraction Joints, and Waterstops    | 0   | Structural            |
| 03300               | Cast-in-Place Concrete                                  | 0   | Structural            |
| 03305               | Miscellaneous Cast-in-Place Concrete                    | A1  | Civil                 |
| 03315               | Non-Shrink Grout  | 0   | Structural            |
| 03410               | Plant Pre-cast Structural Concrete                      | 0   | Structural            |
| 05055               | Welding, Structural                                     | 0   | Structural            |
| 05120               | Structural Steel  | 0   | Structural            |
| 05310               | Steel Roof Decking                                      | 0   | Structural            |
| 05320               | Composite Steel Decking                                 | 0   | Structural            |
| 05505               | Miscellaneous Metals                                    | 0   | Structural            |
| 11811               | ASME Small Vessels                                      | 1   | Mechanical            |
| 11812               | Steel Tanks   | 0   | Mechanical            |
| 11813               | ASME Large Vessels (PP-17A)                             | 1   | Process               |
| 11814               | Polyethylene Tanks                                      | 0   | Mechanical            |
| 11815               | Fabrication of Stainless Steel Sumps                    | 0   | Mechanical            |
| 11817               | Positive Material Identification                        | 0   | Mechanical            |
| 11818               | ASME Vessels - Carbon Steel                             | E2  | Mechanical            |
| 11819               | Seismic Qualification Criteria for Mechanical Equipment | 0   | Mechanical            |
| 11821               | Centrifugal Pumps (PC-1)                                | 0A2 | Mechanical            |
| 11822               | Seismic Qualification Criteria for PC-3 Pumps           | 0   | Mechanical            |
| 11823               | Rotary Gear Pumps (PC-1)                                | 1   | Mechanical            |
| 11824               | Air Diaphragm Pumps                                     | 0A2 | Mechanical            |
| 11825               | Centrifugal Pumps (PC-3)                                | 0   | Mechanical            |
| 11826               | Rotary Gear Pumps (PC-3)                                | 0   | Mechanical            |
| 11827               | Rotary Gear Pumps (PC-1, GS-2, PL-4)                    | 1   | Mechanical            |
| 11831               | Mechanical Agitators                                    | 0   | Mechanical            |
| 11841               | Compressed Air System                                   | 0   | Mechanical            |
| 11842               | Backup Air Receivers Compressor                         | 0   | Mechanical            |
| 11852               | Shell and Tube Heat Exchangers                          | E3  | Mechanical            |
| 11855               | Heaters (Electric)                                      | 0   | Mechanical            |
| 11903               | Cross-Flow Filters                                      | F   | Engineering Mechanics |
| 11904               | Tank Mixing Eductors                                    | 0   | Mechanical            |
| 14510               | Sample Transfer System                                  | 0   | Material Handling     |
| 14512               | Oxalic Acid Loading System                              | B1  | Material Handling     |
| 14513               | Drum Tumbler  | 0   | Material Handling     |
| 14516               | Gloveboxes  | 0   | Material Handling     |
| 14518               | Hot Cell Stainless Steel Lining                         | 0   | Material Handling     |
| 14519               | Fabrication of Specialty Equipment                      | 0   | Material Handling     |
| 15080               | Thermal Insulation                                      | 1   | Piping                |
| 15085               | Bolting Procurement (Piping)                            | 0   | Piping                |
| 15111               | Pipe Fabrication  | 0A2 | Piping                |
| 15112               | Pipe Leak Testing                                       | 0   | Piping                |
| 15113               | Piping Specialty Item Procurement                       | 0   | Piping                |
| 15114               | General Piping Material Procurement                     | 0   | Piping                |
| 15115               | Valve Procurement                                       | 0   | Piping                |
| 15116               | Pipe Procurement  | 0   | Piping                |
| 15117               | Fitting Procurement                                     | 0   | Piping                |
| 15118               | Flange Procurement                                      | 0   | Piping                |
| 15119               | Orskot Procurement                                      | 1   | Piping                |
| 15120               | Piping Material Specification                           | 0   | Piping                |
| 15121               | Field Installation of Process Piping                    | 0   | Piping                |
| 15123               | Protective Coatings - Underground Steel Pipe            | 0   | Mechanical            |
| 15140               | Waste Transfer Line Casing Spacer                       | C2  | Piping                |
| 15185               | Hydronic Pumps  | B1  | HVAC                  |
| 15201               | Seismic Restraint of Mechanical Systems and Equipment   | B1  | HVAC                  |
| 15221               | Chemical Drains Trade Waste                             | 0   | Fire Protection       |
| 15330               | Fire Protection Wet Pipe Sprinkler System               | 0   | Fire Protection       |
| 15331               | Fire Protection Interior Distribution System            | 0   | Fire Protection       |
| 15332               | Fire Protection Underground Water Supply System         | 0   | Fire Protection       |
| 16231               | Standby Diesel Generator Package                        | 0   | Electrical            |
| 16641               | Cathodic Protection                                     | 0   | Electrical            |
| 16721               | Fire Alarm and Detection System                         | 0   | Fire Protection       |
| M-SPC-J-00002       | Positive Material Identification                        | 0   | Vessel                |
| SPC-ME-6204-0002    | BOBCalixC6  | 1   | Chemical              |
| SPC-ME-6204-0003    | Ct-7SB  | 1   | Chemical              |
| SPC-ME-6204-0005    | CSSX Solvent Mixing                                     | 3   | Chemical              |
| X-SPC-J-00007       | Centrifugal Contactor Modules                           | 1   | Mechanical            |
| X-SPC-J-00008       | Centrifugal Contactors                                  | 0   | Mechanical            |

BOARD:  
Paul C. Aughtry, III  
Chairman  
Edwin H. Cooper, III  
Vice Chairman  
Steven G. Kisner  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment*

BOARD:  
Henry C. Scott  
M. David Mitchell, MD  
Glenn A. McCall  
Coleman F. Buckhouse, MD

## BUREAU OF WATER

April 04, 2008

JAMES SOMMA  
PARSONS INFRASTRUCTURE AND TECHNOLOGY GROUP INC  
1080 SILVER BLUFF RD  
AIKEN SC 29803

Re: **SRS/SALT WASTE PROCESSING FACILITY/PHASE 2**  
Aiken County  
Application Tracking # 818672

Dear James Somma:

The Industrial Wastewater Permitting section received an engineering submittal on the above project on 04/04/2008. In accordance with R.61-30 we have reviewed your application for completeness. Based on our review, your project application package is administratively incomplete. For this reason, your project will not be in line for a technical review until you satisfy the deficiencies noted below. As a courtesy, we have logged in your project and will keep it here pending your complete response. To complete your application package, please provide the following items:

1. Three (3) copies of pump station calculations and pump curves need to be submitted.
2. Three (3) copies of flow calculations must be submitted justifying the sizing of the lines and/or equipment.
3. Three (3) copies of a detailed 8 ½" by 11" location map must be submitted.
4. Three (3) sets of signed and sealed specifications must be submitted. Specifications should include all materials of construction (e.g. PVC pipe or stainless steel tanks) and sizes of equipment.
5. A letter of acceptance from the owner stating that they have adequate equipment and personnel to operate and maintain the proposed sewer system must be submitted.
6. A SC registered PE must sign and seal all plans and specifications and the Certificate of Authorization (COA) from the engineering firm must also be affixed near the PE seal. Please resubmit these documents with the appropriate seals. Please note: If the plans and specifications are bound (a staple is sufficient for this purpose), then it is only necessary to place

Letter to Mr. Somma  
April 4, 2008  
Page 2 of 2

the COA and PE seal/signature on the front of the bound document. If the plans and specifications are not bound, then each page must include the COA and the PE seal/signature.


7. The person who signed as owner does not appear to meet the requirements of the application instructions in Part XV. Please resubmit a revised permit application with the appropriate owner's signature (one original and 3 copies) or submit a letter describing how the person who signed meets these requirements.

Please return the above noted items as soon as possible. Failure to submit these items will result in significant delays in the review process.

Also, please note that any land clearing activity that is being performed in relation to this project must be permitted under the State Sediment and Erosion Control Program. For more information contact Ann Clark at (803) 898-4028.

If you have any questions, please do not hesitate to contact this office at 803-898-3964.

Sincerely,



Crystal Rippy, Manager  
Industrial Wastewater Permitting Section  
Water Facilities Permitting Division



**SAVANNAH RIVER SITE**

Aiken, SC 29808 • www.srs.gov

ESH-EPG-2008-00048

April 2, 2008

Mr. Barry S. Mullinax, P.E.  
Industrial Wastewater Permitting Section  
Bureau of Water  
South Carolina Department of Health and  
Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

**RECEIVED**  
APR 04 2008  
WATER FACILITIES  
PERMITTING DIVISION

Re: Construction Permit No.: 19,164-IW  
Salt Waste Processing Facility  
J-Area of the Savannah River Site  
Aiken County

Dear Mr. Mullinax:

Enclosed for your review and approval please find three (3) sets of the Construction Permit Application form, Engineering Report, and application fee for Phase II of the Salt Waste Processing Facility. One Engineering Report is identified as Official Use Only (OUO) which requires U.S. Department of Energy review prior to public disclosure. The other two sets are redacted versions of the OUO Report. This package pertains to the building to be constructed in J-Area that will house the main salt waste treatment units of the Salt Waste Processing Facility, including the Actinide Finishing, Caustic-Side Solvent Extraction, and the Alpha Strike Processes.

The Salt Waste Processing Facility is a specialized radioactive waste treatment facility. This facility is not included in any of the wastewater treatment plant classifications under the South Carolina Pollution Control Act (i.e., Section 48-1-110). Therefore, in addition to the issuance of a construction permit, we request that no wastewater treatment facility operator-in-charge, required to hold a certificate of registration issued by the South Carolina Environmental Certification Board, be included as a condition for the construction or operation of this facility. The F- and H-Area Tank Farm facilities, Defense Waste Processing Facility, and the Saltstone Production Facility do not require such certified operators.

S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

We look forward to your approval and issuance of a construction permit for this facility as soon as practicable. If you have any questions, please call me at 803-952-7382.

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

Sincerely,

Ronald M. Campbell  
Environmental Services Section  
Washington Savannah River Company LLC

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008

DIRECTOR, WATER FACILITIES PERMITTING DIVISION

RMC/r  
Enc.

- c: M. P. Prater, 730-B
- G. S. Hoover, 730-B
- D. F. Hoel, 730-B
- M.D. Sherritt, SCDHEC \*

- V. E. Millings III, SCDHEC Region 5 EQC \*\*
- J. C. Yon, SCDHEC Region 5 EQC \*\*
- R. T. Caldwell II, SCDHEC Region 5 EQC \*\*

\* - Transmittal Letter Only / \*\* - Redacted Version Only

**WASHINGTON SAVANNAH RIVER COMPANY**

The **WSRC Team**: Washington Savannah River Company LLC • Bechtel Savannah River, Inc. • BNG America Savannah River Corporation • BWXT Savannah River Company • CH2 Savannah River Company

R

**RECEIVED**  
APR 04 2008

**United States Department of Energy**  
**Salt Waste Processing Facility**

**Savannah River Site**  
**Aiken, South Carolina**

**Engineering Report**

for an

**Industrial Wastewater Treatment Facility**

Prepared By

**PARSONS**

**1080 Silver Bluff Road**  
**Aiken, South Carolina 29803**

for the

**United States Department of Energy**

**Function: Environmental Permitting**  
**Doc. No.: Q-PER-J-00002**  
**Revision: 2**  
**Date: 03/25/2008**


S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)  
FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008

*[Signature]*  
DIRECTOR, WATER FACILITIES PERMITTING DIVISION



**TABLE OF CONTENTS**

|            |  |           |
|------------|--|-----------|
| <b>1.0</b> | <b>ENGINEERING REPORT.....</b>   | <b>1</b>  |
| <b>2.0</b> | <b>BACKGROUND INFORMATION .....</b>                                      | <b>3</b>  |
| <b>3.0</b> | <b>SALT WASTE PROCESSING FACILITY LOCATION AND FACILITY LAYOUT .....</b> | <b>4</b>  |
| <b>4.0</b> | <b>COMPREHENSIVE DESCRIPTION OF PROPOSED SWPF PROJECT.....</b>           | <b>7</b>  |
| 4.1        | Waste Transfer Line Segments.....  | 9         |
| 4.2        | Wastewater Receipt from Tank Farms.....                                  | 9         |
| 4.3        | SWPF Process Design.....   | 12        |
| 4.3.1      | Alpha Strike Process.....  | 12        |
| 4.3.2      | Caustic-side Solvent Extraction Process.....                             | 18        |
| 4.3.3      | Alpha Finishing Process .....  | 23        |
| 4.4        | Wastewater Transfer to DWPF and SPF .....                                | 25        |
| 4.4.1      | Transfer of MST Sludge from the SWPF to LPPP and DWPF .....              | 25        |
| 4.4.2      | Transfer of Strip Effluent from the SWPF to the LPPP and DWPF.....       | 25        |
| 4.4.3      | Transfer of DSSHT from the SWPF to SPF.....                              | 26        |
| 4.5        | Cold Chemicals Area .....  | 26        |
| 4.6        | Distributed Control System .....   | 27        |
| 4.7        | Equipment and Service Failure or Shutdown .....                          | 27        |
| 4.7.1      | Redundant Pumps and Filters .....  | 27        |
| 4.7.2      | Maintainability.....   | 28        |
| 4.7.3      | SWPF Containment and Ventilation System Design.....                      | 28        |
| 4.7.4      | Miscellaneous Process Systems.....                                       | 30        |
| 4.7.5      | Back-up Power .....  | 31        |
| <b>5.0</b> | <b>WASTE CHARACTERISTICS AND TREATABILITY.....</b>                       | <b>31</b> |
| 5.1        | Wastewater Influent Characteristics and Flow Rate .....                  | 32        |
| 5.2        | Wastewater Treatability.....   | 33        |
| 5.3        | Wastewater Effluent Characteristics and Flow Rate .....                  | 34        |
| <b>6.0</b> | <b>OTHER RELEASES TO THE ENVIRONMENT .....</b>                           | <b>36</b> |
| 6.1        | Utility Water Effluents .....  | 36        |
| 6.2        | Air Emissions.....   | 37        |
| 6.2.1      | Radiological Air Emissions .....   | 37        |
| 6.2.2      | Toxic and Criteria Pollutant Emissions.....                              | 37        |
| 6.3        | Title V Operating Permit .....   | 37        |

**TABLE OF CONTENTS (cont.)**

**7.0 REFERENCES.....37**

**List of Figures**

**Figure 1-1. Savannah River Site Liquid Radioactive Waste System .....2**  
**Figure 3-1. Salt Waste Processing Facility General Layout .....5**  
**Figure 3-2. Three Dimensional, Preliminary Design View of the SWPF Process Building...6**  
**Figure 4-1. Salt Waste Processing Facility Simplified Process Flow Diagram .....8**  
**Figure 4-2. Transfer Flow Paths Between SWPF and the Tank Farm, DWPF, and SPF ...11**  
**Figure 4-3. FFT-A Filter Circuit Flow Diagram.....14**  
**Figure 4-4. Conceptual Schematic of a Cross-Flow Filter .....15**  
**Figure 4-5. MST Sludge Washing Flow Diagram .....17**  
**Figure 4-6. Caustic-side Solvent Extraction Process .....20**  
**Figure 4-7. Cutaway View of Centrifugal Contactor .....21**

**List of Tables**

**Table 5-1. SWPF ASP Decontamination Factors.....33**  
**Table 5-2. SWPF MST/Sludge and Strip Effluent Characteristics .....35**  
**Table 5-3. SWPF DSS Effluent Characteristics .....36**

**List of Attachments**

**Attachment A. Process Building General Arrangement.....A1**  
**Attachment B. Process Flow Drawings.....B1**

**LIST OF ACRONYMS AND ABBREVIATIONS**

|  |   |
|--|---|
| %  | Percent   |
| AFF  | Alpha Finishing Facility                                    |
| AFP  | Alpha Finishing Process                                     |
| APA  | Air Pulse Agitator  |
| ARP  | Actinide Removal Process                                    |
| ASDT   | Alpha Sorption Drain Tank                                   |
| ASP  | Alpha Strike Process  |
| AST-A  | Alpha Sorption Tank-A (in the Alpha Strike Process)         |
| AST-B  | Alpha Sorption Tank-B (in the Alpha Finishing Process)      |
| Ba   | Barium  |
| BDT  | Barium-137 Decay Tank                                       |
| CCA  | Cold Chemicals Area   |
| CFF  | Cross-Flow Filter   |
| Ci   | Curie   |
| CPA  | Central Processing Area                                     |
| CR   | Control Room  |
| CSDT-A                                       | Cleaning Solution Dump Tank-A (in the Alpha Strike Process) |
| Cs   | Cesium  |
| CSS  | Clarified Salt Solution                                     |
| CSSX   | Caustic-side Solvent Extraction                             |
| DCS  | Distributed Control System                                  |
| Drum Off/Decon Area                          | Decontamination Area  |
| Decon Room                                   | Decontamination Room  |
| DF   | Decontamination Factor                                      |
| DG   | Diesel Generator  |
| DOE  | U.S. Department of Energy                                   |
| DSS  | Decontaminated Salt Solution                                |
| DSSHT  | Decontaminated Salt Solution Hold Tank                      |
| DWPF   | Defense Waste Processing Facility                           |
| EPC  | Engineering, Procurement, and Construction (Contractor)     |
| FFA  | Federal Facility Agreement                                  |
| FFT-A  | Filter Feed Tank-A (in the Alpha Strike Process)            |
| FFT-B  | Filter Feed Tank-B (in the Alpha Finishing Process)         |
| g/L  | Grams per liter   |
| GA   | General Arrangement   |
| H <sub>2</sub> C <sub>2</sub> O <sub>2</sub> | Oxalic acid   |
| HEPA   | High-Efficiency Particulate Air                             |
| HNO <sub>3</sub>                             | Nitric acid   |
| IST  | Intermediate Storage Tank                                   |
| lb/hr  | Pounds per hour   |
| LPPP   | Low Point Pump Pit  |
| LRW  | Liquid Radioactive Waste                                    |
| LWC  | Liquid Waste Contractor                                     |



**LIST OF ACRONYMS AND ABBREVIATIONS (cont.)**

|                 |   |
|-----------------|---|
| M               | Moles/Liter (Molar)   |
| Mgal            | Million gallons   |
| MST             | Monosodium Titanate   |
| Na              | Sodium  |
| Na <sup>+</sup> | Sodium ion  |
| NaOH            | Sodium hydroxide  |
| nCi/g           | Nanocuries per gram   |
| P&VG            | Pump and Valve Gallery  |
| PCP             | Precipitate Process (Transfer Line)                           |
| PFD             | Process Flow Diagram  |
| PMVS            | Pulse Mixer Ventilation System                                |
| PPT             | Precipitate Pump Tank   |
| PVVS            | Process Vessel Ventilation System                             |
| ROD             | Record of Decision  |
| SCDHEC          | South Carolina Department of Health and Environmental Control |
| SCR             | South Carolina Regulation                                     |
| SDF             | Saltstone Disposal Facility                                   |
| SDT             | Solvent Drain Tank  |
| SEHT            | Strip Effluent Hold Tank                                      |
| SEIS            | Supplemental Environmental Impact Statement                   |
| SHT             | Solvent Hold Tank   |
| SPF             | Saltstone Production Facility                                 |
| Sr              | Strontium   |
| SRS             | Savannah River Site   |
| SSFT            | Salt Solution Feed Tank                                       |
| SSRT            | Sludge Solids Receipt Tank                                    |
| STP             | Site Treatment Plan   |
| SWPF            | Salt Waste Processing Facility                                |
| TCDS            | Telecommunications and Control Datalink System                |
| TOA             | Tri-n-octylamine  |
| UPS             | Uninterruptible Power Supply                                  |
| WAC             | Waste Acceptance Criteria                                     |
| wt%             | Weight percent  |
| WWHT            | Wash Water Hold Tank  |
| WTE             | Waste Transfer Enclosure                                      |
| WTL             | Waste Transfer Lines  |


## **1.0 ENGINEERING REPORT**

This Engineering Report is being submitted pursuant to South Carolina Regulation (SCR) 61-67 (*Standards for Wastewater Facility Construction*<sup>1</sup>). This Engineering Report describes the location, industrial wastewater treatment processes, wastewater characteristics, wastewater treatability, and configuration of the proposed U.S. Department of Energy (DOE) Salt Waste Processing Facility (SWPF) at Savannah River Site (SRS).

The SWPF is being designed to treat approximately 34 million gallons (Mgal) of liquid radioactive waste (LRW) currently stored in underground waste storage tanks in the SRS F- and H-Area Tank Farms. The primary function of the SWPF is to extract and concentrate cesium (Cs), strontium (Sr), and actinides from the Tank Farm wastewater to render the wastewater acceptable for treatment as decontaminated salt solution (DSS) in the SRS Saltstone Production Facility (SPF). The DSS will be transferred via underground pipe to the SPF and immobilized and disposed as grout at the Saltstone Disposal Facility (SDF). The SWPF concentrate will be transferred via underground pipe to the SRS Defense Waste Processing Facility (DWPF) for vitrification. The vitrified waste is stored in the SRS Glass Waste Storage Building, pending final disposition at the National Geological Repository.

Figure 1-1 provides an overview of SWPF integration into the SRS LRW System. As shown in Figure 1-1, SWPF receives wastewater influent from F- and H-Area. SWPF wastewater effluents are transferred to the DWPF and SPF wastewater facilities for further treatment. The Tank Farms, DWPF, and SPF operate under South Carolina Department of Health and Environmental Control (SCDHEC) industrial wastewater treatment facility and air quality permits. The SPF transfers grout to the SDF, which operates under an SCDHEC Industrial Solid Waste Landfill Permit. The SWPF will have no industrial wastewater discharges to the environment.

Figure 1-1-1. Savannah River Site Liquid Radioactive Waste System



**ACRONYM LIST**

|       |   |
|-------|---|
| ARP   | - Actinide Removal Process                    |
| AFP   | - Alpha Finishing Process                     |
| ASP   | - Alpha Strike Process                        |
| CSS   | - Clarified Salt Solution                     |
| DSS   | - Decontaminated Salt Solution                |
| CSSX  | - Caustic-side Solvent Extraction             |
| DWPF- | Defense Waste Processing Facility             |
| ESP   | - Extended Sludge Processing                  |
| DDA   | - Deliquification, Dissolution and Adjustment |
| MST   | - Monosodium Titanate                         |
| SPF/  | - Saltstone Production Facility/              |
| SDF   | - Saltstone Disposal Facility                 |

\* Transfers of salt solution to ARP may be discontinued after SWPF startup.

Facility features described herein, including numerical values assigned to process parameters or equipment specifications, may be subject to change as the design is further refined and finalized. Construction of the SWPF will begin after SCDHEC issues approval. The scheduled construction start date is June 2008 and Construction is currently projected to be completed by December 2011.

Limited Construction activities commenced in September 2007. Limited Construction includes: site preparation, including site clearing and grubbing; site utilities; electrical; excavation; grading; installation of the mud and base mat for the Process Building; and installation of stormwater control structures. Additionally, under SCDHEC Phase 1 Waste Transfer Line (WTL) Construction Permit No. 19,164-IW, the WTL segments will be installed in July 2008. SWPF stormwater control structures have been permitted by SCDHEC (Permit # SCR10H152<sup>2</sup>) under a Notice of Intent for Stormwater Discharges from Large and Small Construction Activities, National Pollutant Discharge Elimination System General Permit SCR100000<sup>3</sup>.

During Construction, the Engineering, Procurement and Construction (EPC) Contractor (Parsons) will contact SCDHEC representatives on a periodic basis to witness the construction progress occurring in J-Area. The EPC will provide notification to SCDHEC of the schedule for final closure of major process areas, such as the dark cells. SCDHEC is requested to identify any other specific areas that they may wish to observe before covering the excavations. Quarterly updates will be issued on progress, as well as on scheduled activity.

Following completion of Construction, initial testing (Cold Commissioning) will be performed prior to the tie-ins to the liquid waste processing facilities to confirm that all major processes and equipment perform as designed. Water runs will be followed by non-radioactive simulant runs. The products from this testing will be disposed in accordance with SCDHEC's Wastewater or Solid and Hazardous Waste Management Regulations. After SCDHEC issues an operating permit following Cold Commissioning, the tie-ins to the liquid waste processing facilities will be performed and Hot Commissioning will begin. Hot Commissioning is planned to commence as described in the quarterly status reports submitted to SCDHEC. SWPF Design, Construction, Commissioning, and one year of Operations will be completed by the EPC.

## **2.0 BACKGROUND INFORMATION**

Nuclear material production and processing at SRS generated millions of gallons of liquid radioactive waste (LRW) that is presently stored in underground waste storage tanks in the SRS F- and H-Area Tank Farms. Approximately 37 Mgal of the waste remains in the F- and H-Area Tank Farms and includes approximately 3 Mgal of sludge, comprising insoluble and precipitated solids, and 34 Mgal of salt solution and crystallized salts. The SWPF's function is to extract and concentrate the radioactive constituents from the salt solution and crystallized salts. The 3 Mgal of sludge will be retrieved and sent to the Extended Sludge Processing facilities and then to DWPF.

The SRS *Approved Site Treatment Plan* (WSRC-TR-94-0608<sup>4</sup>) (STP) and the *Federal Facility Agreement for the Savannah River Site* (WSRC-OS-94-92<sup>5</sup>) (FFA) require DOE to remove the LRW from the non-compliant LRW tanks. The high-level waste portion of liquid waste is

immobilized in glass. This process is called vitrification, which is carried out at the DWPF; the vitrified waste will ultimately be transported to the National Geological Repository for final disposal. To support tank closure efforts established in the *STP*<sup>4</sup>, the total volume of LRW to be vitrified by the DWPF should be reduced. The SWPF will perform this volume reduction by extracting and concentrating the high-activity constituents from the bulk salt waste. The concentrated high-activity waste fraction will be sent to the DWPF for vitrification. The higher-volume decontaminated salt solution (DSS) is processed into solidified grout at the SPF.

The *Savannah River Site Salt Processing Alternatives Final Supplemental Environmental Impact Statement* (DOE/EIS-0082-S2<sup>6</sup>) (SEIS) and *Record of Decision: Savannah River Site Salt Processing Alternatives*<sup>7</sup> (ROD), as amended January 17, 2006 (DOE/EIS-0082-S2-SA-01) document DOE's analysis and selection of the technologies currently integrated into the SWPF design. The preferred technologies selected in the *SEIS* and *ROD* included the monosodium titanate (MST)-based Alpha Strike Process (ASP) for removal of actinides and Sr, and Caustic-side Solvent Extraction (CSSX) for removal of Cs.

### **3.0 SALT WASTE PROCESSING FACILITY LOCATION AND FACILITY LAYOUT**

The SWPF is located in J-Area at SRS. The configuration of the SWPF Process Building, supporting facilities, and locations of the WTLs are shown in Figure 3-1. Other support structures adjacent to the Process Building include the Exhaust Stack, Administration Building, Chiller Pad, Compressor Building, Diesel Generator (DG) Pad, and parking lot. The SWPF and J-Area are located east of the Low Point Pump Pit (LPPP). The environmental impacts associated with SWPF construction at this location were extensively evaluated and the results were documented in the *SEIS*<sup>6</sup>.

Figure 3-2 provides a three-dimensional Design view of the SWPF Process Building. All waste processing operations are performed within the Central Processing Area (CPA) and Alpha Finishing Facility (AFF) areas of the Process Building. The CPA includes five Process Vessel Cells, the Alpha Strike Process (ASP) Pump and Valve Gallery (P&VG), and the Caustic-side Solvent Extraction (CSSX) Cell. The ASP P&VG is located beneath the Process Building Ventilation Systems shown in Figure 3-2.

Attachment A includes the SWPF General Arrangement (GA) drawings. The GAs show five areas: 1) CPA, 2) Cold Chemicals Area (CCA), 3) Northern Facility Support Area, 4) Eastern Facility Support Area, and 5) AFF. GAs for the CPA are also included, showing various equipment at different elevations. The GA Index also identifies the tanks' designated numbers, size and capacity, and designation of pumps, agitators, and other miscellaneous equipment.





Figure 3-2. Three Dimensional, Preliminary Design View of the SWPF Process Building



#### **4.0 COMPREHENSIVE DESCRIPTION OF PROPOSED SWPF PROJECT**

The SWPF is being designed to process 34 Mgal of liquid radioactive waste (LRW) stored as salt solution or saltcake. The saltcake requires dissolution and blending prior to transfer to the SWPF. After saltcake dissolution, the total wastewater volume requiring processing is approximately 84 Mgal. Most of this wastewater requires processing by the SWPF. This section describes the operational units comprising the SWPF. Wastewater processing at the SWPF occurs in the following five operational steps, including two transfer steps and three processing units:

1. Wastewater receipt from the Tank Farm,
2. Alpha Strike Process (ASP) for removal of actinides and  $^{90}\text{Sr}$ ,
3. Caustic-side Solvent Extraction (CSSX) for removal of  $^{137}\text{Cs}$ ,
4. Alpha Finishing Process (AFP) for additional removal of actinides and  $^{90}\text{Sr}$ , and
5. Wastewater Transfer to the SPF or DWPF.


A simplified process flow diagram (PFD) is provided in Figure 4-1. The three process units are the ASP, CSSX, and AFP. These process units are separated by dashed lines in Figure 4-1. A brief summary of the three process units follows.

Detailed process flow drawings are found in Attachment B. These drawings identify waste streams, waste stream characteristics, and tank throughput capacity.

---



Figure 4-1. Salt Waste Processing Facility Simplified Process Flow Diagram



Note 1 : DSS from single MWT alpha operation  
Note 2 : DSS from multiple MWT alpha operation  
Note 3 : Not currently used - provided for operational flexibility

The SRS Tank Farm will prepare blended macro-batches for SWPF feed that range in size up to 1.2 Mgal. The SWPF ASP receives a small batch of SRS Tank Farm waste that is approximately 23,200 gallons. Upon receipt of a small batch, MST is added to the waste to sorb Sr and actinides, including isotopes of plutonium, americium, neptunium, and uranium. The MST and waste are mixed for several hours, during which time the MST selectively sorbs the Sr and actinides from the wastewater. The resulting MST slurry is then filtered to produce a concentrate of MST slurry and solids that contains most of the Sr and actinides, and a clarified salt solution (CSS) filtrate. The concentrated MST solids are transferred to a holding vessel and washed to reduce the sodium (Na) concentration, prior to transfer to the DWPF. The CSS filtrate is routed to the CSSX process for Cs removal. Section 4.3.1 describes the ASP in more detail.

CSSX is a continuous process that utilizes 36 centrifugal contactors for extraction, scrubbing, stripping, and washing of the aqueous and organic process streams. The Cs is removed by contacting the aqueous CSS with an organic solvent in 16 extraction stage contactors.

Cs is captured in the organic phase by the extractant and then released into a low-volume, slightly acidic strip solution via 16 stripping stages. The strip effluent is collected in the Strip Effluent Hold Tank (SEHT) prior to transfer to the DWPF for vitrification. The decontaminated salt solution (DSS) from the extraction stages is sent to the AFP for either an additional MST strike or for sampling and analysis prior to transfer to the SPF, where it will be solidified into a grout matrix known as saltstone grout. Section 4.3.2 provides a more detailed description of the CSSX process.

The AFP provides the capability to perform an additional MST strike if the Sr and actinide levels present in the CSS after the first MST strike in the ASP are too high to meet the SPF waste acceptance criteria (WAC). For the single-strike processing mode, one of the AFP tanks collects DSS from the CSSX for verification sampling and analysis, prior to transfer to the DSS Hold Tank (DSSHT). DSS that meets the SPF WAC is transferred from the DSSHT to SPF. The basic process steps for the AFP are described in more detail in Section 4.3.3.

#### **4.1 Waste Transfer Line Segments**

A construction application form, engineering report, and application fee for Phase I WTL Segments of the SWPF Project were submitted to SCDHEC and Phase 1 WTL Construction Permit No. 19, 164-IW was issued on January 02, 2008. This application detailed the WTL segments to be constructed before actual construction of the SWPF. These line segments are illustrated in Figure 4-2. Discussion of the operational use of each WTL follows.

The EPC will work with SCDHEC in the transition from the Phase 1 WTL Construction Permit to the Phase II SWPF Construction Permit including closeout notifications, letters, and drawings needed by SCDHEC.

#### **4.2 Wastewater Receipt from Tank Farms**

Wastewater is transferred from a tank in the H-Area Tank Farm to Alpha Sorption Tank-A (AST-A), located in the SWPF AST-A Process Vessel Cell. New transfer lines are required to

---


connect the SWPF to the existing SRS Liquid Waste Transfer System. The WTLs consist of two 3-inch-diameter stainless steel pipes that are encased in 10-inch-diameter carbon steel pipe. The SWPF transfer lines tie into existing underground pipelines operated by the SRS Liquid Waste Operations Contractor.

SWPF feed from the H-Area Tank Farm is routed through existing Process Transfer Line PCP-341 to the 512-S (Actinide Removal Process [ARP]) Facility. At 512-S, the wastewater is routed into existing line PCP-4 that connects to the Low Point Pump Pit (LPPP). A new transfer line, Line 0001, is to be constructed from the LPPP to the SWPF. Figure 4-2 shows the proposed transfer pathways between the SWPF and the Tank Farm, DWPF, and SPF, respectively. The SCDHEC Construction Permit for the Phase 1 WTL Segments details construction and installation of the WTLs. Wastewater transfers to the DWPF and SPF are described in Section 4.4. The EPC is responsible for constructing Line 0001 to the interface point defined at N72864.6, E64531.9 of the SRS Coordinate System. Figure 3-1 shows the location of the proposed WTLs to the LPPP west of the SWPF Process Building. Although the EPC is responsible for constructing most of the WTLs, its operational interface boundary is the first isolation valve inside the SWPF.

SWPF feed delivery is controlled by the Tank Farm 3H Control Room (CR) (Bldg. 241-2H) and monitored from the SWPF CR. The SWPF and Tank Farm 3H CRs have access to all relevant information for waste transfers via the Telecommunications and Control Datalink System (TCDS). The TCDS is the network of telephone and data cables interconnecting various facilities.

---

Figure 4-2. Transfer Flow Paths Between SWPF and the Tank Farm, DWPF, and SPF



### **4.3 SWPF Process Design**

The SWPF performs three treatment operations for wastewater received from the H-Area Tank Farm. In the first pretreatment step, the Sr and actinides are separated from the wastewater (salt solution) in the ASP. The ASP is carried out in the AST-A, Filter Feed Tank-A (FFT-A), and Wash Water Hold Tank (WWHT) Process Vessel Cells. The salt solution is then sent to the CSSX pretreatment process, where Cs is separated from the bulk solution. If additional Sr and actinide removal is required, a third pretreatment step, similar to the ASP, is performed. This third optional pretreatment step is referred to as the AFP. Arrangement of the areas in which the three process operations occur in the SWPF is shown in Figure 3-2 and the General Arrangement (GA) drawings in Attachment A.

#### **4.3.1 Alpha Strike Process**

Wastewater is transferred from the H-Area Tank Farm to AST-A in batches of 23,200 gallons each. MST is then added to AST-A and the tank contents are mixed. Sr and actinides are sorbed from the wastewater onto suspended MST particles. The resulting MST slurry is then transferred to FFT-A and filtered to approximately 5 weight percent (wt%) suspended solids. Filtrate (CSS) is collected in the Salt Solution Feed Tank (SSFT), from which it is fed forward to the CSSX process. The concentrated MST sludge is transferred from FFT-A to the Sludge Solids Receipt Tank (SSRT). The MST sludge is washed with water in the SSRT to reduce the sodium ion ( $\text{Na}^+$ ) for vitrification, and the washed sludge is then sent to the DWPF. Tank sizes and working volumes are listed in Attachment A.

##### **4.3.1.1 Strontium and Actinide Sorption**

H-Area waste feed batches prepared for the SWPF are sampled and analyzed prior to transfer from the H-Area Tank Farm. The analytical results are used to determine the number of MST strikes required, given established Decontamination Factor (DF) values for Sr and actinides (See Section 5.2).

After H-Area Tank Farm feed is transferred to AST-A, it is chemically adjusted from 6.44 Molar (M)  $\text{Na}^+$  to 5.6M  $\text{Na}^+$  by adding recovered wash water from the MST sludge washing step (see Section 4.3.1.4) and fresh 1.66M sodium hydroxide (NaOH). This chemical adjustment enhances the rate of Sr and actinide sorption.

The MST added to AST-A selectively sorbs soluble Sr and actinides present in the waste solution. Most of the Sr and actinide sorption occurs shortly after the MST addition. In order to maximize the MST sorption for one MST strike, the mixing and contact duration within AST-A is 12 hours. When two or more strikes are required to sufficiently remove Sr or actinides, the mixing/contact duration is reduced to 6 hours for both AST-A and Alpha Sorption Tank-B (AST-B) in the AFP. The reduction to 6 hours is due to the fact that the MST removal rate is not linear; it falls off significantly after 6 hours. For example, for plutonium, the 12-hour DF has been measured to be 5.5, while the 6-hour factor is 4.7. By performing separate MST strikes and filtering between strikes, the DF for each strike is essentially multiplied together, resulting in a combined DF of 18.

#### **4.3.1.2 Cross-flow Filtration**

After the MST sorption cycle, the waste in AST-A is transferred to FFT-A in the FFT-A Process Vessel Cell, where it is filtered to separate MST and suspended solids from the wastewater. The salt solution in FFT-A is recirculated through cross-flow filters (CFFs) (Alpha Sorption Filters) located in the FFT-A Process Vessel Cell to concentrate the MST and entrained Tank Farm solids to 5 wt% total suspended solids. Figure 4-3 shows the FFT-A - Alpha Sorption Filter circuit. The CFF contains parallel tubes fabricated from sintered metal, with a pore size of 0.1 micron (Figure 4-4).

Under nominal conditions, the MST slurry reaches 5 wt% solids when the FFT-A volume is reduced to 400 gallons. Measurement of the FFT-A liquid level and the quantity of filtrate removed are used to determine when the 5 wt% target is reached. The MST sludge is then transferred from FFT-A to the SSRT. The CSS filtrate is transferred to the SSFT, where it is staged for the CSSX pretreatment process. There is an in-line turbidity meter in addition to a sampling and analysis program to monitor filter performance and detect an inadvertent transfer of MST solids into the SSFT.

A two-pump system is employed for each Alpha Sorption Filter circuit. This two-pump system consists of a feed pump and a filter circuit recirculation pump (Figure 4-3). There are three independent Filter Feed/Solids Transfer Pumps. Two of the pumps are used at one time to feed their respective filter loops. A spare filter circuit can be placed into service when one of the other circuits needs maintenance or filter cleaning. Cross-flow through the Alpha Sorption Filters is provided by the Filter Recirculation Pump (Figure 4-3). A bleed-back flow, equal to the feed flow rate minus the filtrate flow rate, is returned to FFT-A. The Filter Feed/Solids Transfer Pumps are also used to transfer MST concentrate from FFT-A to the SSRT, which is also located in the FFT-A Process Vessel Cell.

Each filter incorporates a backpulse tank that is connected to the shell side of each filter. Compressed air is used for backpulsing the filters to dislodge particles that have accumulated in the filter pores.

Figure 4-3. FFT-A Filter Circuit Flow Diagram





Figure 4-4. Conceptual Schematic of a Cross-Flow Filter





#### **4.3.1.3 Clarified Salt Solution Storage**


The CSS produced from the FFT-A filtration cycle is stored in the SSFT, located in the SSFT Process Vessel Cell. This vessel provides a means to decouple the ASP and CSSX processes. The SSFT is sized to allow the ASP to process several batches of waste feed with the CSSX shut down for planned outages, or to operate the CSSX for an equivalent time period with the ASP shut down. CSS is normally pumped from the SSFT to the aqueous inlet of the CSSX extraction stages. The CSS can also be transferred back to the ASP for reprocessing.

#### **4.3.1.4 MST Solids Washing**

The SSRT is sized (5,200 gallons) to accommodate at least five concentrated batches of MST sludge from FFT-A and another five batches from the Alpha Finishing Facility (AFF) Filter Feed Tank-B (FFT-B). After collecting sufficient MST concentrate in the SSRT, the vessel contents are washed with water to reduce the Na<sup>+</sup> concentration from 5.6M to approximately 0.5M to meet the WAC for DWPF. Figure 4-5 shows a flow diagram for sludge or concentrate washing.

During the wash cycle, water is added continuously and the SSRT contents are circulated through the cross-flow Washing Filter by a two-pump arrangement that includes the Washing Filter Feed/Sludge Solids Transfer Pump and Washing Filter Recirculation Pump. The filtrate is collected in the WWHT, located in the WWHT Process Vessel Cell. When the calculated quantity of water has been added and removed, the SSRT contents are sampled for Na<sup>+</sup> concentration. The wash water (approximately 2,000 gallons) is transferred from the WWHT to AST-A to mix with the next batch of Tank Farm wastewater (see Section 4.3.1.1).

Figure 4-5. MST Sludge Washing Flow Diagram



#### 4.3.1.5 Cross-Flow Filter Cleaning

The Alpha Sorption and Sludge Washing Filters require periodic cleaning. During operations, two of the three Alpha Sorption Filters are in use and the other is available for routine cleaning.

The filter cleaning steps are as follows. The filter circuit is first drained to FFT-A and flushed with DSS from the DSSHT (Figure 4-1) for several minutes. The filter is then flushed with 0.02M NaOH, followed by an hour of cleaning with 0.5M oxalic acid ( $H_2C_2O_2$ ). The cleaning solution is provided by Cleaning Solution Dump Tank-A (CSDT-A). The 0.5M  $H_2C_2O_2$  is prepared in the Cold Chemicals Area (CCA) Oxalic Acid Feed Tank by mixing  $H_2C_2O_2$  (liquid) and water. CSDT-A receives cleaning solution from the CCA. The 0.02M NaOH flush solution is prepared in the Filter Cleaning Caustic Tank in the CCA by mixing 50% NaOH solution with the appropriate quantity of water. When the cleaning process is completed, the cleaning solution is transferred from CSDT-A to the Alpha Sorption Drain Tank (ASDT) and from the ASDT to the WWHT or AST-A.

#### 4.3.2 Caustic-side Solvent Extraction Process

The CSSX process is carried out in the CSSX Cell, located adjacent to the Process Vessel Cells (Figure 3-2). The CSSX process uses centrifugal contactors to mix the salt solution with an engineered organic solvent, and then separates the aqueous and organic phases. Cs is extracted from the CSS by the BOBCalixC6 molecule in the organic phase. Dilute nitric acid ( $HNO_3$ ) (0.001M) solution is then used to strip or transfer the Cs from the organic solvent. The aqueous strip solution is transferred to the DWPF for vitrification.

The CSSX System consists of 16 stages of extraction, 2 stages of scrub, 16 stages of strip, and 2 stages of caustic wash. Figure 4-6 illustrates the CSSX process. Each contactor has inlets and outlets for both the organic solvent phase and an aqueous phase. Contactors are installed in two parallel rows of 18 units each, with their drive motors protruding through a shielded upper floor.

The CSSX process uses a specially engineered solvent that selectively removes Cs. The solvent is comprised of four components:

1. Cs extractant, a calixarene crown ether known as BOBCalixC6<sup>A</sup>;
2. Modifier, Cs-7SB<sup>B</sup>, which enhances extraction and helps prevent third-phase formation by increasing the solubility of the extractant;
3. Suppressor, Tri-n-octylamine (TOA), which inhibits impurity effects and enhances stripping performance; and
4. Diluent, Isopar<sup>®</sup>L, which is a blend of  $C_{10}$  to  $C_{12}$  branched alkanes.

The centrifugal contactors mix and then separate the aqueous waste and organic solvent. The mixing and separation process allows the transfer of Cs between the aqueous and organic phases

<sup>A</sup> The chemical name for the extractant is Calix[4]arene-bis(tert-actylbenzo-crown-6).

<sup>B</sup> The chemical name for the modifier is 1-(2,2,3,3-Tetrafluoropropoxy)-3-(4-sec-butylphenoxy)-2-propanol.

to occur. Figure 4-7 shows a conceptual cutaway view of the contactor housing, rotor, liquid flow paths, and two wiers. The immiscible organic and aqueous phases are fed into separate inlets and rapidly mixed in the annular space between the spinning rotor and stationary housing. The mixed phases are directed toward the center of the rotor bottom by radial vanes in the housing base. As the liquids enter the central opening of the rotor, they are accelerated toward the outer wall of the contactor.

The mixed phases are rapidly accelerated to rotor speed, and separation begins as the immiscible liquids with differing densities are displaced upward. Weirs at the top of the rotor divert the separated liquids into annular collector rings that lead to the discharge piping.

Figure 4-6. Caustic-side Solvent Extraction Process





Figure 4-7 Cutaway View of Centrifugal Contactor



#### **4.3.2.1 Cesium Extraction**

Extraction of Cs from the wastewater feed is performed in 16 successive contactor stages. Solvent flows through the extraction stages counter-current to the aqueous feed. Each individual stage mixes and then separates the aqueous and organic phases. During the mixing and separation, Cs is transferred from the aqueous phase to the organic phase. Due to the opening size in the BOBCalixC6 molecule, Cs is removed in preference to the Na<sup>+</sup> and potassium ion that is present in the wastewater.

DSS leaves the extraction stages and passes through the DSS Stilling Tank and DSS Coalescer to recover solvent. The stilling tank and coalescer are shown as DSS Solvent Recovery in Figure 4-6. The top of the stilling tank contains the lower-density organic solvent that overflows into the Solvent Hold Tank (SHT). The bottom of the stilling tank contains the denser aqueous phase that flows to the DSS Coalescer. The DSS Coalescer further removes entrained droplets of solvent. The organic solvent drains to the SHT. DSS from the bottom of the coalescer flows to the Barium (Ba)-137 Decay Tank (BDT).

The DSS is passed through the BDT to allow the <sup>137</sup>Ba to decay (in excess of 10 half-lives or at least 30 minutes), prior to transfer to the AFF. The DSS is then pumped to the Intermediate Storage Tank (IST) or to AST-B. After one tank is filled, it is sampled and analyzed for Sr/actinides and Cs content. One of the two BDT Transfer Pumps is used to transfer the DSS to one of the Process Vessels in the AFF. An in-line gamma monitor is installed downstream of the pumps. If the radiation monitor detects high levels of <sup>137</sup>Ba, an interlock is activated to divert DSS to the SSFT.

#### **4.3.2.2 Solvent Scrub**

Following Cs extraction, the Cs-loaded solvent is scrubbed with 0.05M HNO<sub>3</sub>. Contacting the organic stream with the dilute acid has the effect of neutralizing any caustic carryover from the extraction stages. Neutralization of the caustic carryover is necessary to ensure stable operation of the strip stages. Two stages of scrub are provided. The scrub solution enters the second scrub stage and proceeds counter-current to the solvent.

#### **4.3.2.3 Cesium Strip**

The scrubbed solvent flows to the Solvent Strip Feed Tank and is pumped by one of the two Solvent Strip Feed Pumps to the 16 strip stages. The scrubbed solvent flows through 16 centrifugal contactor stages to strip Cs from the organic solvent into an aqueous phase. In the strip stages, organic solvent is contacted with a 0.001M HNO<sub>3</sub> solution, resulting in the transfer of Cs to the strip solution. The nitrate ion concentration in the aqueous phase shifts the equilibrium to favor transport of the Cs ion from the solvent to the aqueous phase.

The strip solution is supplied to the aqueous inlet to the strip stage from the Strip Feed Tank by the Strip Feed Pumps located in the CCA.

Strip effluent exiting the strip stages flows by gravity to the Strip Effluent Stilling Tank and then to the Strip Effluent Coalescer to remove trace amounts of entrained solvent in the aqueous phase. The strip effluent then drains to the Strip Effluent Pump Tank and is pumped to the SEHT by one of the two Strip Effluent Pump Tank Pumps. The recovered solvent from the stilling tank and the coalescer flows by gravity to the Solvent Drain Tank (SDT). The SDT is pumped by the Solvent Drain Tank Pump to the aqueous inlet line to the extraction stages. The recovered solvent is separated from the aqueous phase by the action of the extraction stages.

#### **4.3.2.4 Caustic Wash**

The organic solvent passes from the stripping stages through a two-stage caustic wash process after the strip stages. The caustic wash removes impurities in the solvent that interfere with solvent performance. The TOA and Cs-7SB organic solvent components degrade with time, with the TOA forming dioctylamine and the Cs-7SB forming phenolic compounds. The caustic wash removes these impurities to maintain performance of the solvent. The solvent outlet from the wash stages flows by gravity to the SHT.

The Caustic Wash Tank and one of two Caustic Wash Tank Pumps supply caustic wash solution to the wash contactor aqueous inlet. The caustic wash solution is returned to Caustic Wash Tank. On indication of low pH at the wash stage aqueous outlet, the wash stage solution is transferred to the DSS Stilling Tank and the DSS Coalescer, prior to transfer to the AFF through the BDT. The wash solution is then replaced with 0.01M NaOH make-up provided to the Caustic Wash Tank by the Caustic Make-up Tank located in the CCA.

#### **4.3.2.5 Strip Effluent Storage and Transfer**

The SEHT is located in the SEHT Process Vessel Cell and collects strip effluent for transfer to the DWPF. The SEHT is sized to provide a working volume of approximately 17,000 gallons (approximately 8 days of strip effluent production). Contents of the SEHT are transferred to the DWPF approximately once a week.

#### **4.3.2.6 DSS Storage and Transfer**

DSS is transferred to one of the vessels in the AFF for additional Sr and actinide removal (as required), sampling and analysis, and staging for transfer to the SPF. Section 4.3.3.1 provides a further description of process steps performed in the AFF.

#### **4.3.3 Alpha Finishing Process**

The AFP is carried out in the AFF. Figure 3-2 shows the AFF location within the SWPF. The AFP is essentially identical to corresponding operations in the ASP. The purpose of the AFP is to remove additional Sr and actinides to meet the SPF WAC, without affecting the SWPF throughput rate. The configuration and sequence of the AFP operation are similar to the ASP.



The AFF houses Process Vessels, Alpha Sorption Filters, and pumps and valves that provide the capability to perform additional MST strikes. It is also used to stage, sample, and analyze single-strike and multi-strike DSS prior to transfer to the SPF.

The AFF receives DSS from the CSSX process. Because  $^{137}\text{Cs}$  and its gamma-emitting daughter,  $^{137\text{m}}\text{Ba}$ , are reduced in activity by approximately five orders of magnitude, the AFF does not require shield walls and is constructed of a steel frame enclosed with sheet metal and insulation. The AFF provides the essential confinement and secondary containment required for processing low-activity wastewater.

#### **4.3.3.1 AFP Processing in the Multi-Strike Mode**

If an additional alpha strike is required to meet SPF WAC, DSS from the BDT is fed to the IST. When the IST is full, the contents are transferred to AST-B. Following completion of a batch transfer from the IST to AST-B, MST is added and the contents are mixed with a mechanical agitator. After the six-hour MST sorption cycle is complete, the contents of AST-B are transferred to FFT-B for filtration.

In FFT-B, the MST slurry contents are circulated through two of the three AFP CFFs to concentrate the MST solids to 5 wt%. A mechanical agitator is used to mix the MST slurry in FFT-B. A two-pump system is used, similar to that shown in Figure 4-3. The size and configuration of the CFFs and the pumping system are identical to the ASP arrangement.

Filtrate from these AFP Alpha Sorption Filters is routed to the DSSHT. The concentrated MST slurry is transferred to the MST/Sludge Transfer Tank for interim storage and subsequent transfer to the SSRT for washing.

During routine operation, the filter flux decreases as each FFT-B batch is processed. When the filter flux decreases significantly, the filter is isolated and cleaned to restore normal operation. The cleaning procedure is identical to the procedure used for cleaning the ASP filters.

#### **4.3.3.2 DSS Staging, Sampling, and Analysis in the AFF**

DSS is staged in the DSSHT for transfer to the SPF. The DSSHT is sized to provide a working volume of approximately 35,500 gallons, providing storage for 26 hours of DSS production when the plant is operating at full capacity. In multi-strike mode, DSS is produced/transferred in a batch-wise process.

Collection of a sample that is representative of a discrete DSS batch will require filling the DSSHT, sampling the tank contents, and waiting 12 hours for the SWPF Analytical Laboratory results to verify compliance with the SPF WAC. Such delay would require halting operation of the CSSX and the AFP for 12 hours. In lieu of a shutdown, a sample is collected from AST-B after 6 hours of actinide and Sr sorption. The sample is then filtered and analyzed in the SWPF Analytical Laboratory.

The CFFs in the AFP have 0.1-micron pore size; therefore, the sample collected from AST-B is filtered in the laboratory by a 0.1-micron filter, prior to analysis. If analysis indicates that the sample will meet SPF WAC, the DSS is transferred to FFT-B for filtering. Filtrate produced from circulating the contents of FFT-B through the Alpha Sorption CFFs is directed to the DSSHT, where it is staged for eventual processing at the SPF.

#### **4.4 Wastewater Transfer to DWPF and SPF**

Figure 4-2 shows the transfer path between the MST sludge effluent and DWPF, the strip effluent and DWPF, and the DSS effluent and SPF.

The operational interface boundary is the first isolation valve inside the SWPF. The SWPF transfer lines tie into existing underground pipelines operated by the Site Liquid Waste Contractor (LWC). Although the EPC is responsible for constructing part of the WTLs, the Site LWC has operations and maintenance responsibility for the transfer lines.

The jumpers or line segments connecting the SWPF WTLs are not identified at this point for the existing Site Infrastructure. A new Project (SWPF Tie-ins and Modifications) will be requested/funded by DOE.

##### **4.4.1 Transfer of MST Sludge from the SWPF to LPPP and DWPF**

The washed MST slurry and sludge solids from the SSRT are transferred to the Precipitate Pump Tank (PPT) located in the LPPP (Figure 4-2). The wastewater is pumped with the Washing Filter Feed/Sludge Solids Transfer Pump. The waste transfer path to the LPPP is flushed with strip effluent from the CSSX process output.

Line 0116 is a proposed WTL to be constructed by the EPC from the Waste Transfer Enclosure (WTE) within the SWPF (shown on Attachment A, page A4) to an interface point outside the LPPP. Line 0116 is a 3-inch stainless steel pipe enclosed in a 10-inch carbon steel pipe with Line 0001, the proposed WTL for SWPF feed.

MST/sludge transfers from the SWPF to the PPT in the LPPP are controlled at the SWPF CR. Transfers from the PPT to the Precipitate Reactor Feed Tank in DWPF are controlled by DWPF Operations. The SWPF and DWPF CRs shall have access to all relevant waste transfer information from the TCDS.

##### **4.4.2 Transfer of Strip Effluent from the SWPF to the LPPP and DWPF**

Strip effluent from the SWPF is routed to DWPF by new proposed WTL 0119 to a jumper (i.e., steel pipe) at the LPPP that connects to a transfer line to DWPF. Line 0119 is a 3-inch stainless steel line jacketed in a 10-inch carbon steel pipe, shared with a spare Line 6585. Strip effluent transfers to the DWPF are controlled by the SWPF CR. The SWPF and DWPF CRs monitor all relevant waste transfer information via the TCDS

#### **4.4.3 Transfer of DSSHT from the SWPF to SPF**

DSS is routed from the SWPF to a tie-in, where it is directed by way of an existing permitted transfer line to the SPF.

DSS transfers from the SWPF are controlled by the SWPF CR. The SWPF and SPF CRs have access to all relevant waste transfer information from the TCDS.

#### **4.5 Cold Chemicals Area**

The CCA is used to receive, store, and mix process chemicals used in the ASP, CSSX, and AFP. Chemicals received, stored, and mixed for processing include  $\text{HNO}_3$  (at 50 wt%), 50 wt% NaOH,  $\text{H}_2\text{C}_2\text{O}_2$ , Isopar<sup>®</sup>L, MST, BOBCalixC6, TOA, and Cs-7SB. The CCA is a completely enclosed structure, with access provided through a door to the outside and a Truck Bay. The chemical storage area is provided with a dike and sump system for spill control. The tanks are passively vented through overflow lines that extend into the floor sumps.

NaOH is received as 50 wt% from tanker trucks and pumped to the 50% Caustic Receipt Tank. The estimated annual usage of caustic is 144,560 gallons. The 50% Caustic Receipt Tank is sized to provide a minimum working volume of 8,000 gallons. Metered quantities of 50% caustic are provided to the Caustic Wash Tank, Caustic Dilution Feed Tank, and Filter Cleaning Caustic Tank. Caustic for the solvent wash process is made up in batches in the Caustic Make-up Tank. Water and concentrated caustic are added to the Caustic Make-up Tank to achieve a concentration of 0.4 grams per liter (g/L) (0.01M).

$\text{HNO}_3$  is received as 50 wt% by tanker truck and pumped to the Nitric Acid Receipt Tank. The estimated usage of  $\text{HNO}_3$  is 308 gallons per month. The Nitric Acid Receipt Tank is sized for a working volume of 2,000 gallons. The  $\text{HNO}_3$  is transferred to the Nitric Acid Strip Make-up Tank and to the Nitric Acid Scrub Make-up Tank, where it is diluted to 0.001M and 0.05M, respectively. From the Strip and Scrub Make-up Tanks, dilute  $\text{HNO}_3$  is transferred to the Strip Feed Tank (0.001M) as feed to the aqueous inlet for the CSSX strip stages and to the Scrub Feed Tank (0.05M) as feed to the CSSX scrub stage aqueous inlet.

The CSSX solvent is either purchased premixed in 55-gallon drums for addition to the Solvent Make-up Tank or mixed in the CCA. The minimum volume of solvent required for CSSX operation is 200 gallons. The SHT is sized to provide a maximum working volume of 400 gallons. The concentration of the solvent components is determined by periodic sampling and analysis of the SHT. Individual solvent components are added to maintain the optimum solvent composition and density. Small quantities of solvent components are stored in the CCA.

$\text{H}_2\text{C}_2\text{O}_2$  is received in liquid form and added to water to make a dilute solution for cleaning the ASP and AFF CFFs. This cleaning solution of 0.5M  $\text{H}_2\text{C}_2\text{O}_2$  will be prepared in the Oxalic Acid Feed Tank. A caustic flush solution at 0.02M concentration will be prepared in the Filter Cleaning Caustic Tank by mixing 50% caustic solution with water. The working volume of these tanks is approximately 1,000 gallons each. Cleaning solutions are prepared as needed.

MST is received in 55-gallon drums and stored in the CCA. Twenty drums are required to make up an MST batch in the MST Storage Tank. Mechanical agitation is provided in the MST Storage Tank to prevent MST settling.

Working volumes for tanks that receive chemicals from offsite vendors are sized for at least one week's worth of inventory. Working volumes for tanks that receive and adjust chemicals from other CCA tanks are typically sized for at least one day or one batch of inventory. It is expected that the CSSX solvent will typically be replenished on a component basis and will maintain one complete inventory in one full solvent load. When the solvent is analyzed, any of the four components (extractant, modifier, suppressant, and diluent) that are low will be individually replenished.

#### **4.6 Distributed Control System**

The SWPF Distributed Control System (DCS) provides centralized monitoring and control of all in-cell equipment and support systems. The DCS will gather and record data and information necessary to control the processes and provide historical data from the facility.

The DCS consists of a group of servers, controllers, and workstations linked together by redundant Ethernet networks. The servers provide the network backbone for the DCS and the Plant Information Network. Remote access points are available to access the specialty software for monitoring, data storage, and remote interface. The operator workstations provide the Human-Machine Interface.

#### **4.7 Equipment and Service Failure or Shutdown**

The SWPF is configured so that system failures or shutdowns do not result in the need to bypass the three treatment units and discharge untreated wastewater to the effluent transfer lines to the SPF. If the need arises to shut down any inter-facility transfer or any of the three processing units, all units and transfers can be stopped, as necessary. For example, if there is a system failure or shutdown in the ASP that requires cessation of a transfer from H-Area Tank Farm to AST-A, the wastewater transfer can be stopped and the isolation valve to AST-A can be closed. Double isolation valves are provided.

##### **4.7.1 Redundant Pumps and Filters**

The AFP, CSSX process, and ASP are provided with redundant sets of pumps and filters, where required, to ensure uninterrupted processing (see Attachment A). Single pumps are provided when continuous service is not required by the process unit. For example, the Washing Filter Feed/Sludge Solids Transfer Pump is used to transfer MST solids from the SSRT to DWPF approximately once every five to six days. It is also used in the SSRT washing and filtering process (Figure 4-5) prior to transfers to the DWPF. One pump is used for this particular set of tasks because five days provides sufficient time to replace the pump or the washing filter.

A preliminary spare parts list has been developed and will be further refined as vendor recommendations are obtained during the Construction phase.

#### **4.7.2 Maintainability**

The Process Vessel Cells are designed to be unmanned. The Process Vessels and piping are welded and equipped with systems that have no moving parts or components that require maintenance. Equipment requiring periodic replacement is removed from sealed wells accessible from the overlying Operating Deck (e.g., filters and cameras). The Process Vessel Cells are adjoining reinforced concrete structures. Although the cells are designed to be unmanned, entry is possible through a concrete entry plug. The concrete plug requires removal by an overhead crane, located in the overlying Operating Deck area.

Pumps used to transfer high-activity waste in the ASP and CSSX are located in the ASP and CSSX Pump & Valve Galleries (P&VGs), respectively. The galleries are subdivided by an array of labyrinth shield walls. Because pumps must be drained prior to maintenance or replacement to reduce the radiation dose rate, the labyrinth configuration allows maintenance or replacement of a single pump without necessarily requiring all pumps to be drained. This configuration allows the ASP or CSSX process to continue during the pump change-out.

The Alpha Sorption Filter configuration (two active and one standby) in the ASP and AFP allows cleaning or replacement of a single filter, without slowing or stopping either process.

To facilitate maintenance activities, the CSSX process area is subdivided into the CSSX P&VG, CSSX Tank Cell, and Contactor Cell. The CSSX P&VG and CSSX Tank Cell are located at grade. With the exception of the Contactor Operating Floor, the cell walls and ceilings are constructed of thick reinforced concrete that is provided for shielding, structural strength, and wastewater containment. The Contactor Support Floor (elevation 116 feet) is a stainless steel liner for secondary containment of liquid. The Contactor Cell contains 36 contactors arranged in two east-west linear arrays (shown on Attachment A, page A9). The Contactor Operating Floor is constructed of steel grating able to support use of temporary shielding, as needed. This design permits maintenance access to the contactor motors. The contactor drive shaft penetrates this Contactor Operating Floor, above which the motor is installed. This configuration allows a contactor motor to be removed without the need to drain the entire contactor system.

Installed spare contactors are not envisioned due to the complexity of valving one in or out of the process. However, there will be spare "motor/rotor" assemblies, such that the contactor internals and motor can be replaced with a refurbished unit. The motor/rotor assembly contains all the contactor equipment that requires maintenance.

#### **4.7.3 SWPF Containment and Ventilation System Design**

The SWPF incorporates a number of design features to contain hazardous materials. Multiple containment barriers are provided for all hazardous chemicals and radioactive waste. The high-activity radioactive waste is processed and contained in the Central Processing Area (CPA), which is a reinforced concrete structure. Low-activity waste is processed in the AFF. Hazardous chemicals used in the SWPF are stored in the CCA. All of these areas are located in the Process Building, which provides a secondary containment boundary in the event of a tank or piping system leak.

#### **4.7.3.1 Wastewater Process System Containment**

All tanks for receiving, processing, and collecting high-activity wastes are constructed of stainless steel and are located within enclosed concrete cells in the CPA. These cells are intended to be inaccessible during normal operations. The cells are provided with a stainless steel liner and collection sumps with leak detectors. Piping, pumps, and valves used to route high-activity waste are located in the P&VGs within the CPA. The P&VGs are lined with an epoxy coating. Separate collection sumps and leak detection devices are provided for each labyrinth area.

All sumps located in the Process Building are equipped with leak detection and alarm systems to alert operators in the event of a leak. Waste transfer pumps are interlocked to trip if a leak is detected. Isolation valves to and from the associated tanks or process systems automatically close if a leak is detected. The transfer pumps are also interlocked to trip, based on low level in the source tank or high level in the receiving tank.

Low-activity waste that requires a second MST strike to meet the SPF WAC is processed in the AFF area of the Process Building. The process tanks, piping, and other process equipment are located in concrete diked areas. These diked areas are provided with stainless steel liners that serve as a secondary containment boundary. Sumps and leak detection devices are also provided for each diked area within the AFF.

#### **4.7.3.2 Waste Transfer Containment**

The WTLs are routed into and out of the SWPF Process Building via the WTE. This enclosure is partially below grade to allow WTLs to enter and exit the external wall of the WTE at least four feet below grade. The WTE has a sump and a leak detector, and the capability to transfer liquid in the sump to ASP process vessels. The WTE is equipped with a removable shield cover for access, if needed. The leak detector is interlocked to trip the H-Area Tank Farm transfer pump. The WTE and the sump leak detector alarm provide secondary containment and leak detection functions, respectively.

Encasement pipes drain to valve boxes or pump pits provided with leak detection. Valve box and pump pit leak detectors are provided to detect leakage originating from transfer line encasements or from valve manifolds or jumpers (i.e., steel pipes) in the valve boxes or pump pits.

WTLs external to the SWPF are located below grade for shielding purposes. These transfer lines are of a "pipe-in-pipe" design, in which the exterior pipe serves as a secondary containment boundary. Leak detectors are installed in the transfer line encasements and in the pits, valves, or pump boxes where the transfer lines terminate or connect to other transfer lines. Transfer line encasement, cell sump, valve box, and pump pit leak detectors will activate an alarm in the CRs of all interconnected facilities and activate an interlock to prevent or stop the operation of any transfer pump connected to the pathway.

### **4.7.3.3 Ventilation Systems**

The SWPF has four ventilation systems that filter air that could potentially contain radioactive contaminants. The primary airborne confinement boundary is provided by the Process Building Ventilation Exhaust System. This system maintains a cascaded airflow from normally occupied "clean" areas of the facility to potentially contaminated areas (Zone 2) and then to the process cells (Zone 3). The process cells' air is then filtered by one pre-filter and two stages of high-efficiency particulate air (HEPA) filter banks. The exhaust fans draw air through the HEPA filters and discharge it to the SWPF Exhaust Stack.

The process vessels and contactors used in the ASP or CSSX processes are maintained at a negative pressure, with respect to the process cells, by the Process Vessel Ventilation Systems (PVVS). This system draws air from the vapor space of the process vessels and from the contactor aqueous phase outlet nozzles into a mist eliminator, a pre-filter, and two stages of HEPA filters. The PVVS exhaust fans then discharge the filtered air to the SWPF Exhaust Stack.

A Pulse Mixer Ventilation System (PMVS) is also used to assist the Air Pulse Agitator (APA) system in mixing the process vessels. The APA alternately pressurizes and vents "pulse pots" located in the process vessels. When a pulse pot is pressurized by air, the liquid inside is discharged into the tank. After the liquid has been blown out of the pulse pot, the air supply is isolated and the PMVS draws a vacuum in the pulse pot to promote refilling with liquid from the tank. The periodic blow down and refilling of the pulse pots provides sufficient agitation to keep the tank contents well mixed. The PMVS design is identical to that of the PVVS, except that the PMVS is designed for a higher air flow.

The process vessels located in the AFF are vented through HEPA filters into the processing area. The AFF ventilation exhaust system operates in a similar manner to the Process Building Ventilation Exhaust system, and maintains a cascaded air flow from the normally occupied areas of the AFF to the process areas. The air from the AFF process areas is then drawn into a pre-filter and two stages of HEPA filter banks. The AFF ventilation exhaust fans discharge the filtered air to the SWPF Exhaust Stack.

## **4.7.4 Miscellaneous Process Systems**

### **4.7.4.1 Decontamination Area**

A Decontamination Area (Drum Off/Decon Area) is provided to allow decontamination of process equipment and miscellaneous plant items. Decontamination may be undertaken prior to performing maintenance on or shipping an equipment piece or component out of the SWPF. A local sump and transfer pump are installed to collect and transfer any spent decontamination fluids. Decon Area sump discharge can be routed to the ASDT, Drum Off Station, and DSSHT (see Attachment A).

The material collected in the Decon Area sump will typically be dispositioned back to various processes within the SWPF. Sump material that can not be dispositioned internally will be

characterized by SWPF personnel and then dispositioned in accordance with applicable SCDHEC Wastewater or Solid and Hazardous Waste Management Regulations.

#### **4.7.4.2 Drum Off Station**

A Drum Off Station is located in the Decon Room to allow removal of material from the process systems and sumps. Spent solvent in the CSSX Area is drained to the SDT or pumped from the SHT to the Drum Off Station to allow replacement. Liquid collected in cell sumps that may be incompatible with the process can also be transferred to the Drum Off Station. This could include cleaning or decontamination chemicals, propylene glycol from the Chilled Water System, or other miscellaneous materials (see Attachment A).

Waste drummed up in the Drum Off Station will be characterized by SWPF personnel and then dispositioned by existing Site facilities.

#### **4.7.5 Back-up Power**

Back-up power is provided to support process systems if normal Site-supplied power is lost. An Uninterruptible Power Supply (UPS) is provided for equipment required to operate continuously through voltage or frequency excursions, or during the momentary power loss that occurs before the back-up power source comes on-line and picks up essential electrical loads after a loss of normal power. The SWPF UPS consists of two sets of battery packs. Upon loss of normal power, UPS-1 and -2 provide continuous and distortion-free power. The batteries are sized to carry the required connected loads for at least 30 minutes.

A loss of supplied power results in a start signal to the back-up DG. Automatic transfer switches transfer the loads to the back-up power source after the DG starts. Power is then provided by the DG to systems essential to the wastewater treatment process. The DG is capable of automatically starting and reaching rated speed, and is capable of accepting a full load within 10 seconds after receiving a start signal. The DG provides power to charge both UPS battery banks when the standby busses are feeding the UPS units.

The DG day tank is refilled by a transfer pump connected to a storage tank that provides a four-day fuel supply. The DG is housed in a self-contained engineered structure with all support systems and the double-walled with leak detection day tank.

### **5.0 WASTE CHARACTERISTICS AND TREATABILITY**

The SWPF mission is to process 34 Mgal of salt waste presently stored in the SRS F- and H-Area Tank Farms. The salt waste is present in nearly equal proportions as precipitated salts or salt solution. The former is referred to as saltcake and the latter as supernate. Both saltcake and supernate are largely comprised of NaOH, sodium nitrate, and sodium nitrite. Dissolution of F- and H-Tank Farm saltcake and supernate for blending, transfer, and adjustment to 6.44M Na<sup>+</sup> will result in a total volume of approximately 84 Mgal of industrial wastewater. Some of this wastewater may be processed by the Actinide Removal Process (ARP) and Modular Caustic-side Solvent Extraction (CSSX) Unit prior to SWPF start-up. Some small quantity of low-curie (Ci)



salt may also be sent directly to the SPF prior to SWPF start-up. After SWPF start-up, all remaining wastewater will be processed by the SWPF. The current planning basis assumes that 74 Mgal of wastewater will be processed by the SWPF.

### **5.1 Wastewater Influent Characteristics and Flow Rate**

The SWPF Alpha Strike Process (ASP) is a batch process; therefore, the flow between the Tank Farm and SWPF is not continuous. The H-Area Tank Farm will blend macro-batches of approximately 0.3 – 1.2 Mgal each in an H-Area Tank Farm blend tank. The blended waste will then be transferred to an existing SRS permitted staging tank. The staging tank will then transfer 23,200-gallon batches to Alpha Sorption Tank-A (AST-A) at a flow rate of approximately 130 gallons per minute.

The SWPF is designed to have a maximum instantaneous processing rate of 9.4 Mgal per year.

Tank Farm liquid waste was primarily generated from spent nuclear fuel reprocessing at the F- and H-Canyons. Reprocessing used  $\text{HNO}_3$  dissolution that resulted in acidic Canyon wastewater effluents. The acid effluents were combined with NaOH to increase pH to a level suitable for long-term storage in carbon steel tanks. Caustic in excess of available nitrate, nitrite, and other available anions (such as sulfate and carbonate) remained as NaOH. In addition to these Na species, numerous chemical and radioactive species are present as trace amounts of soluble and insoluble chemical compounds. The insoluble solids or sludge components include a wide range of transition, rare earth, and alkali metal oxides, carbonates, nitrates, sulfates, and phosphates. Solids entrained in the saltcake and supernate comprise a minor component of the wastewater feed, with anticipated concentrations on the order of 10-1,200 milligrams per liter of wastewater. The nominal solids concentration of the SWPF waste feed is assumed to be 600 milligrams per liter. Handling higher solids concentrations will reduce throughput and will negatively impact Filter Feed Tank-A (FFT-A) concentrated batch size.

Tank Farm caustic waste was dewatered for storage through both passive and active evaporation, resulting in supernate and saltcake. The latter retains approximately 22% interstitial liquid. The initial pH adjustment and subsequent dehydration resulted in the creation of very high pH values in the remaining super-saturated liquid waste. After dissolution and blending, the wastewater feed is expected to have an average pH of  $13 \pm 2$ .

Tank Farm waste includes several radioactive isotopes and hazardous metals. Tank Farm salt wastewater includes over 50 radioactive isotopes; however, more than 95% of the activity is contributed by  $^{137}\text{Cs}$  and its short-lived daughter product,  $^{137\text{m}}\text{Ba}$ . Hazardous metals present in the wastewater include arsenic, mercury, cadmium, chromium, lead, selenium, Ba, and silver.

SWPF effluents are transferred to either the DWPF for vitrification as glass or to the SPF for solidification into a grout matrix known as saltstone grout. Because the SWPF does not discharge to surface waters, traditional wastewater analytical parameters such as Biological Oxygen Demand and Chemical Oxygen Demand are not analyzed.

## 5.2 Wastewater Treatability

SWPF processes are designed to remove Cs through the CSSX process, and Sr and actinides through the ASP and Alpha Finishing Process (AFP). Removal of these radioactive isotopes from wastewater reduces the concentration of these radionuclides to levels low enough to allow disposal at the SDF after treatment at the SPF. The operational effectiveness of the SWPF process is defined as the ability to remove and concentrate Sr, actinides, and Cs radionuclides from the Tank Farm feed. Laboratory- and pilot-scale testing established that MST sorption combined with filtration effectively removes and concentrates Sr and actinides, and that the CSSX process effectively removes and concentrates Cs.

The effectiveness of MST sorption and the resultant DF for Sr and actinides has been confirmed through testing (e.g., WSRC-TR-2004-00145: *Monosodium Titanate Multi-Strike Testing*<sup>8</sup>). The current baseline design assumed a 0.4 g/L mixture of MST and waste and 12 hours sorption time for a single MST strike, and 6 hours of sorption time for multi-strike operation. Table 5-1 summarizes the DFs used in the baseline design, established for 0.4 g/L concentrations of MST at 6.44M Na<sup>+</sup>.

**Table 5-1. SWPF ASP Decontamination Factors**

| Radionuclide | Single Strike Decontamination Factor (12-hour Sorption Time) | Multi-Strike Decontamination Factor Values |  |
|--------------|--|--|--|
|              |  | First-Strike (6-hour Sorption Time)        | Subsequent-Strike (6-hour Sorption Time) |
| Strontium    | 20   | 17   | 17                                       |
| Actinides:   |  |  |  |
| Plutonium    | 5.5  | 4.7  | 3.9                                      |
| Uranium      | 1.35   | 1.3  | 1.3                                      |
| Americium    | 4.6  | 3.4  | 1.5                                      |
| Neptunium    | 2.4  | 2.1  | 1.1                                      |

The SWPF can process industrial wastewater as many times as necessary by using the ASP/AFP. However, reliance on repeated MST strikes is less efficient and reduces throughput more than optimum blending of Tank Farm feed because blending ensures that the feed stream meets the SWPF WAC; blending of multiple waste streams removes waste from the Tank Farms, reducing overall risk, and places the waste into safer final storage.

Additionally, evaluation of sample analysis results performed by the Savannah River National Laboratory in 2003, from the SRS Tank Farm, shows that to meet the Saltstone Waste Acceptance Criteria for alpha-emitting transuranic radionuclides requires more than one MST strike for some tanks. In order to process these tanks without reducing throughput, and without requiring extensive blending, we have a separate strike capability.

The CSSX process has been extensively evaluated through bench-scale testing and demonstrated to effectively remove Cs from caustic solution with high concentrations of Na<sup>+</sup> (e.g., ANL-01/10: *Interim Report on a Multi-day Test of the Caustic-Side Solvent Extraction Flowsheet for Cesium Removal from a Simulated SRS Tank Waste*<sup>9</sup>; WSRC-TR-2001-00223:

*Demonstration of Caustic-Side Solvent Extraction with Savannah River Site High Level Waste<sup>10</sup>; and ORNL/TM-2001/278: Evaluation of Mass Transfer Performance for Caustic-Side Solvent Extraction of Cesium in a Conventional 5-cm Centrifugal Contactor<sup>11</sup>).*

The EPC performed pilot-scale tests in 2003 to evaluate potential effects associated with going from bench-scale to engineering-scale and to optimize CSSX Conceptual Design. Using non-radioactive simulated wastewater, the CSSX pilot scale test: 1) demonstrated that DF values are in agreement with bench-scale results; 2) identified optimum flow, temperature, rotor speed, and weir height for the contactors; 3) identified minor design changes needed to mitigate effects of fluid aeration and enhance solvent recovery (i.e., addition of stilling tanks upstream of the coalescers); and 4) demonstrated that recovery from off-normal conditions is easily managed.

Full-scale CSSX tests, performed by the EPC with non-radioactive simulated wastewater, have been conducted since the second half of the 2005 calendar year and are continuing. These tests are being performed to: 1) demonstrate the effectiveness of the CSSX process at full scale, 2) further optimize operating parameters, and 3) evaluate process modifications that were based on the engineering-scale test performed in 2003.

The SWPF design objective is to obtain a DF of  $\geq 40,000$  for Cs removal. Full-scale Testing performed by the EPC is showing that the DF value is readily achievable when utilizing 16 extraction contactor stages.

Hazardous metals and organic compounds must also meet SPF WAC. The SWPF only affects the concentration of these species indirectly through the chemical adjustment processes performed in the ASP, CSSX, and Alpha Finishing Facility (AFF) (e.g., Na<sup>+</sup> concentration adjustment, MST addition, and caustic addition). The Tank Farm will be responsible for blending individual waste tanks prior to staging for SWPF processing to ensure that the blended batches meet the SPF WAC for constituents not affected by SWPF processes. The SWPF WAC will establish limits on the concentration of metals and organic compounds in batches received from the Tank Farm to ensure that SWPF wastewater effluents will meet the SPF WAC.

### **5.3 Wastewater Effluent Characteristics and Flow Rate**

The SWPF produces three wastewater effluent streams including decontaminated salt solution (DSS), MST/sludge, and strip effluent. The SWPF acts as an industrial wastewater pretreatment process between the Tank Farm and DWPF and the Tank Farm and SPF. None of the three SWPF wastewater effluents is discharged to surface waters.

The SWPF produces two effluent streams that are transferred to DWPF for vitrification; including the MST/sludge effluent and strip effluent (see Figure 4-1). The MST/sludge effluent consists of 5 wt% solids concentrated in the ASP and AFP. The ASP/AFP concentrate comprises MST solids containing sorbed Sr and actinides, and incidentally entrained Tank Farm sludge solids. The strip effluent comprises the concentrated Cs stream from the CSSX process, containing up to 66 Ci of Cs per gallon. The Cs concentration in the strip effluent is approximately 15 times that of the clarified salt solution (CSS).

Table 5-2 summarizes current understanding of the SWPF MST/sludge and strip effluent characteristics and flow rates.

Prior testing has confirmed that the DSS produced by the SWPF can meet the proposed SPF WAC. Table 5-3 summarizes the flow rates and waste effluent characteristics, based on mass balance calculations that incorporate DFs for the ASP/AFP and CSSX processes.

**Table 5-2. SWPF MST/Sludge and Strip Effluent Characteristics**

| <b>Nominal Quantities/Flow Rates</b>   |                   |                       |
|--|-------------------|-----------------------|
|  | <b>MST/Sludge</b> | <b>Strip Effluent</b> |
| Effluent Quantity (gal/year)   | 131,000           | 603,000               |
| Effluent Production Rate (gal/day)   | 360               | 1,700                 |
| Total Alpha (Ci/gal)   | 0.09              | Negligible            |
| <sup>90</sup> Sr (Ci/gal)  | 4.25              | Negligible            |
| <sup>137</sup> Cs (Ci/gal)   | 0.77              | 66                    |
| Batch Working Volume (gal)   | 4,000 (SSRT)      | 16,000 (SEHT)         |
| Product Transfer Rate (gpm)  | 200               | 200                   |
| <b>Physical Characteristics of Effluent</b>  |                   |                       |
|  | <b>MST/Sludge</b> | <b>Strip Effluent</b> |
| Temperature, °C  | 10 to 40          | 10 to 40              |
| pH   | 13 ± 1            | 3 ± 1                 |
| Specific Gravity   | 1.44 ± 0.05       | 1.01 ± 0.01           |
| Viscosity, Centipoise  | 2.0 ± 0.05        | 1.1 ± 0.2             |
| C = Centigrade<br>Ci/gal = curies/gallon<br>Cs = Cesium<br>gal = gallon<br>gpm = Gallons per minute<br>MST = Monosodium Titanate<br>SEHT = Strip Effluent Hold Tank<br>Sr = Strontium<br>SSRT = Sludge Solids Receipt Tank |                   |                       |



## **6.2 Air Emissions**

### **6.2.1 Radiological Air Emissions**

Radiological emissions from the SWPF have been modeled in accordance with 40 CFR 61, Subpart H (*National Emission Standards for Radionuclides Other Than Radon from Department of Energy Facilities*<sup>12</sup>) and were determined to be below the exemption threshold of 0.1 millirem per year to the Maximally Exposed Off-Site Individual. Results of radiological air modeling are documented in the calculation Q-CLC-J-00001 (*SWPF Radionuclide Emissions during Normal Operations of Vented Process Vessels: Source Term Derivation, Air Dispersion and Total Effective Dose Rate Calculations Performed Pursuant to 40 CFR 61.96(b)*<sup>13</sup>).

### **6.2.2 Toxic and Criteria Pollutant Emissions**

SWPF emissions of toxic and criteria pollutants were determined to be below exemption threshold emission rates established in TV-0080-0041 (*Savannah River Site Part 70 Air Quality (Title V Operating) Permit*<sup>14</sup>), as well as emission rate thresholds established in SCR 61-62 (*Air Pollution Control Regulations and Standards*<sup>15</sup>) for toxic and criteria air pollutants. Mercury, HNO<sub>3</sub>, and methanol were shown to have maximum emission rates under 0.05 pounds per hour (lb/hr), the exemption threshold for toxic air pollutants. Nitrogen dioxide and ozone (volatile organic compounds as an ozone precursor) were shown to have emission rates below 0.5 lb/hr, the exemption threshold emission rate for criteria pollutants in TV-0080-0041. The results of emission calculations are contained in Q-PER-J-00001 (*SWPF: Air Quality Permit Exemption Request for Toxic Air and Criteria Pollutant Emissions: Engineering Report*<sup>16</sup>).

The above SWPF emission calculations and supporting reports demonstrating that emission rates are below exemption thresholds have been submitted to the SRS Permit custodians for review and concurrence. These calculations and reports are available to SCDHEC for review.

## **6.3 Title V Operating Permit**

A DG and 10,000-gallon fuel supply tank will be installed and operated only when 1) power is lost, and 2) to conduct periodic preventive maintenance. The preventive maintenance will utilize less than 100 hours/year. The DG and fuel tank will require a modification to TV-0080-0041 (*Savannah River Site Part 70 Air Quality [Title V] Operating Permit*<sup>17</sup>). This modification will be filed prior to the date of placing the DG into service.

## **7.0 REFERENCES**

- <sup>1</sup> SCR 61-67, *South Carolina Standards for Wastewater Facility Construction*. South Carolina Department of Health and Environmental Control, Columbia, South Carolina. May 24, 2002.
- <sup>2</sup> SCR10H152, Coverage granted under SCR100000 on September 14, 2007; expires September 14, 2012. (SWPF-specific coverage number under SCR1000000). Coverage

---

grant contained in a letter from Martens, Jan (Stormwater, Dams & Agricultural permitting Section, SCDHEC) to David B. Amerine (Parsons): Subject: "Salt Waste Processing Facility, J-Area, Aiken, County: File number: 02-07-08-07". Dated September 14, 2007.

- <sup>3</sup> Permit No. SCR100000, *South Carolina NPDES General Permit For Storm Water Discharges From Large and Small Construction Activities*. South Carolina Department of Health and Environmental Control, Bureau of Water, Columbia, South Carolina. Issued April 1, 2006; Effective September 1, 2006; Expires August 31, 2011.
  - <sup>4</sup> WSRC-TR-94-0608, *Approved Site Treatment Plan*, Revision 13. Westinghouse Savannah River Company, Aiken, South Carolina. November 2005.
  - <sup>5</sup> WSRC-OS-94-92, *Federal Facility Agreement for the Savannah River Site*. Administrative Docket No. 89-05-FF. Westinghouse Savannah River Company, Aiken, South Carolina. Effective date August 16, 1993.
  - <sup>6</sup> DOE/EIS-0082-S2, *Savannah River Site Salt Processing Alternatives Final Supplemental Environmental Impact Statement*. U.S. Department of Energy, Savannah River Operations Office, Aiken, South Carolina. June 2001.
  - <sup>7</sup> *Record of Decision: Savannah River Site Salt Processing Alternatives*. U.S. Department of Energy, Washington, D.C. Published in the Federal Register: October 17, 2001 (Volume 66, Number 201, Page 52752), and amended as published in the Federal Register: January 24, 2006 (Volume 71, Number 15, Page 3834).
  - <sup>8</sup> WSRC-TR-2004-00145, *Monosodium Titanate Multi-Strike Testing*, Revision 0. Authors: Barnes, M.J., F.F. Fondeur, D.T. Hobbs, and S.D. Fink. Westinghouse Savannah River Company, Aiken, South Carolina. April 29, 2004.
  - <sup>9</sup> ANL-01/10, *Interim Report on a Multi-day Test of the Caustic-Side Solvent Extraction Flowsheet for Cesium Removal from a Simulated SRS Tank Waste*. Argonne National Laboratory, Argonne, Illinois. April 2001.
  - <sup>10</sup> WSRC-TR-2001-00223, *Demonstration of Caustic-Side Solvent Extraction with Savannah River Site High Level Waste*, Revision 0. Westinghouse Savannah River Company, Aiken, South Carolina. April 2001.
  - <sup>11</sup> ORNL/TM-2001/278, *Evaluation of Mass Transfer Performance for Caustic-Side Solvent Extraction of Cesium in a Conventional 5-cm Centrifugal Contactor*. Oak Ridge National Laboratory, Oak Ridge, Tennessee. January 2002.
  - <sup>12</sup> 40 CFR 61, Subpart H, Protection of Environment: Chapter I, Environmental Protection Agency: National emission standards for hazardous air pollutants: *National Emission*
-

---

*Standards for Radionuclides Other Than Radon from Department of Energy Facilities.*  
Revised July 1, 2007.

- <sup>13</sup> Q-CLC-J-00001, *Salt Waste Processing Facility Project Radionuclide Emissions during Normal Operations of Vented Process Vessels: Source Term Derivation, Air Dispersion and Total Effective Dose Rate Calculations Performed Pursuant to 40 CFR 61.96(b),* Revision 0. Parsons, Aiken, South Carolina.
  - <sup>14</sup> TV-0080-0041, *Savannah River Site Part 70 Air Quality (Title V Operating) Permit.* South Carolina Department of Health and Environmental Control, Columbia, South Carolina. Issued February 19, 2003.
  - <sup>15</sup> SCR 61-62, *Air Pollution Control Regulations and Standards.* Bureau of Air Quality, South Carolina Department of Health and Environmental Control, Columbia, South Carolina. Effective June 27, 2007.
  - <sup>16</sup> Q-PER-J-00001, *Salt Waste Processing Facility Project: Air Quality Permit Exemption Request for Toxic Air and Criteria Pollutant Emissions: Engineering Report.* Parsons, Aiken, South Carolina.
  - <sup>17</sup> TV-0080-0041, *Savannah River Site Part 70 Air Quality (Title V Operating) Permit.* South Carolina Department of Health and Environmental Control, Columbia, South Carolina. Issued February 19, 2003, as amended.
-



**Attachment A. Process Building General Arrangement**

1. G-P1-J-00001, *SWPF Process Building General Arrangement Drawing Index, Symbols, Abbreviations, Equipment Designations and General Notes (U)*

**NOTE** The following drawings withheld due to sensitive information determined by DOE Security to be unsuited for release to the public.

2. P-PG-J-0002, *SWPF Process Building General Arrangement Index Key Plan (U)*
3. P-PG-J-0003, *SWPF Process Building General Arrangement Central Process Area Plan at Elevation 100'-0" (Unless Otherwise Noted) (U)*
4. P-PG-J-0004, *SWPF Process Building General Arrangement Cold Chemicals Area Plan at Elevation 100'-0" (U)*
5. P-PG-J-0005, *SWPF Process Building General Arrangement Northern Facility Support Area Plan at Elevation 100'-0" (U)*
6. P-PG-J-0006, *SWPF Process Building General Arrangement Eastern Facility Support Area Plan at Elevation 100'-0" (U)*
7. P-PG-J-0007, *SWPF Alpha Finishing Facility General Arrangement Alpha Finishing Facility Plan at Elevation 100'-0" (Unless Otherwise Noted) (U)*
8. P-PG-J-0008, *SWPF Process Building General Arrangement Central Process Area Plan at Elevation 116'-0" (Unless Otherwise Noted) (U)*
9. P-PG-J-0009, *SWPF Process Building General Arrangement Central Process Area Plan at Elevation 124'-0" (U)*
10. P-PG-J-0010, *SWPF Process Building General Arrangement Central Process Area Plan at Elevation 139'-0" (U)*


**S. C. DEPT. OF HEALTH & ENVIRONMENTAL CONTROL  
BUREAU OF WATER**

**WASTEWATER FACILITIES  
APPROVED FOR CONSTRUCTION**

(SUBJECT TO ANY PROVISIONS WHICH MAY  
APPEAR IN THE CONSTRUCTION PERMIT.)

FINAL WRITTEN APPROVAL FOR OPERATION MUST  
BE OBTAINED FROM THIS OFFICE AFTER COM-  
PLETION OF CONSTRUCTION.

PERMIT NO. 19,219-IW DATE Aug. 6, 2008



DIRECTOR, WATER FACILITIES PERMITTING DIVISION